

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/12/2016
Received: 10/20/2016
Sampled By: Troy Thompson
Work Order: 6295004


C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: North High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6295004-01	Sample Name: NHS139 F Sampled: 10/20/16 4:40		Matrix: Water				
+Lead	1030	EPA 200.9	5.0	ppb	2.0	20 ppb	12/07/16 16:39
6295004-02	Sample Name: NHS140 DF Sampled: 10/20/16 4:40		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6295004-03	Sample Name: NHS141 Bradley Sampled: 10/20/16 4:40		Matrix: Water				
+Lead	1030	EPA 200.9	3.5	ppb	2.0	20 ppb	12/07/16 16:39
6295004-04	Sample Name: NHS142 Bradley Sampled: 10/20/16 4:40		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6295004-05	Sample Name: NHS143 F Sampled: 10/20/16 4:41		Matrix: Water				
+Lead	1030	EPA 200.9	29.5	ppb	2.0	20 ppb	12/07/16 16:39 MCLE
6295004-06	Sample Name: NHS144 F Sampled: 10/20/16 4:44		Matrix: Water				
+Lead	1030	EPA 200.9	34.1	ppb	2.0	20 ppb	12/07/16 16:39 MCLE
6295004-07	Sample Name: NHS145 F Sampled: 10/20/16 4:44		Matrix: Water				
+Lead	1030	EPA 200.9	57.2	ppb	4.0	20 ppb	12/07/16 16:39 MCLE
6295004-08	Sample Name: NHS146 F Sampled: 10/20/16 4:44		Matrix: Water				
+Lead	1030	EPA 200.9	43.2	ppb	4.0	20 ppb	12/07/16 16:39 MCLE
6295004-09	Sample Name: NHS147 F Sampled: 10/20/16 4:47		Matrix: Water				
+Lead	1030	EPA 200.9	23.1	ppb	2.0	20 ppb	12/07/16 16:39 MCLE
6295004-10	Sample Name: NHS148 F Sampled: 10/20/16 4:47		Matrix: Water				
+Lead	1030	EPA 200.9	87.6	ppb	8.0	20 ppb	12/07/16 16:39 MCLE



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/12/2016
Received: 10/20/2016
Sampled By: Troy Thompson
Work Order: 6295004


C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: North High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6295004-11	Sample Name: NHS149 F Sampled: 10/20/16 4:47		Matrix: Water				
+Lead	1030	EPA 200.9	236	ppb	20.0	20 ppb	12/07/16 16:39 MCLE
6295004-12	Sample Name: NHS150 F Sampled: 10/20/16 4:47		Matrix: Water				
+Lead	1030	EPA 200.9	128	ppb	8.0	20 ppb	12/07/16 16:39 MCLE
6295004-13	Sample Name: NHS151 F Sampled: 10/20/16 4:47		Matrix: Water				
+Lead	1030	EPA 200.9	36.0	ppb	4.0	20 ppb	12/07/16 16:39 MCLE
6295004-14	Sample Name: NHS152 F Sampled: 10/20/16 4:48		Matrix: Water				
+Lead	1030	EPA 200.9	37.8	ppb	4.0	20 ppb	12/07/16 16:39 MCLE
6295004-15	Sample Name: NHS153 F Sampled: 10/20/16 4:48		Matrix: Water				
+Lead	1030	EPA 200.9	23.6	ppb	2.0	20 ppb	12/07/16 16:39 MCLE
6295004-16	Sample Name: NHS154 F Sampled: 10/20/16 4:49		Matrix: Water				
+Lead	1030	EPA 200.9	105	ppb	8.0	20 ppb	12/07/16 16:39 MCLE
6295004-17	Sample Name: NHS155 F Sampled: 10/20/16 4:50		Matrix: Water				
+Lead	1030	EPA 200.9	53.1	ppb	4.0	20 ppb	12/07/16 16:39 MCLE
6295004-18	Sample Name: NHS156 F Sampled: 10/20/16 4:50		Matrix: Water				
+Lead	1030	EPA 200.9	44.0	ppb	4.0	20 ppb	12/07/16 16:39 MCLE
6295004-19	Sample Name: NHS157 F Sampled: 10/20/16 4:57		Matrix: Water				
+Lead	1030	EPA 200.9	38.3	ppb	4.0	20 ppb	12/07/16 16:39 MCLE
6295004-20	Sample Name: NHS158 F Sampled: 10/20/16 4:57		Matrix: Water				
+Lead	1030	EPA 200.9	78.9	ppb	8.0	20 ppb	12/07/16 16:39 MCLE



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/12/2016
Received: 10/20/2016
Sampled By: Troy Thompson
Work Order: 6295004


C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: North High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6295004-21	Sample Name: NHS159 F Sampled: 10/20/16 4:57		Matrix: Water				
+Lead	1030	EPA 200.9	60.4	ppb	4.0	20 ppb	12/07/16 16:39 MCLE
6295004-22	Sample Name: NHS160 F Sampled: 10/20/16 4:59		Matrix: Water				
+Lead	1030	EPA 200.9	52.8	ppb	4.0	20 ppb	12/07/16 16:39 MCLE
6295004-23	Sample Name: NHS161 F Sampled: 10/20/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	66.1	ppb	4.0	20 ppb	12/09/16 15:15 MCLE
6295004-24	Sample Name: NHS162 F Sampled: 10/20/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	37.8	ppb	2.0	20 ppb	12/09/16 15:15 MCLE
6295004-25	Sample Name: NHS163 F Sampled: 10/20/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	48.4	ppb	4.0	20 ppb	12/09/16 15:15 MCLE
6295004-26	Sample Name: NHS164 F Sampled: 10/20/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	44.5	ppb	4.0	20 ppb	12/09/16 15:15 MCLE
6295004-27	Sample Name: NHS165 F Sampled: 10/20/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	5.6	ppb	2.0	20 ppb	12/09/16 15:15
6295004-28	Sample Name: NHS166 Bradley Sampled: 10/20/16 5:02		Matrix: Water				
+Lead	1030	EPA 200.9	11.5	ppb	2.0	20 ppb	12/09/16 15:15
6295004-29	Sample Name: NHS167 Bradley Sampled: 10/20/16 5:02		Matrix: Water				
+Lead	1030	EPA 200.9	7.2	ppb	2.0	20 ppb	12/09/16 15:15
6295004-30	Sample Name: NHS168 DF Sampled: 10/20/16 5:04		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/09/16 15:15



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013


Reported: 12/12/2016
Received: 10/20/2016
Sampled By: Troy Thompson
Work Order: 6295004

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: North High School

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6295004-31	Sample Name: NHS169 F Sampled: 10/20/16 5:07		Matrix: Water				
+Lead	1030	EPA 200.9	5.3	ppb	2.0	20 ppb	12/09/16 15:15
6295004-32	Sample Name: NHS170 Ice maker Sampled: 10/20/16 5:07		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/09/16 15:15
6295004-33	Sample Name: NHS171 DF Sampled: 10/20/16 5:07		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/09/16 15:15
6295004-34	Sample Name: NHS172 DF Sampled: 10/20/16 5:08		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/09/16 15:15
6295004-35	Sample Name: NHS173 DF Sampled: 10/20/16 5:08		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/09/16 15:15
6295004-36	Sample Name: NHS174 F Sampled: 10/20/16 5:09		Matrix: Water				
+Lead	1030	EPA 200.9	2.2	ppb	2.0	20 ppb	12/09/16 15:15
6295004-37	Sample Name: NHS175 DF Sampled: 10/20/16 5:12		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/09/16 15:15
6295004-38	Sample Name: NHS176 Bradley Sampled: 10/20/16 5:12		Matrix: Water				
+Lead	1030	EPA 200.9	19.6	ppb	2.0	20 ppb	12/09/16 15:15
6295004-39	Sample Name: NHS178 F Sampled: 10/20/16 5:18		Matrix: Water				
+Lead	1030	EPA 200.9	11.2	ppb	2.0	20 ppb	12/09/16 15:15
6295004-40	Sample Name: NHS180 F Sampled: 10/20/16 5:20		Matrix: Water				
+Lead	1030	EPA 200.9	8.3	ppb	2.0	20 ppb	12/09/16 15:15



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/12/2016
Received: 10/20/2016
Sampled By: Troy Thompson
Work Order: 6295004


C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N
T Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: North High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6295004-41	Sample Name: NHS181 Bradley Sampled: 10/20/16 5:20		Matrix: Water				
+Lead	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	12/09/16 15:15
6295004-42	Sample Name: NHS182 Bradley Sampled: 10/20/16 5:20		Matrix: Water				
+Lead	1030	EPA 200.9	7.9	ppb	2.0	20 ppb	12/09/16 15:15
6295004-43	Sample Name: NHS185 F Sampled: 10/20/16 5:26		Matrix: Water				
+Lead	1030	EPA 200.9	3.4	ppb	2.0	20 ppb	12/09/16 15:15
6295004-44	Sample Name: NHS186 F Sampled: 10/20/16 5:30		Matrix: Water				
+Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	12/09/16 15:15
6295004-45	Sample Name: NHS187 F Sampled: 10/20/16 5:31		Matrix: Water				
+Lead	1030	EPA 200.9	7.6	ppb	2.0	20 ppb	12/09/16 15:15
6295004-46	Sample Name: NHS188 F Sampled: 10/20/16 5:40		Matrix: Water				
+Lead	1030	EPA 200.9	6.2	ppb	2.0	20 ppb	12/09/16 15:15
6295004-47	Sample Name: NHS196 F Sampled: 10/20/16 5:42		Matrix: Water				
+Lead	1030	EPA 200.9	12.3	ppb	2.0	20 ppb	12/09/16 15:15
6295004-48	Sample Name: NHS 189 F Sampled: 10/20/16 5:42		Matrix: Water				
+Lead	1030	EPA 200.9	16.8	ppb	2.0	20 ppb	12/09/16 15:15
6295004-49	Sample Name: NHS190 F Sampled: 10/20/16 5:43		Matrix: Water				
+Lead	1030	EPA 200.9	28.2	ppb	2.0	20 ppb	12/09/16 15:15 MCL
6295004-50	Sample Name: NHS191 Bradley Sampled: 10/20/16 5:43		Matrix: Water				
+Lead	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	12/09/16 15:15



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/12/2016
Received: 10/20/2016
Sampled By: Troy Thompson
Work Order: 6295004

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: North High School

Lab Number


	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6295004-51	Sample Name: NHS192 Bradley Sampled: 10/20/16 5:46		Matrix: Water				
†Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	12/09/16 15:15
6295004-52	Sample Name: NHS193 F Sampled: 10/20/16 5:46		Matrix: Water				
†Lead	1030	EPA 200.9	3.5	ppb	2.0	20 ppb	12/09/16 15:15
6295004-53	Sample Name: NHS194 F Sampled: 10/20/16 5:46		Matrix: Water				
†Lead	1030	EPA 200.9	33.3	ppb	2.0	20 ppb	12/09/16 15:15 MCLE
6295004-54	Sample Name: NHS195 F Sampled: 10/20/16 5:47		Matrix: Water				
†Lead	1030	EPA 200.9	20.0	ppb	2.0	20 ppb	12/09/16 15:15

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.