

**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 12/14/2016  
Received: 10/20/2016  
Sampled By: Troy Thompson  
Work Order: 6295019


**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: North High School

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6295019-01</b>	<b>Sample Name:</b> NHS-43F <b>Sampled:</b> 10/18/16 5:21		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	9.4	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-02</b>	<b>Sample Name:</b> NHS-44F <b>Sampled:</b> 10/18/16 5:21		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7.3	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-03</b>	<b>Sample Name:</b> NHS-45F <b>Sampled:</b> 10/18/16 5:22		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7.7	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-04</b>	<b>Sample Name:</b> NHS-46F <b>Sampled:</b> 10/18/16 5:22		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	11.2	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-05</b>	<b>Sample Name:</b> NHS-47F <b>Sampled:</b> 10/18/16 5:24		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	18.5	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-06</b>	<b>Sample Name:</b> NHS-48F <b>Sampled:</b> 10/18/16 5:24		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	6.4	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-07</b>	<b>Sample Name:</b> NHS-49F <b>Sampled:</b> 10/18/16 5:26		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.7	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-08</b>	<b>Sample Name:</b> NHS-50F <b>Sampled:</b> 10/18/16 5:26		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-09</b>	<b>Sample Name:</b> NHS-51F <b>Sampled:</b> 10/18/16 5:28		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-10</b>	<b>Sample Name:</b> NHS-52F <b>Sampled:</b> 10/18/16 5:28		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	10.8	ppb	2.0	20 ppb	12/12/16 15:59



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013


Reported: 12/14/2016  
Received: 10/20/2016  
Sampled By: Troy Thompson  
Work Order: 6295019

**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: North High School

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6295019-11</b>	<b>Sample Name:</b> NHS-53F <b>Sampled:</b> 10/18/16 5:28		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.1	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-12</b>	<b>Sample Name:</b> NHS-54F <b>Sampled:</b> 10/18/16 5:28		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7.1	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-13</b>	<b>Sample Name:</b> NHS-55F <b>Sampled:</b> 10/18/16 5:28		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.4	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-14</b>	<b>Sample Name:</b> NHS-56F <b>Sampled:</b> 10/18/16 5:29		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	12.5	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-15</b>	<b>Sample Name:</b> NHS-57F <b>Sampled:</b> 10/18/16 5:29		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.4	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-16</b>	<b>Sample Name:</b> NHS-58F <b>Sampled:</b> 10/18/16 5:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7.0	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-17</b>	<b>Sample Name:</b> NHS-59F <b>Sampled:</b> 10/18/16 5:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	10.6	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-18</b>	<b>Sample Name:</b> NHS-60F <b>Sampled:</b> 10/18/16 5:31		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	5.3	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-19</b>	<b>Sample Name:</b> NHS-61F <b>Sampled:</b> 10/18/16 5:31		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7.2	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-20</b>	<b>Sample Name:</b> NHS-62F <b>Sampled:</b> 10/18/16 5:32		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.4	ppb	2.0	20 ppb	12/12/16 15:59



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 12/14/2016  
Received: 10/20/2016  
Sampled By: Troy Thompson  
Work Order: 6295019


**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: North High School

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6295019-21</b>	<b>Sample Name:</b> NHS-63F <b>Sampled:</b> 10/18/16 5:32		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	6.1	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-22</b>	<b>Sample Name:</b> NHS-64F <b>Sampled:</b> 10/18/16 5:32		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7.0	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-23</b>	<b>Sample Name:</b> NHS-65F <b>Sampled:</b> 10/18/16 5:33		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-24</b>	<b>Sample Name:</b> NHS-66F <b>Sampled:</b> 10/18/16 5:34		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	10.9	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-25</b>	<b>Sample Name:</b> NHS-67F <b>Sampled:</b> 10/18/16 5:34		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8.3	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-26</b>	<b>Sample Name:</b> NHS-68F <b>Sampled:</b> 10/18/16 5:34		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7.3	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-27</b>	<b>Sample Name:</b> NHS-69F <b>Sampled:</b> 10/18/16 5:36		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.6	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-28</b>	<b>Sample Name:</b> NHS-70F <b>Sampled:</b> 10/18/16 5:36		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7.1	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-29</b>	<b>Sample Name:</b> NHS-71F <b>Sampled:</b> 10/18/16 5:37		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	6.1	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-30</b>	<b>Sample Name:</b> NHS-72F <b>Sampled:</b> 10/18/16 5:37		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	6.8	ppb	2.0	20 ppb	12/12/16 15:59



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013


Reported: 12/14/2016  
Received: 10/20/2016  
Sampled By: Troy Thompson  
Work Order: 6295019

**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: North High School

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6295019-31</b>	<b>Sample Name:</b> NHS-73F <b>Sampled:</b> 10/18/16 5:37		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	10.8	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-36</b>	<b>Sample Name:</b> NHS-74F <b>Sampled:</b> 10/18/16 5:39		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.9	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-37</b>	<b>Sample Name:</b> NHS-75F <b>Sampled:</b> 10/18/16 5:40		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8.8	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-38</b>	<b>Sample Name:</b> NHS-76F <b>Sampled:</b> 10/18/16 5:40		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	11.3	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-39</b>	<b>Sample Name:</b> NHS-77F <b>Sampled:</b> 10/18/16 5:42		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	9.7	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-40</b>	<b>Sample Name:</b> NHS-78F <b>Sampled:</b> 10/18/16 5:42		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	5.7	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-41</b>	<b>Sample Name:</b> NHS-79F <b>Sampled:</b> 10/18/16 5:42		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.7	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-42</b>	<b>Sample Name:</b> NHS-80F <b>Sampled:</b> 10/18/16 5:42		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.5	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-43</b>	<b>Sample Name:</b> NHS-81F <b>Sampled:</b> 10/18/16 5:43		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	5.0	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-44</b>	<b>Sample Name:</b> NHS-82F <b>Sampled:</b> 10/18/16 5:43		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8.1	ppb	2.0	20 ppb	12/12/16 15:59



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/14/2016  
Received: 10/20/2016  
Sampled By: Troy Thompson  
Work Order: 6295019

**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: North High School

## Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6295019-45</b>	<b>Sample Name:</b> NHS-83F <b>Sampled:</b> 10/18/16 5:44		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	7.7	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-46</b>	<b>Sample Name:</b> NHS-84F <b>Sampled:</b> 10/18/16 5:45		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	15.0	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-47</b>	<b>Sample Name:</b> NHS-85F <b>Sampled:</b> 10/18/16 5:45		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	14.5	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-48</b>	<b>Sample Name:</b> NHS-86F <b>Sampled:</b> 10/18/16 5:46		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	19.4	ppb	2.0	20 ppb	12/12/16 15:59
<b>6295019-49</b>	<b>Sample Name:</b> NHS-87F <b>Sampled:</b> 10/18/16 5:46		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	<b>25.8</b>	ppb	2.0	20 ppb	12/12/16 15:59 <b>MCLE</b>
<b>6295019-50</b>	<b>Sample Name:</b> NHS-88F <b>Sampled:</b> 10/18/16 5:47		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	8.8	ppb	2.0	20 ppb	12/12/16 15:59

**MCLE** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: \_\_\_\_\_

  
Adriana Gonzalez-Gray  
Laboratory Director

