

13035 SW Pacific Hwy
 Tigard, OR 97223
 Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
 Laboratory
 Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/22/2016
 Received: 10/20/2016
 Sampled By: Troy Thompson
 Work Order: 6298013


**C
 L
 I
 E
 N
 T** **David Douglas School District**
 Attn: -
 11300 NE Halsey St
 Portland OR, 97220
 Phone: (503) 252-2900

Project:
 Project # : N/A
 Sample Type :

Sampling Location: North High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298013-01	Sample Name: NHS01F Sampled: 10/20/16 4:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/19/16 17:04
6298013-02	Sample Name: NHS02F Sampled: 10/20/16 4:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/19/16 17:04
6298013-03	Sample Name: NHS03F Sampled: 10/20/16 4:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/19/16 17:04
6298013-04	Sample Name: NHS04SP Sampled: 10/20/16 4:01		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/19/16 17:04
6298013-05	Sample Name: NHS05F Sampled: 10/20/16 4:02		Matrix: Water				
+Lead	1030	EPA 200.9	10.5	ppb	2.0	20 ppb	12/21/16 17:09
6298013-06	Sample Name: NHS07F Sampled: 10/20/16 4:03		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/21/16 17:09
6298013-07	Sample Name: NHS08SP Sampled: 10/20/16 4:03		Matrix: Water				
+Lead	1030	EPA 200.9	5.6	ppb	2.0	20 ppb	12/21/16 17:09
6298013-08	Sample Name: NHS09F Sampled: 10/20/16 4:04		Matrix: Water				
+Lead	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	12/21/16 17:09
6298013-09	Sample Name: NSH10F Sampled: 10/20/16 4:08		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/21/16 17:09
6298013-10	Sample Name: NHS11F Sampled: 10/20/16 4:10		Matrix: Water				
+Lead	1030	EPA 200.9	6.7	ppb	2.0	20 ppb	12/21/16 17:09



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/22/2016
Received: 10/20/2016
Sampled By: Troy Thompson
Work Order: 6298013


C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: North High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298013-11	Sample Name: NHS12F Sampled: 10/20/16 4:10		Matrix: Water				
+Lead	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	12/21/16 17:09
6298013-12	Sample Name: NHS13DF Sampled: 10/20/16 4:12		Matrix: Water				
+Lead	1030	EPA 200.9	4.8	ppb	2.0	20 ppb	12/21/16 17:09
6298013-13	Sample Name: NHS14DF Sampled: 10/20/16 4:12		Matrix: Water				
+Lead	1030	EPA 200.9	8.3	ppb	2.0	20 ppb	12/21/16 17:09
6298013-14	Sample Name: NHS15F Sampled: 10/20/16 4:12		Matrix: Water				
+Lead	1030	EPA 200.9	3.7	ppb	2.0	20 ppb	12/21/16 17:09
6298013-15	Sample Name: NHS16Bradley Sampled: 10/20/16 4:13		Matrix: Water				
+Lead	1030	EPA 200.9	3.8	ppb	2.0	20 ppb	12/21/16 17:09
6298013-16	Sample Name: NHS17Bradley Sampled: 10/20/16 4:15		Matrix: Water				
+Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	12/21/16 17:09
6298013-17	Sample Name: NHS18DF Sampled: 10/20/16 4:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/21/16 17:09
6298013-18	Sample Name: NHS23F Sampled: 10/20/16 4:22		Matrix: Water				
+Lead	1030	EPA 200.9	11.0	ppb	2.0	20 ppb	12/21/16 17:09
6298013-19	Sample Name: NHS24F Sampled: 10/20/16 4:22		Matrix: Water				
+Lead	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	12/21/16 17:09
6298013-20	Sample Name: NHS25F Sampled: 10/20/16 4:22		Matrix: Water				
+Lead	1030	EPA 200.9	8.0	ppb	2.0	20 ppb	12/21/16 17:09



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/22/2016
Received: 10/20/2016
Sampled By: Troy Thompson
Work Order: 6298013


C **David Douglas School District**
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: North High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298013-21	Sample Name: NHS26F		Matrix: Water				
	Sampled: 10/20/16 4:25						
+Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	12/21/16 17:09
6298013-22	Sample Name: NHS29F		Matrix: Water				
	Sampled: 10/18/16 5:10						
+Lead	1030	EPA 200.9	2.5	ppb	2.0	20 ppb	12/21/16 17:09
6298013-23	Sample Name: NHS30F		Matrix: Water				
	Sampled: 10/18/16 5:11						
+Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	12/21/16 17:09
6298013-24	Sample Name: NHS31F		Matrix: Water				
	Sampled: 10/18/16 5:12						
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/21/16 17:09
6298013-25	Sample Name: NHS32F		Matrix: Water				
	Sampled: 10/18/16 5:13						
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/21/16 17:09
6298013-26	Sample Name: NHS184F		Matrix: Water				
	Sampled: 10/18/16 5:14						
+Lead	1030	EPA 200.9	15.2	ppb	2.0	20 ppb	12/21/16 17:09
6298013-27	Sample Name: NHS33F		Matrix: Water				
	Sampled: 10/18/16 5:15						
+Lead	1030	EPA 200.9	8.6	ppb	2.0	20 ppb	12/21/16 17:09
6298013-28	Sample Name: NHS34F		Matrix: Water				
	Sampled: 10/18/16 5:15						
+Lead	1030	EPA 200.9	7.8	ppb	2.0	20 ppb	12/21/16 17:09
6298013-29	Sample Name: NHS35F		Matrix: Water				
	Sampled: 10/18/16 5:16						
+Lead	1030	EPA 200.9	5.7	ppb	2.0	20 ppb	12/21/16 17:09
6298013-30	Sample Name: NHS36F		Matrix: Water				
	Sampled: 10/18/16 5:16						
+Lead	1030	EPA 200.9	5.5	ppb	2.0	20 ppb	12/21/16 17:09



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/22/2016
Received: 10/20/2016
Sampled By: Troy Thompson
Work Order: 6298013

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: North High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298013-31	Sample Name: NHS37F Sampled: 10/18/16 5:16		Matrix: Water				
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	12/21/16 17:09
6298013-32	Sample Name: NHS38F Sampled: 10/18/16 5:18		Matrix: Water				
+Lead	1030	EPA 200.9	5.2	ppb	2.0	20 ppb	12/21/16 17:09
6298013-33	Sample Name: NHS39F Sampled: 10/18/16 5:18		Matrix: Water				
+Lead	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	12/21/16 17:09
6298013-34	Sample Name: NHS40F Sampled: 10/18/16 5:19		Matrix: Water				
+Lead	1030	EPA 200.9	5.6	ppb	2.0	20 ppb	12/21/16 17:09
6298013-35	Sample Name: NHS41F Sampled: 10/18/16 5:19		Matrix: Water				
+Lead	1030	EPA 200.9	8.1	ppb	2.0	20 ppb	12/21/16 17:09
6298013-36	Sample Name: NHS42F Sampled: 10/18/16 5:21		Matrix: Water				
+Lead	1030	EPA 200.9	8.5	ppb	2.0	20 ppb	12/21/16 17:09

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.