

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/19/2016
Received: 10/20/2016
Sampled By: Troy Thompson
Work Order: 6298020

C **David Douglas School District**
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Performing Arts Center

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298020-01	Sample Name: PAC01 F Sampled: 10/18/16 4:17		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6298020-02	Sample Name: PAC02 DF Sampled: 10/18/16 4:17		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6298020-03	Sample Name: PAC03 DF Sampled: 10/18/16 4:18		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6298020-04	Sample Name: PAC04 DF Sampled: 10/18/16 4:19		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6298020-05	Sample Name: PAC05 DF Sampled: 10/18/16 4:20		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6298020-06	Sample Name: PAC06 DF Sampled: 10/18/16 4:20		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6298020-07	Sample Name: PAC07 DF Sampled: 10/18/16 4:22		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6298020-08	Sample Name: PAC08 F Sampled: 10/18/16 4:24		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6298020-09	Sample Name: PAC09 DF Sampled: 10/18/16 4:24		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6298020-10	Sample Name: PAC10 DF Sampled: 10/18/16 4:25		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/19/2016
Received: 10/20/2016
Sampled By: Troy Thompson
Work Order: 6298020


**C
L
I
E
N
T**
David Douglas School District
Attn: -
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:

Project # : N/A
Sample Type :

Sampling Location: Performing Arts Center

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298020-11	Sample Name: PAC11 Bradley Sampled: 10/18/16 4:26		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6298020-12	Sample Name: PAC12 Bradley Sampled: 10/18/16 4:26		Matrix: Water				
+Lead	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	12/14/16 16:30
6298020-13	Sample Name: PAC13 F Sampled: 10/18/16 4:27		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6298020-14	Sample Name: PAC14 F Sampled: 10/18/16 4:27		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6298020-15	Sample Name: PAC15 DF Sampled: 10/18/16 4:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6298020-16	Sample Name: PAC16 F Sampled: 10/18/16 4:30		Matrix: Water				
+Lead	1030	EPA 200.9	2.5	ppb	2.0	20 ppb	12/14/16 16:30
6298020-17	Sample Name: PAC17 F Sampled: 10/18/16 4:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6298020-18	Sample Name: PAC18 F Sampled: 10/18/16 4:32		Matrix: Water				
+Lead	1030	EPA 200.9	3.7	ppb	2.0	20 ppb	12/14/16 16:30
6298020-19	Sample Name: PAC19 F Sampled: 10/18/16 4:32		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6298020-20	Sample Name: PAC20 F Sampled: 10/18/16 4:34		Matrix: Water				
+Lead	1030	EPA 200.9	44.2	ppb	4.0	20 ppb	12/14/16 16:30 MCL



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/19/2016
Received: 10/20/2016
Sampled By: Troy Thompson
Work Order: 6298020

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Performing Arts Center

Lab Number


Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298020-21	Sample Name: PAC21 F Sampled: 10/18/16 4:34						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/16/16 16:39
6298020-22	Sample Name: PAC23 DF Sampled: 10/18/16 4:36						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/16/16 16:39
6298020-23	Sample Name: PAC24 DF Sampled: 10/18/16 4:36						Matrix: Water
+Lead	1030	EPA 200.9	8.8	ppb	2.0	20 ppb	12/16/16 16:39
6298020-24	Sample Name: PAC25 F Sampled: 10/18/16 4:37						Matrix: Water
+Lead	1030	EPA 200.9	6.1	ppb	2.0	20 ppb	12/16/16 16:39
6298020-25	Sample Name: PAC26 F Sampled: 10/18/16 4:37						Matrix: Water
+Lead	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	12/16/16 16:39
6298020-26	Sample Name: PAC27 F Sampled: 10/18/16 4:37						Matrix: Water
+Lead	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	12/16/16 16:39
6298020-27	Sample Name: PAC28 F Sampled: 10/18/16 4:38						Matrix: Water
+Lead	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	12/16/16 16:39
6298020-28	Sample Name: PAC29 F Sampled: 10/18/16 4:38						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/16/16 16:39

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit

MCL = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/19/2016
Received: 10/20/2016
Sampled By: Troy Thompson
Work Order: 6298020

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Performing Arts Center

Lab Number

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director