

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/21/2016
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298026

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: South High School (SHS)

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
6298026-01	Sample Name: SHS 81 F Sampled: 10/22/16 7:34							Matrix: Water
+Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	12/19/16 17:04	
6298026-02	Sample Name: SHS 83 DF Sampled: 10/22/16 7:35							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/19/16 17:04	
6298026-03	Sample Name: SHS 86 DF Sampled: 10/22/16 7:40							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/19/16 17:04	
6298026-04	Sample Name: SHS 87 Bradley Sampled: 10/22/16 7:45							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/19/16 17:04	
6298026-05	Sample Name: SHS 89 F Sampled: 10/22/16 7:47							Matrix: Water
+Lead	1030	EPA 200.9	4.6	ppb	2.0	20 ppb	12/19/16 17:04	
6298026-06	Sample Name: SHS 90 F Sampled: 10/22/16 7:48							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/19/16 17:04	
6298026-07	Sample Name: SHS 91 Ice Machine Sampled: 10/22/16 7:49							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/19/16 17:04	
6298026-08	Sample Name: SHS 92 Bradley Sampled: 10/22/16 0:00							Matrix: Water
+Lead	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	12/19/16 17:04	
6298026-09	Sample Name: SHS 93 DF Sampled: 10/22/16 7:53							Matrix: Water
+Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	12/19/16 17:04	
6298026-10	Sample Name: SHS94 F Sampled: 10/22/16 7:55							Matrix: Water
+Lead	1030	EPA 200.9	25.7	ppb	2.0	20 ppb	12/19/16 17:04 MCLE	



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/21/2016
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298026

**C
L
I
E
N
T** **David Douglas School District**
Attn: -
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: South High School (SHS)

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298026-11	Sample Name: SHS95 B Sampled: 10/22/16 8:05		Matrix: Water				
+Lead	1030	EPA 200.9	15.1	ppb	2.0	20 ppb	12/19/16 17:04
6298026-12	Sample Name: SHS96 F Sampled: 10/22/16 8:09		Matrix: Water				
+Lead	1030	EPA 200.9	5.7	ppb	2.0	20 ppb	12/19/16 17:04
6298026-13	Sample Name: SHS 97 Bradley Sampled: 10/22/16 8:10		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/19/16 17:04
6298026-15	Sample Name: SHS 99 B Sampled: 10/22/16 8:11		Matrix: Water				
+Lead	1030	EPA 200.9	47.7	ppb	4.0	20 ppb	12/19/16 17:04 MCLE
6298026-16	Sample Name: SHS 100 Bradley Sampled: 10/22/16 8:12		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/19/16 17:04
6298026-17	Sample Name: SHS 101 F Sampled: 10/22/16 8:15		Matrix: Water				
+Lead	1030	EPA 200.9	15.9	ppb	2.0	20 ppb	12/19/16 17:04
6298026-18	Sample Name: SHS 102 F Sampled: 10/22/16 8:16		Matrix: Water				
+Lead	1030	EPA 200.9	5.9	ppb	2.0	20 ppb	12/19/16 17:04
6298026-19	Sample Name: SHS103 F Sampled: 10/22/16 8:17		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/19/16 17:04
6298026-20	Sample Name: SHS 104 Ice Mach Sampled: 10/22/16 8:19		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/19/16 17:04
6298026-21	Sample Name: SHS 105 F Sampled: 10/22/16 8:22		Matrix: Water				
+Lead	1030	EPA 200.9	5.6	ppb	2.0	20 ppb	12/19/16 17:04



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/21/2016
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298026

C **David Douglas School District**
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: South High School (SHS)

Lab Number


Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298026-22	Sample Name: SHS 106 F Sampled: 10/22/16 8:23		Matrix: Water				
+Lead	1030	EPA 200.9	8.6	ppb	2.0	20 ppb	12/19/16 17:04
6298026-23	Sample Name: SHS 107 F Sampled: 10/22/16 8:25		Matrix: Water				
+Lead	1030	EPA 200.9	12.3	ppb	2.0	20 ppb	12/19/16 17:04
6298026-24	Sample Name: SHS 108 F Sampled: 10/22/16 8:25		Matrix: Water				
+Lead	1030	EPA 200.9	13.4	ppb	2.0	20 ppb	12/19/16 17:04
6298026-25	Sample Name: SHS 109 F Sampled: 10/22/16 8:30		Matrix: Water				
+Lead	1030	EPA 200.9	72.9	ppb	4.0	20 ppb	12/19/16 17:04 MCLE
6298026-26	Sample Name: SHS 110 Bradley Sampled: 10/22/16 8:35		Matrix: Water				
+Lead	1030	EPA 200.9	8.2	ppb	2.0	20 ppb	12/19/16 17:04
6298026-27	Sample Name: SHS 111 B Sampled: 10/22/16 8:35		Matrix: Water				
+Lead	1030	EPA 200.9	3.9	ppb	2.0	20 ppb	12/19/16 17:04
6298026-28	Sample Name: SHS 112 F Sampled: 10/22/16 8:35		Matrix: Water				
+Lead	1030	EPA 200.9	15.8	ppb	2.0	20 ppb	12/19/16 17:04
6298026-29	Sample Name: SHS 113 F Sampled: 10/22/16 8:35		Matrix: Water				
+Lead	1030	EPA 200.9	13.6	ppb	2.0	20 ppb	12/19/16 17:04
6298026-30	Sample Name: SHS 114 F Sampled: 10/22/16 6:48		Matrix: Water				
+Lead	1030	EPA 200.9	39.7	ppb	4.0	20 ppb	12/19/16 17:04 MCLE

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL

MRL = Minimum Reporting Limit

MCL = Maximum Contamination Limit



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/21/2016
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298026

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: South High School (SHS)

Lab Number

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director