



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/29/2016
Received: 11/18/2016
Sampled By: Troy Thompson
Work Order: 6323008

**C
L
I
E
N
T**
David Douglas School District
Attn: -
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: West Powell

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
6323008-01	Sample Name: WP 25F Retest Sampled: 11/16/16 6:15							Matrix: Water
+Lead	1030	EPA 200.9	10.5	ppb	2.0	20 ppb	11/28/16 16:11	
6323008-02	Sample Name: WP 42F Retest Sampled: 11/16/16 6:17							Matrix: Water
+Lead	1030	EPA 200.9	10.0	ppb	2.0	20 ppb	11/28/16 16:11	
6323008-03	Sample Name: WP 55F Retest Sampled: 11/16/16 6:19							Matrix: Water
+Lead	1030	EPA 200.9	30.8	ppb	2.0	20 ppb	11/28/16 16:11 MCLE	

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director