



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 09/19/2017
Received: 09/07/2017
Sampled By: Troy Thompson
Work Order: 7250010

C
L
I
E
N
T

David Douglas School District
Attn: Troy Thompson
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: Floyd Light

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7250010-01	Sample Name: FL 92DF retest		Matrix: Water				
	Sampled: 9/7/17 6:45						
+Lead	1030	EPA 200.9	21	ppb	2	20 ppb	09/15/17 15:23 MCLE
7250010-02	Sample Name: FL 93DF retest		Matrix: Water				
	Sampled: 9/7/17 6:46						
+Lead	1030	EPA 200.9	11	ppb	2	20 ppb	09/15/17 15:23

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director