



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 09/19/2017
Received: 09/07/2017
Sampled By: Troy Thompson
Work Order: 7250011

C
L
I
E
N
T

David Douglas School District
Attn: Troy Thompson
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: South High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7250011-01	Sample Name: SHS 6F Sampled: 8/31/17 6:40		Matrix: Water				
+Lead	1030	EPA 200.9	3	ppb	2	20 ppb	09/15/17 15:23
7250011-02	Sample Name: SHS 33F Sampled: 8/31/17 6:45		Matrix: Water				
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	09/15/17 15:23
7250011-03	Sample Name: SHS 46F Sampled: 8/31/17 6:53		Matrix: Water				
+Lead	1030	EPA 200.9	4	ppb	2	20 ppb	09/15/17 15:23
7250011-04	Sample Name: SHS 77F Sampled: 8/31/17 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	09/15/17 15:23

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director