

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 01/13/2017
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298030

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Alice Ott

Lab Number

| Lab Number | Code | Method | Result | Units | MRL | EPA MCL* | Analysis Date/ Time |
|-------------------|--------------------------------------------------------------|-----------|----------------------|-------|-----|----------|----------------------------|
| 6298030-01 | Sample Name: AO01 F Sampled: 10/21/16 4:00 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |
| 6298030-02 | Sample Name: AO02 F Sampled: 10/21/16 4:00 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |
| 6298030-03 | Sample Name: AO03 SP Sampled: 10/21/16 4:01 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 23.9 | ppb | 2.0 | 20 ppb | 12/16/16 16:39 MCLE |
| 6298030-04 | Sample Name: AO04 F Sampled: 10/21/16 4:01 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 5.7 | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |
| 6298030-05 | Sample Name: AO05 SP Sampled: 10/21/16 4:03 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 4.8 | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |
| 6298030-06 | Sample Name: AO06 F Sampled: 10/21/16 4:03 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 4.7 | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |
| 6298030-07 | Sample Name: AO07 SK Sampled: 10/21/16 4:05 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |
| 6298030-08 | Sample Name: AO08 DF Sampled: 10/21/16 4:06 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |
| 6298030-09 | Sample Name: AO09 F Sampled: 10/21/16 4:06 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |
| 6298030-10 | Sample Name: AO10 F Sampled: 10/21/16 4:07 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 2.4 | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 01/13/2017
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298030


C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Alice Ott

Lab Number

| | Code | Method | Result | Units | MRL | EPA MCL* | Analysis Date/ Time |
|-------------------|--------------------------------------------------------------|-----------|----------------------|-------|-----|----------|---------------------|
| 6298030-11 | Sample Name: AO11 F Sampled: 10/21/16 4:08 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 2.8 | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |
| 6298030-12 | Sample Name: AO13 DF Sampled: 10/21/16 4:08 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |
| 6298030-13 | Sample Name: AO14 DF Sampled: 10/21/16 4:09 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |
| 6298030-14 | Sample Name: AO15 F Sampled: 10/21/16 4:09 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 6.7 | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |
| 6298030-15 | Sample Name: AO16 F Sampled: 10/21/16 4:11 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 3.6 | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |
| 6298030-16 | Sample Name: AO17 DF Sampled: 10/21/16 4:13 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |
| 6298030-17 | Sample Name: AO18 F Sampled: 10/21/16 4:13 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |
| 6298030-18 | Sample Name: AO19 F Sampled: 10/21/16 4:14 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 2.5 | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |
| 6298030-19 | Sample Name: AO20 DF Sampled: 10/21/16 4:16 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |
| 6298030-20 | Sample Name: AO21 F Sampled: 10/21/16 4:18 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 6.4 | ppb | 2.0 | 20 ppb | 12/16/16 16:39 |



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/13/2017
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298030


C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Alice Ott

Lab Number

| Lab Number | Code | Method | Result | Units | MRL | EPA MCL* | Analysis Date/ Time |
|-------------------|-------------------------------------------------------------|-----------|----------------------|-------|-----|----------|---------------------|
| 6298030-21 | Sample Name: AO22 F Sampled: 10/21/16 4:18 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 16.9 | ppb | 2.0 | 20 ppb | 12/19/16 17:04 |
| 6298030-22 | Sample Name: AO23 F Sampled: 10/21/16 4:21 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 8.7 | ppb | 2.0 | 20 ppb | 12/19/16 17:04 |
| 6298030-23 | Sample Name: AO24 F Sampled: 10/21/16 4:21 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 8.7 | ppb | 2.0 | 20 ppb | 12/19/16 17:04 |
| 6298030-24 | Sample Name: AO25 F Sampled: 10/21/16 4:21 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 8.5 | ppb | 2.0 | 20 ppb | 12/19/16 17:04 |
| 6298030-25 | Sample Name: AO26 F Sampled: 10/21/16 4:22 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 4.5 | ppb | 2.0 | 20 ppb | 12/19/16 17:04 |
| 6298030-26 | Sample Name: AO27 F Sampled: 10/21/16 4:23 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 6.3 | ppb | 2.0 | 20 ppb | 12/19/16 17:04 |
| 6298030-27 | Sample Name: AO28 F Sampled: 10/21/16 4:25 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 4.5 | ppb | 2.0 | 20 ppb | 12/19/16 17:04 |
| 6298030-28 | Sample Name: AO29 F Sampled: 10/21/16 4:25 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 6.8 | ppb | 2.0 | 20 ppb | 12/19/16 17:04 |
| 6298030-29 | Sample Name: AO30 F Sampled: 10/21/16 4:25 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 7.9 | ppb | 2.0 | 20 ppb | 12/19/16 17:04 |
| 6298030-30 | Sample Name: AO31 F Sampled: 10/21/16 4:27 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 4.1 | ppb | 2.0 | 20 ppb | 12/19/16 17:04 |



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/13/2017
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298030


C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Alice Ott

Lab Number

| | Code | Method | Result | Units | MRL | EPA MCL* | Analysis Date/ Time | |
|-------------------|-------------------------------------------------------------|-----------|--------|-------|-----|----------|---------------------|----------------------|
| 6298030-31 | Sample Name: AO32 F Sampled: 10/21/16 4:27 | | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | 5.2 | ppb | 2.0 | 20 ppb | 12/19/16 17:04 | |
| 6298030-32 | Sample Name: AO33 F Sampled: 10/21/16 4:29 | | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | 10.5 | ppb | 2.0 | 20 ppb | 12/19/16 17:04 | |
| 6298030-33 | Sample Name: AO34 F Sampled: 10/21/16 4:29 | | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | 9.1 | ppb | 2.0 | 20 ppb | 12/19/16 17:04 | |
| 6298030-34 | Sample Name: AO35 F Sampled: 10/21/16 4:31 | | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | 8.0 | ppb | 2.0 | 20 ppb | 12/19/16 17:04 | |
| 6298030-35 | Sample Name: AO36 F Sampled: 10/21/16 4:31 | | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | 10.5 | ppb | 2.0 | 20 ppb | 12/19/16 17:04 | |
| 6298030-36 | Sample Name: AO37 F Sampled: 10/21/16 4:31 | | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | 7.7 | ppb | 2.0 | 20 ppb | 01/10/17 16:19 | |
| 6298030-37 | Sample Name: AO38 F Sampled: 10/21/16 4:32 | | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | 8.0 | ppb | 2.0 | 20 ppb | 01/10/17 16:19 | |
| 6298030-38 | Sample Name: AO39 F Sampled: 10/21/16 4:32 | | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | 7.1 | ppb | 2.0 | 20 ppb | 01/10/17 16:19 | |
| 6298030-39 | Sample Name: AO40 F Sampled: 10/21/16 4:32 | | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | 7.3 | ppb | 2.0 | 20 ppb | 01/10/17 16:19 | |
| 6298030-40 | Sample Name: AO41 F Sampled: 10/21/16 4:34 | | | | | | | Matrix: Water |
| +Lead | 1030 | EPA 200.9 | 4.2 | ppb | 2.0 | 20 ppb | 01/10/17 16:19 | |



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 01/13/2017
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298030

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Alice Ott

Lab Number


| Lab Number | Code | Method | Result | Units | MRL | EPA MCL* | Analysis Date/ Time |
|-------------------|-------------------------------------------------------------|-----------|----------------------|-------|-----|----------|---------------------|
| 6298030-41 | Sample Name: AO42 F Sampled: 10/21/16 4:35 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 8.1 | ppb | 2.0 | 20 ppb | 01/10/17 16:19 |
| 6298030-42 | Sample Name: AO43 F Sampled: 10/21/16 4:35 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 10.7 | ppb | 2.0 | 20 ppb | 01/10/17 16:19 |
| 6298030-43 | Sample Name: AO44 F Sampled: 10/21/16 4:35 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 7.3 | ppb | 2.0 | 20 ppb | 01/10/17 16:19 |
| 6298030-44 | Sample Name: AO45 F Sampled: 10/21/16 4:36 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2.0 | 20 ppb | 01/10/17 16:19 |
| 6298030-45 | Sample Name: AO46 F Sampled: 10/21/16 4:36 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | ND | ppb | 2.0 | 20 ppb | 01/10/17 16:19 |
| 6298030-46 | Sample Name: AO47 F Sampled: 10/21/16 4:36 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 4.7 | ppb | 2.0 | 20 ppb | 01/10/17 16:19 |
| 6298030-47 | Sample Name: AO48 F Sampled: 10/21/16 4:36 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 2.1 | ppb | 2.0 | 20 ppb | 01/10/17 16:19 |
| 6298030-48 | Sample Name: AO49 F Sampled: 10/21/16 4:37 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 3.5 | ppb | 2.0 | 20 ppb | 01/10/17 16:19 |
| 6298030-49 | Sample Name: AO50 F Sampled: 10/21/16 4:38 | | Matrix: Water | | | | |
| +Lead | 1030 | EPA 200.9 | 3.9 | ppb | 2.0 | 20 ppb | 01/10/17 16:19 |

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL

MRL = Minimum Reporting Limit

MCL = Maximum Contamination Limit



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/13/2017

Received: 10/24/2016

Sampled By: Troy Thompson

Work Order: 6298030

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:

Project # : N/A

Sample Type :

Sampling Location: Alice Ott

Lab Number

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.