

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/17/2017
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298031


C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N
T Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: Alice Ott

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298031-01	Sample Name: AO51 F Sampled: 10/21/16 4:40		Matrix: Water				
+Lead	1030	EPA 200.9	4.0	ppb	2.0	20 ppb	01/10/17 16:19
6298031-02	Sample Name: AO52 F Sampled: 10/21/16 4:40		Matrix: Water				
+Lead	1030	EPA 200.9	5.2	ppb	2.0	20 ppb	01/10/17 16:19
6298031-03	Sample Name: AO53 F Sampled: 10/21/16 4:41		Matrix: Water				
+Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	01/10/17 16:19
6298031-04	Sample Name: AO54 F Sampled: 10/21/16 4:42		Matrix: Water				
+Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	01/10/17 16:19
6298031-05	Sample Name: AO55 DF Sampled: 10/21/16 4:42		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/10/17 16:19
6298031-06	Sample Name: AO56 B Sampled: 10/21/16 4:43		Matrix: Water				
+Lead	1030	EPA 200.9	6.9	ppb	2.0	20 ppb	01/10/17 16:19
6298031-07	Sample Name: AO57 B Sampled: 10/21/16 4:44		Matrix: Water				
+Lead	1030	EPA 200.9	4.2	ppb	2.0	20 ppb	01/10/17 16:19
6298031-08	Sample Name: AO58 Bradley Sampled: 10/21/16 4:47		Matrix: Water				
+Lead	1030	EPA 200.9	8.7	ppb	2.0	20 ppb	01/10/17 16:19
6298031-09	Sample Name: AO59 Bradley Sampled: 10/21/16 4:51		Matrix: Water				
+Lead	1030	EPA 200.9	3.8	ppb	2.0	20 ppb	01/10/17 16:19
6298031-10	Sample Name: AO60 F Sampled: 10/21/16 4:51		Matrix: Water				
+Lead	1030	EPA 200.9	5.3	ppb	2.0	20 ppb	01/10/17 16:19



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 01/17/2017
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298031

C
L
I
E
N
T

David Douglas School District

Attn: -
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900


Project:

Project # : N/A
Sample Type :

Sampling Location: Alice Ott

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298031-11	Sample Name: AO61 F Sampled: 10/21/16 4:52		Matrix: Water				
+Lead	1030	EPA 200.9	67.3	ppb	4.0	20 ppb	01/10/17 16:19 MCLE
6298031-12	Sample Name: AO62 B Sampled: 10/21/16 4:52		Matrix: Water				
+Lead	1030	EPA 200.9	54.7	ppb	4.0	20 ppb	01/10/17 16:19 MCLE
6298031-13	Sample Name: AO63 Bradley Sampled: 10/21/16 4:53		Matrix: Water				
+Lead	1030	EPA 200.9	6.9	ppb	2.0	20 ppb	01/10/17 16:19
6298031-14	Sample Name: AO64 B Sampled: 10/21/16 4:54		Matrix: Water				
+Lead	1030	EPA 200.9	7.3	ppb	2.0	20 ppb	01/10/17 16:19
6298031-15	Sample Name: AO65 B Sampled: 10/21/16 4:54		Matrix: Water				
+Lead	1030	EPA 200.9	5.7	ppb	2.0	20 ppb	01/10/17 16:19
6298031-16	Sample Name: AO66 Bradley Sampled: 10/21/16 4:55		Matrix: Water				
+Lead	1030	EPA 200.9	7.0	ppb	2.0	20 ppb	01/10/17 16:19
6298031-17	Sample Name: AO67 F Sampled: 10/21/16 4:55		Matrix: Water				
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	01/10/17 16:19
6298031-18	Sample Name: AO68 F Sampled: 10/21/16 4:56		Matrix: Water				
+Lead	1030	EPA 200.9	29.5	ppb	2.0	20 ppb	01/10/17 16:19 MCLE
6298031-19	Sample Name: AO69 F Sampled: 10/21/16 4:56		Matrix: Water				
+Lead	1030	EPA 200.9	13.2	ppb	2.0	20 ppb	01/10/17 16:19
6298031-20	Sample Name: AO70 F Sampled: 10/21/16 4:57		Matrix: Water				
+Lead	1030	EPA 200.9	8.0	ppb	2.0	20 ppb	01/10/17 16:19



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/17/2017
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298031


C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Alice Ott

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298031-21	Sample Name: AO71 F Sampled: 10/21/16 4:58		Matrix: Water				
+Lead	1030	EPA 200.9	6.1	ppb	2.0	20 ppb	01/10/17 16:19
6298031-22	Sample Name: AO72 F Sampled: 10/21/16 4:58		Matrix: Water				
+Lead	1030	EPA 200.9	5.7	ppb	2.0	20 ppb	01/10/17 16:19
6298031-23	Sample Name: AO73 F Sampled: 10/21/16 4:58		Matrix: Water				
+Lead	1030	EPA 200.9	28.6	ppb	2.0	20 ppb	01/10/17 16:19 MCLE
6298031-24	Sample Name: AO74 B Sampled: 10/21/16 4:58		Matrix: Water				
+Lead	1030	EPA 200.9	7.2	ppb	2.0	20 ppb	01/10/17 16:19
6298031-25	Sample Name: AO75 F Sampled: 10/21/16 4:59		Matrix: Water				
+Lead	1030	EPA 200.9	9.2	ppb	2.0	20 ppb	01/10/17 16:19
6298031-26	Sample Name: AO76 F Sampled: 10/21/16 4:59		Matrix: Water				
+Lead	1030	EPA 200.9	57.1	ppb	4.0	20 ppb	01/10/17 16:19 MCLE
6298031-27	Sample Name: AO77 F Sampled: 10/21/16 4:59		Matrix: Water				
+Lead	1030	EPA 200.9	26.0	ppb	2.0	20 ppb	01/10/17 16:19 MCLE
6298031-28	Sample Name: AO78 F Sampled: 10/21/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	12.2	ppb	2.0	20 ppb	01/10/17 16:19
6298031-29	Sample Name: AO79 F Sampled: 10/21/16 5:02		Matrix: Water				
+Lead	1030	EPA 200.9	30.4	ppb	2.0	20 ppb	01/10/17 16:19 MCLE
6298031-30	Sample Name: AO80 F Sampled: 10/21/16 5:04		Matrix: Water				
+Lead	1030	EPA 200.9	4.0	ppb	2.0	20 ppb	01/10/17 16:19



13035 SW Pacific Hwy
 Tigard, OR 97223
 Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
 Laboratory
 Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/17/2017
 Received: 10/24/2016
 Sampled By: Troy Thompson
 Work Order: 6298031

**C
 L
 I
 E
 N
 T**


David Douglas School District
 Attn: -
 11300 NE Halsey St
 Portland OR, 97220
 Phone: (503) 252-2900

Project:
 Project # : N/A
 Sample Type :

Sampling Location: Alice Ott

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298031-31	Sample Name: AO81 F Sampled: 10/21/16 5:07		Matrix: Water				
+Lead	1030	EPA 200.9	49.5	ppb	4.0	20 ppb	01/10/17 16:19 MCLE
6298031-32	Sample Name: AO82 F Sampled: 10/21/16 5:08		Matrix: Water				
+Lead	1030	EPA 200.9	6.7	ppb	2.0	20 ppb	01/10/17 16:19
6298031-33	Sample Name: AO83 F Sampled: 10/21/16 5:09		Matrix: Water				
+Lead	1030	EPA 200.9	2.8	ppb	2.0	20 ppb	01/10/17 16:19
6298031-34	Sample Name: AO84 Bradley Sampled: 10/21/16 5:09		Matrix: Water				
+Lead	1030	EPA 200.9	4.0	ppb	2.0	20 ppb	01/10/17 16:19
6298031-35	Sample Name: AO85 F Sampled: 10/21/16 5:09		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/10/17 16:19
6298031-36	Sample Name: AO86 Bradley Sampled: 10/21/16 5:09		Matrix: Water				
+Lead	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	01/16/17 16:52
6298031-37	Sample Name: AO87 Bradley Sampled: 10/21/16 5:10		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/16/17 16:52
6298031-38	Sample Name: AO88 F Sampled: 10/21/16 5:11		Matrix: Water				
+Lead	1030	EPA 200.9	4.6	ppb	2.0	20 ppb	01/16/17 16:52
6298031-39	Sample Name: AO89 DF Sampled: 10/21/16 5:11		Matrix: Water				
+Lead	1030	EPA 200.9	5.1	ppb	2.0	20 ppb	01/16/17 16:52
6298031-40	Sample Name: AO90 F Sampled: 10/21/16 5:11		Matrix: Water				
+Lead	1030	EPA 200.9	6.4	ppb	2.0	20 ppb	01/16/17 16:52



13035 SW Pacific Hwy
 Tigard, OR 97223
 Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
 Laboratory
 Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/17/2017
 Received: 10/24/2016
 Sampled By: Troy Thompson
 Work Order: 6298031


C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
 Project # : N/A
 Sample Type :

Sampling Location: Alice Ott

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298031-41	Sample Name: AO91 F Sampled: 10/21/16 5:11		Matrix: Water				
+Lead	1030	EPA 200.9	8.5	ppb	2.0	20 ppb	01/16/17 16:52
6298031-42	Sample Name: AO92 F Sampled: 10/21/16 5:11		Matrix: Water				
+Lead	1030	EPA 200.9	3.7	ppb	2.0	20 ppb	01/16/17 16:52
6298031-43	Sample Name: AO93 F Sampled: 10/21/16 5:11		Matrix: Water				
+Lead	1030	EPA 200.9	4.7	ppb	2.0	20 ppb	01/16/17 16:52
6298031-44	Sample Name: AO94 F Sampled: 10/21/16 5:13		Matrix: Water				
+Lead	1030	EPA 200.9	16.4	ppb	2.0	20 ppb	01/16/17 16:52
6298031-45	Sample Name: AO95 F Sampled: 10/21/16 5:14		Matrix: Water				
+Lead	1030	EPA 200.9	19.9	ppb	2.0	20 ppb	01/16/17 16:52
6298031-46	Sample Name: AO96 F Sampled: 10/21/16 5:14		Matrix: Water				
+Lead	1030	EPA 200.9	19.3	ppb	2.0	20 ppb	01/16/17 16:52
6298031-47	Sample Name: AO97 F Sampled: 10/21/16 5:15		Matrix: Water				
+Lead	1030	EPA 200.9	6.5	ppb	2.0	20 ppb	01/16/17 16:52
6298031-48	Sample Name: AO98 SP Sampled: 10/21/16 5:18		Matrix: Water				
+Lead	1030	EPA 200.9	35.9	ppb	2.0	20 ppb	01/10/17 16:19 MCLE
6298031-49	Sample Name: AO99 F Sampled: 10/21/16 5:18		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/16/17 16:52
6298031-50	Sample Name: AO100 B Sampled: 10/21/16 5:20		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/16/17 16:52



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/17/2017
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298031

C
L
I
E
N
T

David Douglas School District

Attn: -
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:

Project # : N/A
Sample Type :

Sampling Location: Alice Ott

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298031-51	Sample Name: AO101 B						Matrix: Water
	Sampled: 10/21/16 5:21						
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/16/17 16:52

MCL This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director