

**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 01/23/2017  
Received: 11/18/2016  
Sampled By: Troy Thompson  
Work Order: 6323011


**C  
L  
I  
E  
N  
T**  
**David Douglas School District**  
Attn: -  
11300 NE Halsey St  
Portland OR, 97220  
Phone: (503) 252-2900

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: District Office

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
<b>6323011-01</b>	<b>Sample Name: DO 1 F</b>							<b>Matrix: Water</b>
	<b>Sampled: 11/18/16 5:37</b>							
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36	
<b>6323011-02</b>	<b>Sample Name: DO 2 F</b>							<b>Matrix: Water</b>
	<b>Sampled: 11/18/16 5:38</b>							
+Lead	1030	EPA 200.9	2.2	ppb	2.0	20 ppb	01/20/17 16:36	
<b>6323011-03</b>	<b>Sample Name: DO 3 F</b>							<b>Matrix: Water</b>
	<b>Sampled: 11/18/16 5:37</b>							
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36	
<b>6323011-04</b>	<b>Sample Name: DO 4 F</b>							<b>Matrix: Water</b>
	<b>Sampled: 11/18/16 5:36</b>							
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36	
<b>6323011-05</b>	<b>Sample Name: DO 5 F</b>							<b>Matrix: Water</b>
	<b>Sampled: 11/18/16 5:36</b>							
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36	
<b>6323011-06</b>	<b>Sample Name: DO 6 F</b>							<b>Matrix: Water</b>
	<b>Sampled: 11/18/16 5:40</b>							
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36	
<b>6323011-07</b>	<b>Sample Name: DO 7 F</b>							<b>Matrix: Water</b>
	<b>Sampled: 11/18/16 5:40</b>							
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36	
<b>6323011-08</b>	<b>Sample Name: DO 8 F</b>							<b>Matrix: Water</b>
	<b>Sampled: 11/18/16 5:41</b>							
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36	
<b>6323011-09</b>	<b>Sample Name: DO 9 F</b>							<b>Matrix: Water</b>
	<b>Sampled: 11/18/16 5:41</b>							
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36	
<b>6323011-10</b>	<b>Sample Name: DO 10 DF</b>							<b>Matrix: Water</b>
	<b>Sampled: 11/18/16 5:42</b>							
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36	



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 01/23/2017  
Received: 11/18/2016  
Sampled By: Troy Thompson  
Work Order: 6323011

**C  
L  
I  
E  
N  
T**  
**David Douglas School District**  
Attn: -  
11300 NE Halsey St  
Portland OR, 97220  
Phone: (503) 252-2900

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: District Office

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
<b>6323011-11</b>	<b>Sample Name:</b> DO 11 F <b>Sampled:</b> 11/18/16 5:43							<b>Matrix:</b> Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36	
<b>6323011-12</b>	<b>Sample Name:</b> DO 12 F <b>Sampled:</b> 11/18/16 5:43							<b>Matrix:</b> Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36	
<b>6323011-13</b>	<b>Sample Name:</b> DO 13 F <b>Sampled:</b> 11/18/16 5:44							<b>Matrix:</b> Water
+Lead	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	01/20/17 16:36	

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: Carrie Seidel for AGG  
Adriana Gonzalez-Gray  
Laboratory Director