



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 07/27/2017
Received: 07/19/2017
Sampled By:
Work Order: 7200003

C David Douglas School District
L Attn: Troy Thompson
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location:

Lab Number

Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7200003-01		Sample Name: FL 83DF Sampled: 7/18/17 6:25				Matrix: Water
+Lead	1030 EPA 200.9	23	ppb	2	20 ppb	07/26/17 15:17 MCLE
7200003-02		Sample Name: FL 92DF Sampled: 7/18/17 6:22				Matrix: Water
+Lead	1030 EPA 200.9	19	ppb	2	20 ppb	07/26/17 15:17
7200003-03		Sample Name: FL 93DF Sampled: 7/18/17 6:22				Matrix: Water
+Lead	1030 EPA 200.9	8	ppb	2	20 ppb	07/26/17 15:17

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:

Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.