



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 05/11/2017  
Received: 04/27/2017  
Sampled By: Troy Thompson  
Work Order: 7117003

C  
L  
I  
E  
N  
T

**David Douglas School District**

Attn: Troy Thompson  
11300 NE Halsey St  
Portland OR, 97220  
Phone: (503) 252-2900

**Project:**

Project # : N/A  
Sample Type :

Sampling Location: Floyd Light Middle School


**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>7117003-01</b>	<b>Sample Name:</b> FL 6 SP (now a faucet) <b>Sampled:</b> 4/27/17 6:09		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	05/10/17 16:53
<b>7117003-02</b>	<b>Sample Name:</b> FL 32F <b>Sampled:</b> 4/27/17 6:20		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	05/10/17 16:53
<b>7117003-03</b>	<b>Sample Name:</b> FL 50F <b>Sampled:</b> 4/27/17 6:18		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	05/10/17 16:53
<b>7117003-04</b>	<b>Sample Name:</b> FL 77F <b>Sampled:</b> 4/27/17 6:17		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	05/10/17 16:53
<b>7117003-05</b>	<b>Sample Name:</b> FL 78F <b>Sampled:</b> 4/27/17 6:18		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	4.1	ppb	2.0	20 ppb	05/10/17 16:53
<b>7117003-06</b>	<b>Sample Name:</b> FL 88F <b>Sampled:</b> 4/27/17 6:11		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	7.0	ppb	2.0	20 ppb	05/10/17 16:53
<b>7117003-07</b>	<b>Sample Name:</b> FL 90F <b>Sampled:</b> 4/27/17 6:13		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	2.8	ppb	2.0	20 ppb	05/10/17 16:53

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director