



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/22/2016
Received: 11/18/2016
Sampled By: Troy Thompson
Work Order: 6323007

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Fir Ridge

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6323007-01	Sample Name: FR 9 SK retest		Matrix: Water				
	Sampled: 11/16/16 6:05						
+Lead	1030	EPA 200.9	59.8	ppb	4.0	20 ppb	11/21/16 17:09 MCLE
6323007-02	Sample Name: FR 9 SK 2nd draw		Matrix: Water				
	Sampled: 11/16/16 6:06						
+Lead	1030	EPA 200.9	1020	ppb	100	20 ppb	11/21/16 17:09 MCLE

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director