

**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 03/03/2017

Received: 02/24/2017

Sampled By: Troy Thompson

Work Order: 7055006

**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**

Project # : N/A

Sample Type :

Sampling Location: Fir Ridge

Sample Matrix: Water

## Lab Number


Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>7055006-01</b>	<b>Sample Name:</b> FR 9 SK 3rd test		<b>Matrix:</b> Water				
	<b>Sampled:</b> 2/24/17 6:30						
+Lead	1030	EPA 200.9	<b>101</b>	ppb	8.0	20 ppb	03/01/17 14:04 <b>MCLE</b>

**MCLE** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director