


**DAVID DOUGLAS SCHOOL DISTRICT
LEAD TESTING RESULTS BY SCHOOL**

6/6/2016 3:59 PM

Classroom/Location	Analysis Report Date	Work Order #	1st Draw	1 Min Draw	Action Taken
			Test #1 mg/L	Test #2 mg/L	
FIR RIDGE SCHOOL					
Commons 1	10/28/2013	3297016	nd	nd	none
Commons 2	10/28/2013	3297016	nd	nd	none
Gym 1	10/28/2013	3297016	nd	nd	none
Gym 2	10/28/2013	3297016	nd	nd	none
Kitchen 1	10/28/2013	3297016	0.0040	nd	none
Kitchen 2	10/28/2013	3297016	0.0060	nd	none



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 10/28/2013
Received: 10/24/2013
Sampled By: Faye Bayer
Work Order: 3297016

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project # : N/A
PWSID # : -
PO # : 140989


Sampling Location: Fir Ridge Campus
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/18/13 6:02		Sample Composition:				
3297016-01	FRCOMMON1A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	10/25/13 16:07

Lab Number	Sample Name	Sampled: 10/18/13 6:04		Sample Composition:				
3297016-02	FRCOMMON1B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	10/25/13 16:07

Lab Number	Sample Name	Sampled: 10/18/13 5:53		Sample Composition:				
3297016-03	FRCOMMON2A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	10/25/13 16:07

Lab Number	Sample Name	Sampled: 10/18/13 5:54		Sample Composition:				
3297016-04	FRCOMMON2B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	10/25/13 16:07



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 10/28/2013
Received: 10/24/2013
Sampled By: Faye Bayer
Work Order: 3297016

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project # : N/A
PWSID # : -
PO # : 140989


Sampling Location: Fir Ridge Campus
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/18/13 6:11		Sample Composition:				
3297016-05	FRGYM1A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<i>†Lead</i>	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	10/25/13 16:07

Lab Number	Sample Name	Sampled: 10/18/13 6:13		Sample Composition:				
3297016-06	FRGYM1B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<i>†Lead</i>	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	10/25/13 16:07

Lab Number	Sample Name	Sampled: 10/18/13 6:15		Sample Composition:				
3297016-07	FRGYM2A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<i>†Lead</i>	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	10/25/13 16:07

Lab Number	Sample Name	Sampled: 10/18/13 6:16		Sample Composition:				
3297016-08	FRGYM2B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<i>†Lead</i>	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	10/25/13 16:07



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 10/28/2013
Received: 10/24/2013
Sampled By: Faye Bayer
Work Order: 3297016

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project # : N/A
PWSID # : -
PO # : 140989


Sampling Location: Fir Ridge Campus
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/18/13 5:38		Sample Composition:				
3297016-09	FRKITCHEN1A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.004	0.002	0.015	-	10/25/13 16:07

Lab Number	Sample Name	Sampled: 10/18/13 5:40		Sample Composition:				
3297016-10	FRKITCHEN1B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	10/25/13 16:07

Lab Number	Sample Name	Sampled: 10/18/13 5:44		Sample Composition:				
3297016-11	FRKITCHEN2A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.006	0.002	0.015	-	10/25/13 16:07

Lab Number	Sample Name	Sampled: 10/18/13 5:46		Sample Composition:				
3297016-12	FRKITCHEN2B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	10/25/13 16:07



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 10/28/2013

Received: 10/24/2013

Sampled By: Faye Bayer


Work Order: 3297016

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project # : N/A
PWSID # : -
PO # : 140989

Sampling Location: Fir Ridge Campus
Sample Matrix: Drinking Water

ND = None detected **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
†All procedures for this analysis conform to NELAC standards.

Approved by: 
Scott Dickman
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.