



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 09/11/2017
Received: 09/07/2017
Sampled By: Troy Thompson
Work Order: 7250009

C **David Douglas School District**
L Attn: Troy Thompson
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Gilbert Heights
Sample Matrix: Water

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7250009-01	Sample Name: GH 52DF		Matrix: Water				
	Sampled: 9/7/17 6:23						
+Lead	1030	EPA 200.9	4	ppb	2	20 ppb	09/08/17 14:31

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____


 Adriana Gonzalez-Gray
 Laboratory Director

