

**DAVID DOUGLAS SCHOOL DISTRICT
LEAD TESTING RESULTS BY SCHOOL**

6/6/2016 3:59 PM

Classroom/Location	Analysis Report Date	Work Order #	1st Draw	1 Min Draw	Action Taken
			Test #1 mg/L	Test #2 mg/L	
GILBERT HEIGHTS ELEMENTARY SCHOOL					
1	11/12/2013	3304011	0.0030	ND	none
2	11/12/2013	3304011	ND	ND	none
3	11/12/2013	3304011	0.0040	nd	none
4	11/12/2013	3304011	nd	nd	none
5	11/12/2013	3304011	nd	nd	none
6	11/12/2013	3304011	0.0080	0.0020	none
7	11/12/2013	3304011	0.0030	nd	none
8	11/12/2013	3304011	nd	nd	none
9	11/12/2013	3304011	0.0100	nd	none
11	11/12/2013	3304011	0.0040	nd	none
12	11/12/2013	3304011	0.0090	nd	none
13	11/12/2013	3304011	0.0040	0.0030	none
14	11/12/2013	3304011	0.0040	nd	none
15	11/12/2013	3304011	0.0080	nd	none
16	11/12/2013	3304011	0.0060	0.0030	none
17	11/12/2013	3304011	0.0080	nd	none
18	11/12/2013	3304011	0.0030	nd	none
19	11/12/2013	3304011	0.0040	nd	none
20	11/12/2013	3304011	0.0280	nd	Turned off/disabled
21	11/12/2013	3304011	0.0020	0.0030	none
22	11/12/2013	3304011	nd	nd	none
23	11/12/2013	3304011	nd	nd	none
Hall 33	11/12/2013	3304011	nd	nd	none
31	11/12/2013	3304011	nd	nd	none
32	11/12/2013	3304011	nd	nd	none
33	11/12/2013	3304011	nd	nd	none
34	11/12/2013	3304011	nd	nd	none
Office	11/12/2013	3304011	0.0090	0.0090	none
Hall 1	11/12/2013	3304011	0.0170	nd	Turned off/disabled
Hall 11	11/12/2013	3304011	nd	nd	none
Hall 32	11/12/2013	3304011	nd	nd	none
Gym 1	11/12/2013	3304011	nd	nd	none
Gym 2	11/12/2013	3304011	nd	nd	none
Cafeteria	11/12/2013	3304011	0.0030	nd	none
Kitchen 1A	11/12/2013	3304011	0.0070	nd	none
Kitchen 2A	11/12/2013	3304011	0.0020	nd	none
Retesting affected rooms:					
20	4/2/2014	4086013	0.0280	0.0190	Remain turned off
CL (room 20)	3/11/2016	5065004	0.1050	0.0030	Remain turned off
20	5/12/2016	6120002	0.0950	0.0030	Remain turned off
1	5/12/2016	6120002	0.0030	nd	Duplicate test
Hall 1	5/12/2016	6120002	0.0230	0.0020	Remain turned off

ND - NONE DETECTED

ITEMS IN RED ARE OVER THE 20 PPB EPA RECOMMENDATION FOR REPLACEMENT



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project # : N/A
PWSID # : -
PO # : 140989


Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/25/13 7:14		Sample Composition:				
3304011-01	GH1A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 7:16		Sample Composition:				
3304011-02	GH1B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 7:19		Sample Composition:				
3304011-03	GH2A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 7:21		Sample Composition:				
3304011-04	GH2B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 839-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011

**C
L
I
E
N
T**
David Douglas School District
Attn: David Callaway
2900 SE 122nd
Portland OR, 97236
Phone: (503) 252-2900

Project: -
Project #: N/A
PWSID #: -
PO #: 140989

Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/25/13 7:24		Sample Composition:				
3304011-05	GH3A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.004	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 7:26		Sample Composition:				
3304011-06	GH3B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 7:29		Sample Composition:				
3304011-07	GH4A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 7:31		Sample Composition:				
3304011-08	GH4B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project #: N/A
PWSID #: -
PO #: 140989

Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/25/13 7:33		Sample Composition:				
3304011-09	GH5A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 7:35		Sample Composition:				
3304011-10	GH5B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 7:38		Sample Composition:				
3304011-11	GH6A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.008	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 7:40		Sample Composition:				
3304011-12	GH6B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.002	0.002	0.015	-	11/08/13 15:57



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project #: N/A
PWSID #: -
PO #: 140989


Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/25/13 7:42		Sample Composition:				
3304011-13	GH7A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 7:44		Sample Composition:				
3304011-14	GH7B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 7:45		Sample Composition:				
3304011-15	GH8A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 7:46		Sample Composition:				
3304011-16	GH8B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 839-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project #: N/A
PWSID #: -
PO #: 140989

Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/25/13 7:48		Sample Composition:				
3304011-17	GH9A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.010	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 7:50		Sample Composition:				
3304011-18	GH9B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 7:52		Sample Composition:				
3304011-19	GH11A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.004	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 7:54		Sample Composition:				
3304011-20	GH11B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 839-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011

C David Douglas School District
L Altn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project #: N/A
PWSID #: -
PO #: 140989


Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/25/13 8:01		Sample Composition:					
3304011-21	GH12A								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
[†] Lead	1030	EPA 200.9	mg/L	0.009	0.002	0.015	-	11/08/13 15:57	

Lab Number	Sample Name	Sampled: 10/25/13 8:03		Sample Composition:					
3304011-22	GH12B								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57	

Lab Number	Sample Name	Sampled: 10/29/13 5:48		Sample Composition:					
3304011-23	GH13A								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
[†] Lead	1030	EPA 200.9	mg/L	0.004	0.002	0.015	-	11/08/13 15:57	

Lab Number	Sample Name	Sampled: 10/29/13 5:50		Sample Composition:					
3304011-24	GH13B								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
[†] Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	11/08/13 15:57	



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project #: N/A
PWSID #: -
PO #: 140989


Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/29/13 5:51		Sample Composition:				
3304011-25	GH14A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<i>†Lead</i>	1030	EPA 200.9	mg/L	0.004	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/29/13 5:53		Sample Composition:				
3304011-26	GH14B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<i>†Lead</i>	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/29/13 6:02		Sample Composition:				
3304011-27	GH15A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<i>†Lead</i>	1030	EPA 200.9	mg/L	0.008	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/29/13 6:04		Sample Composition:				
3304011-28	GH15B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<i>†Lead</i>	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project #: N/A
PWSID #: -
PO #: 140989

Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/29/13 6:06		Sample Composition:					
3304011-29	GH16A								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
<i>†Lead</i>	1030	EPA 200.9	mg/L	0.006	0.002	0.015	-	11/08/13 15:57	

Lab Number	Sample Name	Sampled: 10/29/13 6:07		Sample Composition:					
3304011-30	GH16B								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
<i>†Lead</i>	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	11/08/13 15:57	

Lab Number	Sample Name	Sampled: 10/29/13 6:18		Sample Composition:					
3304011-31	GH17A								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
<i>†Lead</i>	1030	EPA 200.9	mg/L	0.008	0.002	0.015	-	11/08/13 15:57	

Lab Number	Sample Name	Sampled: 10/29/13 6:19		Sample Composition:					
3304011-32	GH17B								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
<i>†Lead</i>	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57	



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013


Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project #: N/A
PWSID #: -
PO #: 140989

Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

<u>Lab Number</u>	<u>Sample Name</u>	<u>Sampled:</u>		<u>Sample Composition:</u>				
3304011-33	GH18A	10/29/13	6:23					
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	11/08/13 15:57
3304011-34	GH18B	10/29/13	6:24					
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57
3304011-35	GH19A	10/29/13	6:26					
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.004	0.002	0.015	-	11/08/13 15:57
3304011-36	GH19B	10/29/13	6:28					
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 839-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011

**C
L
I
E
N
T**
David Douglas School District
Attn: David Callaway
2900 SE 122nd
Portland OR, 97236
Phone: (503) 252-2900

Project: -
Project #: N/A
PWSID #: -
PO #: 140989

Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/29/13 5:55		Sample Composition:				
3304011-37	GH20A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.028	0.002	0.015	-	11/08/13 15:57 MCL

Lab Number	Sample Name	Sampled: 10/29/13 5:56		Sample Composition:				
3304011-38	GH20B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/29/13 5:59		Sample Composition:				
3304011-39	GH21A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.002	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/29/13 6:00		Sample Composition:				
3304011-40	GH21B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	11/08/13 15:57



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 839-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project #: N/A
PWSID #: -
PO #: 140989


Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/29/13 6:15		Sample Composition:				
3304011-41	GH22A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/29/13 6:16		Sample Composition:				
3304011-42	GH22B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/29/13 6:20		Sample Composition:				
3304011-43	GH23A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/29/13 6:22		Sample Composition:				
3304011-44	GH23B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011

**C
L
I
E
N
T**
David Douglas School District
Attn: David Callaway
2900 SE 122nd
Portland OR, 97236
Phone: (503) 252-2900

Project: -
Project #: N/A
PWSID #: -
PO #: 140989

Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/29/13 6:56		Sample Composition:				
3304011-45	GHHALL33A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/29/13 6:57		Sample Composition:				
3304011-46	GHHALL33B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/29/13 7:06		Sample Composition:				
3304011-47	GH31A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number	Sample Name	Sampled: 10/29/13 7:08		Sample Composition:				
3304011-48	GH31B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011

**C
L
I
E
N
T**
David Douglas School District
Attn: David Callaway
2900 SE 122nd
Portland OR, 97236
Phone: (503) 252-2900

Project: -
Project #: N/A
PWSID #: -
PO #: 140989

Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

Lab Number 3304011-49 **Sample Name** GH32A **Sampled:** 10/29/13 7:04 **Sample Composition:**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number 3304011-50 **Sample Name** GH32B **Sampled:** 10/29/13 7:05 **Sample Composition:**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/08/13 15:57

Lab Number 3304011-51 **Sample Name** GH33A **Sampled:** 10/29/13 6:50 **Sample Composition:**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57

Lab Number 3304011-52 **Sample Name** GH33B **Sampled:** 10/29/13 6:52 **Sample Composition:**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011

**C
L
I
E
N
T**
David Douglas School District
Attn: David Callaway
2900 SE 122nd
Portland OR, 97236
Phone: (503) 252-2900

Project: -
Project #: N/A
PWSID #: -
PO #: 140989


Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/29/13 6:47		Sample Composition:				
3304011-53	GH34A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/29/13 6:48		Sample Composition:				
3304011-54	GH34B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 6:37		Sample Composition:				
3304011-55	GHOFFICEA							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.009	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 6:39		Sample Composition:				
3304011-56	GHOFFICEB							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.009	0.002	0.015	-	11/11/13 15:57



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project #: N/A
PWSID #: -
PO #: 140989

Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

Lab Number 3304011-57 **Sample Name** GHHALL1A **Sampled:** 10/25/13 7:06 **Sample Composition:**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.017	0.002	0.015	-	11/11/13 15:57 MCLB

Lab Number 3304011-58 **Sample Name** GHHALL1B **Sampled:** 10/25/13 7:08 **Sample Composition:**


Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57

Lab Number 3304011-59 **Sample Name** GHHALL1A **Sampled:** 10/25/13 7:56 **Sample Composition:**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57

Lab Number 3304011-60 **Sample Name** GHHALL1B **Sampled:** 10/25/13 7:58 **Sample Composition:**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project #: N/A
PWSID #: -
PO #: 140989

Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/29/13 6:59		Sample Composition:				
3304011-61	GHHALL32A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/29/13 7:01		Sample Composition:				
3304011-62	GHHALL32B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/29/13 6:40		Sample Composition:				
3304011-63	GHGYM1A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/29/13 6:41		Sample Composition:				
3304011-64	GHGYM1B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project #: N/A
PWSID #: -
PO #: 140989

Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/29/13 6:42		Sample Composition:				
3304011-65	GHGYM2A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/29/13 6:43		Sample Composition:				
3304011-66	GHGYM2B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 7:01		Sample Composition:				
3304011-67	GHCAFEA							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 7:03		Sample Composition:				
3304011-68	GHCAFEB							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57



13035 SW Pacific Hwy
 Tigard, OR 97223
 Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
 Laboratory
 Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
 Received: 10/31/2013
 Sampled By: Faye Bayer
 Work Order: 3304011

**C
 L
 I
 E
 N
 T** David Douglas School District
 Attn: David Callaway
 2900 SE 122nd
 Portland OR, 97236
 Phone: (503) 252-2900

Project: -
 Project #: N/A
 PWSID #: -
 PO #: 140989


Sampling Location: Gilbert Heights
 Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/25/13 6:54		Sample Composition:				
3304011-69	GHKITCHEN1A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<i>†Lead</i>	1030	EPA 200.9	mg/L	0.007	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 6:56		Sample Composition:				
3304011-70	GHKITCHEN1B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<i>†Lead</i>	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 6:57		Sample Composition:				
3304011-71	GHKITCHEN2A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<i>†Lead</i>	1030	EPA 200.9	mg/L	0.002	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/25/13 6:58		Sample Composition:				
3304011-72	GHKITCHEN2B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<i>†Lead</i>	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 884-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/12/2013
Received: 10/31/2013
Sampled By: Faye Bayer
Work Order: 3304011


C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project #: N/A
PWSID #: -
PO #: 140989

Sampling Location: Gilbert Heights
Sample Matrix: Drinking Water

ND = None detected MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit
MCLE This analyte exceeds the MCL limit.

+All procedures for this analysis conform to NELAC standards.

Approved by: 
Scott Dickman
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 04/02/2014
Received: 03/27/2014
Sampled By:
Work Order: 4086013

C David Douglas School District
L Attn: -
I 1500 SE 130th
E Portland OR, 97233
N Phone: (503) 252-2900
T

Project: -
Project # : N/A
PWSID # : -

Sample Matrix: Water


Lab Number	Sample Name	Sampled: 3/27/14 6:40		Sample Composition:				
4086013-01	GH 20 A							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.028	0.002	0.015	-	04/02/14 11:55 MCLE

Lab Number	Sample Name	Sampled: 3/27/14 6:41		Sample Composition:				
4086013-02	GH 20 B							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.019	0.002	0.015	-	04/02/14 11:55 MCLE

Lab Number	Sample Name	Sampled: 3/27/14 6:50		Sample Composition:				
4086013-03	GH 20 C							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.013	0.002	0.015	-	04/02/14 11:55

ND = None detected **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
MCLE This analyte exceeds the MCL limit.

†All procedures for this analysis conform to NELAC standards.

Approved by: 
Scott Dickman
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 03/11/2015
Received: 03/06/2015
Sampled By:
Work Order: 5065004

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project # : N/A
PWSID # : -

Sampling Location: Gilbert Heights/Halsey Center/Yaws
Sample Matrix: Water

Lab Number	Sample Name	Sampled: 3/4/15 6:32		Sample Composition:				
5065004-01	GHCL #1							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.105	0.008	0.015	-	03/10/15 17:43 MCLE

Lab Number	Sample Name	Sampled: 3/4/15 6:34		Sample Composition:				
5065004-02	GHCL#2							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	03/10/15 17:43

Lab Number	Sample Name	Sampled: 3/6/15 7:53		Sample Composition:				
5065004-03	HB#1							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.002	0.002	0.015	-	03/10/15 17:43

Lab Number	Sample Name	Sampled: 3/6/15 7:55		Sample Composition:				
5065004-04	HB#2							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	03/10/15 17:43

Lab Number	Sample Name	Sampled: 3/6/15 8:03		Sample Composition:				
5065004-05	Yaws#1							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.010	0.002	0.015	-	03/10/15 17:43



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 03/11/2015
Received: 03/06/2015
Sampled By:
Work Order: 5065004

**C
L
I
E
N
T**
David Douglas School District
Attn: David Callaway
2900 SE 122nd
Portland OR, 97236
Phone: (503) 252-2900

Project: -
Project # : N/A
PWSID # : -

Sampling Location: Gilbert Heights/Halsey Center/Yaws
Sample Matrix: Water

Lab Number	Sample Name	Sampled: 3/6/15 8:05		Sample Composition:				
5065004-06	Yaws#2							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	03/10/15 17:43

ND = None detected **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
MCL This analyte exceeds the MCL limit.

†All procedures for this analysis conform to NELAC standards.

Approved by: 
Scott Dickman
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

RECEIVED

MAY 25 2016

ACCOUNTS PAYABLE

Reported: 05/12/2016
Received: 04/29/2016
Sampled By: Troy Thompson
Work Order: 6120002

C
L
I
E
N
T

David Douglas School District

Attn: Troy Thompson

11300 NE Halsey St

Portland OR, 97220

Phone: (503) 252-2900

Project:

Project # : N/A

PWSID # :

Sampling Location: Varies

Sample Matrix: Water

Lab Number

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
6120002-01 Sample Name: GP Cafe C Sampled: 4/17/16 6:17							
<i>Metals (Total)</i>							
+Lead	1030	EPA 200.9	mg/L	0.010	0.002	0.015	05/09/16 17:17
6120002-02 Sample Name: GP Cafe D Sampled: 4/17/16 6:17							
<i>Metals (Total)</i>							
+Lead	1030	EPA 200.9	mg/L	0.008	0.002	0.015	05/09/16 17:17
6120002-03 Sample Name: GP GC Sampled: 4/17/16 6:15							
<i>Metals (Total)</i>							
+Lead	1030	EPA 200.9	mg/L	0.010	0.002	0.015	05/09/16 17:17
6120002-04 Sample Name: GP GD Sampled: 4/17/16 6:15							
<i>Metals (Total)</i>							
+Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	05/09/16 17:17
6120002-05 Sample Name: AO hall 9C Sampled: 4/17/16 6:45							
<i>Metals (Total)</i>							
+Lead	1030	EPA 200.9	mg/L	0.005	0.002	0.015	05/09/16 17:17
6120002-06 Sample Name: AO hall 9D Sampled: 4/17/16 6:45							
<i>Metals (Total)</i>							
+Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	05/09/16 17:17
6120002-07 Sample Name: EB 3C Sampled: 4/17/16 6:30							
<i>Metals (Total)</i>							
+Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	05/09/16 17:17



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

RECEIVED

MAY 25 2016

ACCOUNTS PAYABLE

Reported: 05/12/2016
Received: 04/29/2016
Sampled By: Troy Thompson
Work Order: 6120002

C
L
I
E
N
T

David Douglas School District
Attn: Troy Thompson
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
PWSID # :

Sampling Location: Varies
Sample Matrix: Water

Lab Number

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
6120002-08 Sample Name: EB 3D Sampled: 4/17/16 6:30							
<i>Metals (Total)</i>							
+Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	05/09/16 17:17
6120002-09 Sample Name: GH 20C Sampled: 4/17/16 6:45							
<i>Metals (Total)</i>							
+Lead	1030	EPA 200.9	mg/L	0.095	0.008	0.015	05/09/16 17:17 MCLE
6120002-10 Sample Name: GH 20D Sampled: 4/17/16 6:45							
<i>Metals (Total)</i>							
+Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	05/09/16 17:17
6120002-11 Sample Name: GH CL #1A Sampled: 4/17/16 6:50							
<i>Metals (Total)</i>							
+Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	05/09/16 17:17
6120002-12 Sample Name: GH CL #1B Sampled: 4/17/16 6:50							
<i>Metals (Total)</i>							
+Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	05/09/16 17:17
6120002-13 Sample Name: GH hall 1D Sampled: 4/17/16 6:46							
<i>Metals (Total)</i>							
+Lead	1030	EPA 200.9	mg/L	0.002	0.002	0.015	05/11/16 14:46
6120002-14 Sample Name: GH hall 1C Sampled: 4/17/16 6:45							
<i>Metals (Total)</i>							
+Lead	1030	EPA 200.9	mg/L	0.023	0.002	0.015	05/11/16 14:46 MCLE



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

RECEIVED

MAY 25

ACCOUNTS PAYABLE

Reported: 05/12/2016
Received: 04/29/2016
Sampled By: Troy Thompson
Work Order: 6120002

C
L
I
E
N
T

David Douglas School District
Attn: Troy Thompson
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
PWSID # :

Sampling Location: Varies
Sample Matrix: Water

Lab Number

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are accredited in accordance with NELAP standards.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.