

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 07/20/2017
Received: 07/07/2017
Sampled By: Troy Thompson
Work Order: 7188021

**C
L
I
E
N
T**

David Douglas School District
Attn: -
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:

Project # : N/A
Sample Type :

Sampling Location: Gilbert Park

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7188021-11	Sample Name: GP 68F Sampled: 7/6/17 6:23		Matrix: Water				
†Lead	1030	EPA 200.9	3	ppb	2	20 ppb	07/19/17 16:02
7188021-12	Sample Name: GP 76F Sampled: 7/6/17 6:24		Matrix: Water				
†Lead	1030	EPA 200.9	4	ppb	2	20 ppb	07/19/17 16:02
7188021-13	Sample Name: GP 77F Sampled: 7/6/17 6:24		Matrix: Water				
†Lead	1030	EPA 200.9	7	ppb	2	20 ppb	07/19/17 16:02

MCL This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit


†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:



Adriana Gonzalez-Gray
Laboratory Director



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 07/20/2017
Received: 07/07/2017
Sampled By: Troy Thompson
Work Order: 7188021

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Gilbert Park

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7188021-01	Sample Name: GP 5F Sampled: 7/6/17 6:30		Matrix: Water				
+Lead	1030	EPA 200.9	7	ppb	2	20 ppb	07/19/17 16:02
7188021-02	Sample Name: GP 19F Sampled: 7/6/17 6:10		Matrix: Water				
+Lead	1030	EPA 200.9	28	ppb	2	20 ppb	07/19/17 16:02 MCLE
7188021-03	Sample Name: GP 23F Sampled: 7/6/17 6:10		Matrix: Water				
+Lead	1030	EPA 200.9	15	ppb	2	20 ppb	07/19/17 16:02
7188021-04	Sample Name: GP 25F Sampled: 7/6/17 6:11		Matrix: Water				
+Lead	1030	EPA 200.9	27	ppb	2	20 ppb	07/19/17 16:02 MCLE
7188021-05	Sample Name: GP 27F Sampled: 7/6/17 6:12		Matrix: Water				
+Lead	1030	EPA 200.9	13	ppb	2	20 ppb	07/19/17 16:02
7188021-06	Sample Name: GP 51DF Sampled: 7/6/17 6:15		Matrix: Water				
+Lead	1030	EPA 200.9	9	ppb	2	20 ppb	07/19/17 16:02
7188021-07	Sample Name: GP 52F Sampled: 7/6/17 6:19		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/19/17 16:02
7188021-08	Sample Name: GP 55DF Sampled: 7/6/17 6:18		Matrix: Water				
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	07/19/17 16:02
7188021-09	Sample Name: GP 60F Sampled: 7/6/17 6:22		Matrix: Water				
+Lead	1030	EPA 200.9	5	ppb	2	20 ppb	07/19/17 16:02
7188021-10	Sample Name: GP 63DF Sampled: 7/6/17 6:20		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/19/17 16:02