



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/20/2017
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298034

C **David Douglas School District**
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Gilbert Park

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298034-01	Sample Name: GP1 F Sampled: 10/22/16 8:42		Matrix: Water				
+Lead	1030	EPA 200.9	5.6	ppb	2.0	20 ppb	01/18/17 16:14
6298034-02	Sample Name: GP2 F Sampled: 10/22/16 8:43		Matrix: Water				
+Lead	1030	EPA 200.9	4.3	ppb	2.0	20 ppb	01/18/17 16:14
6298034-03	Sample Name: GP3 SK Sampled: 10/22/16 8:43		Matrix: Water				
+Lead	1030	EPA 200.9	8.1	ppb	2.0	20 ppb	01/18/17 16:14
6298034-04	Sample Name: GP4 F Sampled: 10/22/16 8:44		Matrix: Water				
+Lead	1030	EPA 200.9	3.4	ppb	2.0	20 ppb	01/18/17 16:14
6298034-05	Sample Name: GP5 F Sampled: 10/22/16 8:44		Matrix: Water				
+Lead	1030	EPA 200.9	20.1	ppb	2.0	20 ppb	01/18/17 16:14
6298034-06	Sample Name: GP6 DF Sampled: 10/22/16 8:45		Matrix: Water				
+Lead	1030	EPA 200.9	3.7	ppb	2.0	20 ppb	01/18/17 16:14
6298034-07	Sample Name: GP7 F Sampled: 10/22/16 8:49		Matrix: Water				
+Lead	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	01/18/17 16:14
6298034-08	Sample Name: GP8 F Sampled: 10/22/16 8:50		Matrix: Water				
+Lead	1030	EPA 200.9	7.5	ppb	2.0	20 ppb	01/18/17 16:14
6298034-09	Sample Name: GP9 F Sampled: 10/22/16 8:50		Matrix: Water				
+Lead	1030	EPA 200.9	7.4	ppb	2.0	20 ppb	01/18/17 16:14
6298034-10	Sample Name: GP10 Sampled: 10/22/16 8:50		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/20/2017
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298034


C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Gilbert Park

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298034-11	Sample Name: GP11 F Sampled: 10/22/16 8:52		Matrix: Water				
+Lead	1030	EPA 200.9	7.2	ppb	2.0	20 ppb	01/18/17 16:14
6298034-12	Sample Name: GP12 B Sampled: 10/22/16 8:52		Matrix: Water				
+Lead	1030	EPA 200.9	10.8	ppb	2.0	20 ppb	01/19/17 16:38
6298034-13	Sample Name: GP13 F Sampled: 10/22/16 8:53		Matrix: Water				
+Lead	1030	EPA 200.9	9.5	ppb	2.0	20 ppb	01/19/17 16:38
6298034-14	Sample Name: GP14 B Sampled: 10/22/16 8:53		Matrix: Water				
+Lead	1030	EPA 200.9	7.2	ppb	2.0	20 ppb	01/19/17 16:38
6298034-15	Sample Name: GP15 F Sampled: 10/22/16 8:54		Matrix: Water				
+Lead	1030	EPA 200.9	8.1	ppb	2.0	20 ppb	01/19/17 16:38
6298034-16	Sample Name: GP16 B Sampled: 10/22/16 8:54		Matrix: Water				
+Lead	1030	EPA 200.9	8.4	ppb	2.0	20 ppb	01/19/17 16:38
6298034-17	Sample Name: GP17 F Sampled: 10/22/16 8:55		Matrix: Water				
+Lead	1030	EPA 200.9	4.3	ppb	2.0	20 ppb	01/19/17 16:38
6298034-18	Sample Name: GP18 B Sampled: 10/22/16 8:55		Matrix: Water				
+Lead	1030	EPA 200.9	4.0	ppb	2.0	20 ppb	01/19/17 16:38
6298034-19	Sample Name: GP19 F Sampled: 10/22/16 8:56		Matrix: Water				
+Lead	1030	EPA 200.9	18.9	ppb	2.0	20 ppb	01/19/17 16:38
6298034-20	Sample Name: GP20 B Sampled: 10/22/16 8:56		Matrix: Water				
+Lead	1030	EPA 200.9	8.9	ppb	2.0	20 ppb	01/19/17 16:38



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 01/20/2017
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298034


C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Gilbert Park

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298034-21	Sample Name: GP21 F Sampled: 10/22/16 8:57		Matrix: Water				
+Lead	1030	EPA 200.9	12.0	ppb	2.0	20 ppb	01/19/17 16:38
6298034-22	Sample Name: GP22 B Sampled: 10/22/16 8:57		Matrix: Water				
+Lead	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	01/19/17 16:38
6298034-23	Sample Name: GP23 F Sampled: 10/22/16 8:58		Matrix: Water				
+Lead	1030	EPA 200.9	19.4	ppb	2.0	20 ppb	01/19/17 16:38
6298034-24	Sample Name: GP24 B Sampled: 10/22/16 8:58		Matrix: Water				
+Lead	1030	EPA 200.9	7.8	ppb	2.0	20 ppb	01/19/17 16:38
6298034-25	Sample Name: GP25 F Sampled: 10/22/16 8:59		Matrix: Water				
+Lead	1030	EPA 200.9	16.8	ppb	2.0	20 ppb	01/19/17 16:38
6298034-26	Sample Name: GP26 B Sampled: 10/22/16 8:59		Matrix: Water				
+Lead	1030	EPA 200.9	5.6	ppb	2.0	20 ppb	01/19/17 16:38
6298034-27	Sample Name: FP27 F Sampled: 10/22/16 9:00		Matrix: Water				
+Lead	1030	EPA 200.9	23.0	ppb	2.0	20 ppb	01/19/17 16:38 MCLE
6298034-28	Sample Name: GP29 F Sampled: 10/22/16 9:01		Matrix: Water				
+Lead	1030	EPA 200.9	11.1	ppb	2.0	20 ppb	01/19/17 16:38
6298034-29	Sample Name: GP30 B Sampled: 10/22/16 9:01		Matrix: Water				
+Lead	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	01/19/17 16:38
6298034-30	Sample Name: GP31 Bradley Sampled: 10/22/16 9:02		Matrix: Water				
+Lead	1030	EPA 200.9	8.2	ppb	2.0	20 ppb	01/19/17 16:38



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/20/2017
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298034

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Gilbert Park

Lab Number


Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298034-31	Sample Name: GP32 Bradley Sampled: 10/22/16 9:02		Matrix: Water				
+Lead	1030	EPA 200.9	13.8	ppb	2.0	20 ppb	01/19/17 16:38
6298034-32	Sample Name: GP33 Bradley Sampled: 10/22/16 9:03		Matrix: Water				
+Lead	1030	EPA 200.9	10.5	ppb	2.0	20 ppb	01/19/17 16:38
6298034-33	Sample Name: GP34 Bradley Sampled: 10/22/16 9:03		Matrix: Water				
+Lead	1030	EPA 200.9	12.8	ppb	2.0	20 ppb	01/18/17 16:14
6298034-34	Sample Name: GP35 F Sampled: 10/22/16 9:04		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
6298034-35	Sample Name: GP36 F Sampled: 10/22/16 9:04		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
6298034-36	Sample Name: GP37 F Sampled: 10/22/16 9:05		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
6298034-37	Sample Name: GP38 Bradley Sampled: 10/22/16 9:05		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
6298034-38	Sample Name: GP39 Bradley Sampled: 10/22/16 9:06		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
6298034-39	Sample Name: GP40 F Sampled: 10/22/16 9:06		Matrix: Water				
+Lead	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	01/18/17 16:14

MCL This analyte exceeds the MCL limit.

ND = None detected at the MRL

MRL = Minimum Reporting Limit

MCL = Maximum Contamination Limit



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/20/2017
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298034

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Gilbert Park

Lab Number

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:

Carrie Seidl for AGG

Adriana Gonzalez-Gray
Laboratory Director

