

**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/20/2017  
Received: 10/24/2016  
Sampled By: Troy Thompson  
Work Order: 6298033


**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Gilbert Park

## Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6298033-01</b>	<b>Sample Name:</b> GP41 B <b>Sampled:</b> 10/22/16 9:07		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-02</b>	<b>Sample Name:</b> GP42 F <b>Sampled:</b> 10/22/16 9:07		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	5.8	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-03</b>	<b>Sample Name:</b> GP43 B <b>Sampled:</b> 10/22/16 9:08		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-04</b>	<b>Sample Name:</b> GP44 DF <b>Sampled:</b> 10/22/16 9:08		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-05</b>	<b>Sample Name:</b> GP45 DF <b>Sampled:</b> 10/22/16 9:08		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-06</b>	<b>Sample Name:</b> GP46 F <b>Sampled:</b> 10/22/16 9:09		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-07</b>	<b>Sample Name:</b> GP47 F <b>Sampled:</b> 10/22/16 9:09		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-08</b>	<b>Sample Name:</b> GP48 F <b>Sampled:</b> 10/22/16 9:09		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-09</b>	<b>Sample Name:</b> GP49 F <b>Sampled:</b> 10/22/16 9:10		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-10</b>	<b>Sample Name:</b> GP50 DF <b>Sampled:</b> 10/22/16 9:18		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 01/20/2017  
Received: 10/24/2016  
Sampled By: Troy Thompson  
Work Order: 6298033


**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Gilbert Park

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6298033-11</b>	<b>Sample Name:</b> GP52 F <b>Sampled:</b> 10/22/16 9:19		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	16.5	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-12</b>	<b>Sample Name:</b> GP53 B <b>Sampled:</b> 10/22/16 9:19		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-13</b>	<b>Sample Name:</b> GP54 F <b>Sampled:</b> 10/22/16 9:20		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	10.5	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-14</b>	<b>Sample Name:</b> GP55 B <b>Sampled:</b> 10/22/16 9:20		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	<b>92.6</b>	ppb	8.0	20 ppb	01/18/17 16:14 <b>MCL</b>
<b>6298033-15</b>	<b>Sample Name:</b> GP56 F <b>Sampled:</b> 10/22/16 9:21		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.7	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-16</b>	<b>Sample Name:</b> GP57 B <b>Sampled:</b> 10/22/16 9:21		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.5	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-17</b>	<b>Sample Name:</b> GP58 F <b>Sampled:</b> 10/22/16 9:22		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	9.3	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-18</b>	<b>Sample Name:</b> GP60 F <b>Sampled:</b> 10/22/16 9:23		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	18.6	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-19</b>	<b>Sample Name:</b> GP61 B <b>Sampled:</b> 10/22/16 9:23		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.6	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-20</b>	<b>Sample Name:</b> GP62 F <b>Sampled:</b> 10/22/16 9:24		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8.2	ppb	2.0	20 ppb	01/18/17 16:14



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/20/2017  
Received: 10/24/2016  
Sampled By: Troy Thompson  
Work Order: 6298033


**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Gilbert Park

## Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6298033-21</b>	<b>Sample Name:</b> GP63 B <b>Sampled:</b> 10/22/16 9:24		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	22.6	ppb	2.0	20 ppb	01/18/17 16:14 <b>MCLE</b>
<b>6298033-22</b>	<b>Sample Name:</b> GP64 F <b>Sampled:</b> 10/22/16 9:25		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.5	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-23</b>	<b>Sample Name:</b> GP65 B <b>Sampled:</b> 10/22/16 9:25		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	14.1	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-24</b>	<b>Sample Name:</b> GP66 F <b>Sampled:</b> 10/22/16 9:26		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	10.4	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-25</b>	<b>Sample Name:</b> GP67 B <b>Sampled:</b> 10/22/16 9:26		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-26</b>	<b>Sample Name:</b> GP68 F <b>Sampled:</b> 10/22/16 9:27		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	19.9	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-27</b>	<b>Sample Name:</b> GP69 B <b>Sampled:</b> 10/22/16 9:27		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8.8	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-28</b>	<b>Sample Name:</b> GP70 F <b>Sampled:</b> 10/22/16 9:28		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	5.6	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-29</b>	<b>Sample Name:</b> GP71 B <b>Sampled:</b> 10/22/16 9:28		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	01/18/17 16:14
<b>6298033-30</b>	<b>Sample Name:</b> GP72 Bradley <b>Sampled:</b> 10/22/16 9:29		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.7	ppb	2.0	20 ppb	01/18/17 16:14



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 01/20/2017  
Received: 10/24/2016  
Sampled By: Troy Thompson  
Work Order: 6298033


**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Gilbert Park

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6298033-31</b>	<b>Sample Name:</b> GP73 Bradley <b>Sampled:</b> 10/22/16 9:29		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	01/19/17 16:38
<b>6298033-32</b>	<b>Sample Name:</b> GP74 Bradley <b>Sampled:</b> 10/22/16 9:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	13.7	ppb	2.0	20 ppb	01/19/17 16:38
<b>6298033-33</b>	<b>Sample Name:</b> GP75 Bradley <b>Sampled:</b> 10/22/16 9:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	18.8	ppb	2.0	20 ppb	01/19/17 16:38
<b>6298033-34</b>	<b>Sample Name:</b> GP76 F <b>Sampled:</b> 10/22/16 9:31		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	17.0	ppb	2.0	20 ppb	01/19/17 16:38
<b>6298033-35</b>	<b>Sample Name:</b> GP77 F <b>Sampled:</b> 10/22/16 9:31		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	<b>20.1</b>	ppb	2.0	20 ppb	01/19/17 16:38 <b>MCL</b>
<b>6298033-36</b>	<b>Sample Name:</b> GP78 DF <b>Sampled:</b> 10/22/16 9:14		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7.2	ppb	2.0	20 ppb	01/19/17 16:38
<b>6298033-37</b>	<b>Sample Name:</b> GP79 F <b>Sampled:</b> 10/22/16 9:14		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	01/19/17 16:38
<b>6298033-38</b>	<b>Sample Name:</b> GP80 F <b>Sampled:</b> 10/22/16 9:15		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.7	ppb	2.0	20 ppb	01/19/17 16:38
<b>6298033-39</b>	<b>Sample Name:</b> GP81 F <b>Sampled:</b> 10/22/16 9:15		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	01/19/17 16:38
<b>6298033-40</b>	<b>Sample Name:</b> GP82 Sprayer <b>Sampled:</b> 10/22/16 8:42		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	01/19/17 16:38



Professional Laboratory Services

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/20/2017

Received: 10/24/2016

Sampled By: Troy Thompson

Work Order: 6298033

**C** **David Douglas School District**  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**

Project # : N/A

Sample Type :

Sampling Location: Gilbert Park

---

## Lab Number

---

**MCLE** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL

**MRL** = Minimum Reporting Limit

**MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:

Adriana Gonzalez-Gray  
Laboratory Director

