

**DAVID DOUGLAS SCHOOL DISTRICT
LEAD TESTING RESULTS BY SCHOOL**

6/6/2016 3:59 PM

Classroom/Location	Analysis Report Date	Work Order #	1st Draw		1 Min Draw		Action Taken
			Test #1 mg/L	Test #2 mg/L	Test #1 mg/L	Test #2 mg/L	
DISTRICT OFFICE - HALSEY/YAWS							
HALSEY	3/11/2015	5065004	0.0020	nd			none
YAWS	3/11/2015	5065004	0.0100	nd			none



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 03/11/2015
Received: 03/06/2015
Sampled By:
Work Order: 5065004

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project # : N/A
PWSID # : -

Sampling Location: Gilbert Heights/Halsey Center/Yaws
Sample Matrix: Water


Lab Number	Sample Name	Sampled: 3/4/15 6:32		Sample Composition:				
5065004-01	GHCL #1							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.105	0.008	0.015	-	03/10/15 17:43 MCLE

Lab Number	Sample Name	Sampled: 3/4/15 6:34		Sample Composition:				
5065004-02	GHCL#2							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	03/10/15 17:43

Lab Number	Sample Name	Sampled: 3/6/15 7:53		Sample Composition:				
5065004-03	HB#1							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.002	0.002	0.015	-	03/10/15 17:43

Lab Number	Sample Name	Sampled: 3/6/15 7:55		Sample Composition:				
5065004-04	HB#2							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	03/10/15 17:43

Lab Number	Sample Name	Sampled: 3/6/15 8:03		Sample Composition:				
5065004-05	Yaws#1							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.010	0.002	0.015	-	03/10/15 17:43



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 03/11/2015
Received: 03/06/2015
Sampled By:
Work Order: 5065004

**C
L
I
E
N
T**
David Douglas School District
Attn: David Callaway
2900 SE 122nd
Portland OR, 97236
Phone: (503) 252-2900

Project: -
Project # : N/A
PWSID # : -


Sampling Location: Gilbert Heights/Halsey Center/Yaws
Sample Matrix: Water

Lab Number	Sample Name	Sampled: 3/6/15 8:05		Sample Composition:					
5065004-06	Yaws#2								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	03/10/15 17:43	

ND = None detected **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
MCL This analyte exceeds the MCL limit.

†All procedures for this analysis conform to NELAC standards.

Approved by:



Scott Dickman
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.