

**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 11/11/2016  
Received: 10/14/2016  
Sampled By: Troy Thompson  
Work Order: 6288036

**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Lincoln Park

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6288036-01</b>	<b>Sample Name:</b> LP01-F <b>Sampled:</b> 10/14/16 4:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-02</b>	<b>Sample Name:</b> LP02-F <b>Sampled:</b> 10/14/16 4:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-03</b>	<b>Sample Name:</b> LP03-Sprayer <b>Sampled:</b> 10/14/16 4:01		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-04</b>	<b>Sample Name:</b> LP04-SK <b>Sampled:</b> 10/14/16 4:01		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-05</b>	<b>Sample Name:</b> LP06-Bubbler <b>Sampled:</b> 10/14/16 4:02		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	14.7	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-06</b>	<b>Sample Name:</b> LP05-Faucet <b>Sampled:</b> 10/14/16 4:04		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.9	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-07</b>	<b>Sample Name:</b> LP07-F <b>Sampled:</b> 10/14/16 4:06		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-08</b>	<b>Sample Name:</b> LP08-F <b>Sampled:</b> 10/14/16 4:06		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8.4	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-09</b>	<b>Sample Name:</b> LP09-B <b>Sampled:</b> 10/14/16 4:07		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.2	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-10</b>	<b>Sample Name:</b> LP10-F <b>Sampled:</b> 10/14/16 4:10		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	6.2	ppb	2.0	20 ppb	11/08/16 17:05



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 11/11/2016  
Received: 10/14/2016  
Sampled By: Troy Thompson  
Work Order: 6288036

**C  
L  
I  
E  
N  
T**  
**David Douglas School District**  
Attn: -  
11300 NE Halsey St  
Portland OR, 97220  
Phone: (503) 252-2900

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Lincoln Park

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6288036-11</b>	<b>Sample Name:</b> LP11-Bradley <b>Sampled:</b> 10/14/16 4:11		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-12</b>	<b>Sample Name:</b> LP12-Bradley <b>Sampled:</b> 10/14/16 4:11		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8.8	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-13</b>	<b>Sample Name:</b> LP13-B <b>Sampled:</b> 10/14/16 4:12		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-14</b>	<b>Sample Name:</b> LP14-F <b>Sampled:</b> 10/14/16 4:12		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7.0	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-15</b>	<b>Sample Name:</b> LP15-B <b>Sampled:</b> 10/14/16 4:13		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-16</b>	<b>Sample Name:</b> LP16-F <b>Sampled:</b> 10/14/16 4:13		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-17</b>	<b>Sample Name:</b> LP17-B <b>Sampled:</b> 10/14/16 4:13		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.6	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-18</b>	<b>Sample Name:</b> LP18-F <b>Sampled:</b> 10/14/16 4:14		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	6.7	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-19</b>	<b>Sample Name:</b> LP19-B <b>Sampled:</b> 10/14/16 4:15		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-20</b>	<b>Sample Name:</b> LP20-F <b>Sampled:</b> 10/14/16 4:17		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	11/08/16 17:05



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

## ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/11/2016  
Received: 10/14/2016  
Sampled By: Troy Thompson  
Work Order: 6288036


**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Lincoln Park

### Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6288036-21</b>	<b>Sample Name:</b> LP21-B <b>Sampled:</b> 10/14/16 4:19		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.6	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-22</b>	<b>Sample Name:</b> LP22-F <b>Sampled:</b> 10/14/16 4:19		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	9.0	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-23</b>	<b>Sample Name:</b> LP23-B <b>Sampled:</b> 10/14/16 4:20		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-24</b>	<b>Sample Name:</b> LP24-F <b>Sampled:</b> 10/14/16 4:20		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	5.1	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-25</b>	<b>Sample Name:</b> LP25-B <b>Sampled:</b> 10/14/16 4:20		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-26</b>	<b>Sample Name:</b> LP26-F <b>Sampled:</b> 10/14/16 4:21		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.8	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-27</b>	<b>Sample Name:</b> LP27-B <b>Sampled:</b> 10/14/16 4:21		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-28</b>	<b>Sample Name:</b> LP28-F <b>Sampled:</b> 10/14/16 4:22		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-29</b>	<b>Sample Name:</b> LP29-B <b>Sampled:</b> 10/14/16 4:22		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-30</b>	<b>Sample Name:</b> LP30-F <b>Sampled:</b> 10/14/16 4:23		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7.1	ppb	2.0	20 ppb	11/08/16 17:05



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

## ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/11/2016  
Received: 10/14/2016  
Sampled By: Troy Thompson  
Work Order: 6288036


**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Lincoln Park

### Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6288036-31</b>	<b>Sample Name:</b> LP31-B <b>Sampled:</b> 10/14/16 4:23		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-32</b>	<b>Sample Name:</b> LP32-F <b>Sampled:</b> 10/14/16 4:23		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.1	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-33</b>	<b>Sample Name:</b> LP33-F <b>Sampled:</b> 10/14/16 4:23		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8.1	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-34</b>	<b>Sample Name:</b> LP34-B <b>Sampled:</b> 10/14/16 4:23		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-35</b>	<b>Sample Name:</b> LP35-B <b>Sampled:</b> 10/14/16 4:24		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.7	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-36</b>	<b>Sample Name:</b> LP36-F <b>Sampled:</b> 10/14/16 4:24		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.5	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-37</b>	<b>Sample Name:</b> LP37-F <b>Sampled:</b> 10/14/16 4:44		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.4	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-38</b>	<b>Sample Name:</b> LP38-F <b>Sampled:</b> 10/14/16 4:25		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-39</b>	<b>Sample Name:</b> LP39-F <b>Sampled:</b> 10/14/16 4:25		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.5	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-40</b>	<b>Sample Name:</b> LP40-F <b>Sampled:</b> 10/14/16 4:26		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 11/11/2016  
Received: 10/14/2016  
Sampled By: Troy Thompson  
Work Order: 6288036

**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Lincoln Park

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6288036-41</b>	<b>Sample Name:</b> LP41-Bradley <b>Sampled:</b> 10/14/16 4:27		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	16.1	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-42</b>	<b>Sample Name:</b> LP42-Bradley <b>Sampled:</b> 10/14/16 4:27		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	10.7	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-43</b>	<b>Sample Name:</b> LP43-F <b>Sampled:</b> 10/14/16 4:27		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.5	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-44</b>	<b>Sample Name:</b> LP44-B <b>Sampled:</b> 10/14/16 4:28		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-45</b>	<b>Sample Name:</b> LP45-F <b>Sampled:</b> 10/14/16 4:28		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-46</b>	<b>Sample Name:</b> LP46-B <b>Sampled:</b> 10/14/16 4:29		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-47</b>	<b>Sample Name:</b> LP47-F <b>Sampled:</b> 10/14/16 4:29		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.7	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-48</b>	<b>Sample Name:</b> LP48-B <b>Sampled:</b> 10/14/16 4:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-49</b>	<b>Sample Name:</b> LP49-F <b>Sampled:</b> 10/14/16 4:31		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.8	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-50</b>	<b>Sample Name:</b> LP50-B <b>Sampled:</b> 10/14/16 4:32		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.8	ppb	2.0	20 ppb	11/08/16 17:05



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 11/11/2016  
Received: 10/14/2016  
Sampled By: Troy Thompson  
Work Order: 6288036


**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Lincoln Park

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6288036-51</b>	<b>Sample Name:</b> LP51-F <b>Sampled:</b> 10/14/16 4:32		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	4.5	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-52</b>	<b>Sample Name:</b> LP52-B <b>Sampled:</b> 10/14/16 4:32		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	2.8	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-53</b>	<b>Sample Name:</b> LP53-F <b>Sampled:</b> 10/14/16 4:32		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-54</b>	<b>Sample Name:</b> LP54-B <b>Sampled:</b> 10/14/16 4:32		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	4.5	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-55</b>	<b>Sample Name:</b> LP55-F <b>Sampled:</b> 10/14/16 4:33		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	4.8	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-56</b>	<b>Sample Name:</b> LP56-B <b>Sampled:</b> 10/14/16 4:33		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	4.6	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-57</b>	<b>Sample Name:</b> LP57-F <b>Sampled:</b> 10/14/16 4:34		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	6.3	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-58</b>	<b>Sample Name:</b> LP58-B <b>Sampled:</b> 10/14/16 4:34		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-59</b>	<b>Sample Name:</b> LP59-F <b>Sampled:</b> 10/14/16 4:35		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	3.6	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-60</b>	<b>Sample Name:</b> LP60-B <b>Sampled:</b> 10/14/16 4:36		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

## ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/11/2016  
Received: 10/14/2016  
Sampled By: Troy Thompson  
Work Order: 6288036

**C**  
**L**  
**I**  
**E**  
**N**  
**T**


**David Douglas School District**  
Attn: -  
11300 NE Halsey St  
Portland OR, 97220  
Phone: (503) 252-2900

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Lincoln Park

### Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6288036-61</b>	<b>Sample Name:</b> LP61-F <b>Sampled:</b> 10/14/16 4:36		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-62</b>	<b>Sample Name:</b> LP62-B <b>Sampled:</b> 10/14/16 4:36		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.8	ppb	2.0	20 ppb	11/08/16 17:05
<b>6288036-63</b>	<b>Sample Name:</b> LP63-F <b>Sampled:</b> 10/14/16 4:37		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8.9	ppb	2.0	20 ppb	11/09/16 16:52
<b>6288036-64</b>	<b>Sample Name:</b> LP64-B <b>Sampled:</b> 10/14/16 4:37		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	5.8	ppb	2.0	20 ppb	11/09/16 16:52
<b>6288036-65</b>	<b>Sample Name:</b> LP65-F <b>Sampled:</b> 10/14/16 4:38		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	12.3	ppb	2.0	20 ppb	11/09/16 16:52
<b>6288036-66</b>	<b>Sample Name:</b> LP66-B <b>Sampled:</b> 10/14/16 4:38		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.4	ppb	2.0	20 ppb	11/09/16 16:52
<b>6288036-67</b>	<b>Sample Name:</b> LP67-F <b>Sampled:</b> 10/14/16 4:39		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.8	ppb	2.0	20 ppb	11/09/16 16:52
<b>6288036-68</b>	<b>Sample Name:</b> LP68-B <b>Sampled:</b> 10/14/16 4:39		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	11/09/16 16:52
<b>6288036-69</b>	<b>Sample Name:</b> LP69-F <b>Sampled:</b> 10/14/16 4:40		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	12.1	ppb	2.0	20 ppb	11/09/16 16:52
<b>6288036-70</b>	<b>Sample Name:</b> LP70-B <b>Sampled:</b> 10/14/16 4:41		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 11/11/2016  
Received: 10/14/2016  
Sampled By: Troy Thompson  
Work Order: 6288036

**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Lincoln Park

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6288036-71</b>	<b>Sample Name:</b> LP71-F <b>Sampled:</b> 10/14/16 4:41		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52
<b>6288036-72</b>	<b>Sample Name:</b> LP72-B <b>Sampled:</b> 10/14/16 4:42		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	4.2	ppb	2.0	20 ppb	11/09/16 16:52
<b>6288036-73</b>	<b>Sample Name:</b> LP73-F <b>Sampled:</b> 10/14/16 4:42		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	17.3	ppb	2.0	20 ppb	11/09/16 16:52
<b>6288036-74</b>	<b>Sample Name:</b> LP74-B <b>Sampled:</b> 10/14/16 4:43		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	3.9	ppb	2.0	20 ppb	11/09/16 16:52
<b>6288036-75</b>	<b>Sample Name:</b> LP75-F <b>Sampled:</b> 10/14/16 4:46		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	5.5	ppb	2.0	20 ppb	11/09/16 16:52
<b>6288036-76</b>	<b>Sample Name:</b> LP76-DF <b>Sampled:</b> 10/14/16 4:46		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52
<b>6288036-77</b>	<b>Sample Name:</b> LP77-F <b>Sampled:</b> 10/14/16 4:47		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52
<b>6288036-78</b>	<b>Sample Name:</b> LP78-F <b>Sampled:</b> 10/14/16 4:47		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	12.3	ppb	2.0	20 ppb	11/09/16 16:52
<b>6288036-79</b>	<b>Sample Name:</b> LP79-F <b>Sampled:</b> 10/14/16 4:49		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	18.6	ppb	2.0	20 ppb	11/09/16 16:52

**ND** = None detected at the MRL      **MRL** = Minimum Reporting Limit      **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.





Professional Laboratory Services

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/11/2016

Received: 10/14/2016

Sampled By: Troy Thompson

Work Order: 6288036

**C** **David Douglas School District**  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Lincoln Park

---

## Lab Number

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director

