



Professional Laboratory Services

13035 SW Pacific Hwy Tigard, OR 97223 Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/13/2017 Received: 12/30/2016 Sampled By: Troy Thompson Work Order: 6365003

CLIENT David Douglas School District Attn: Troy Thompson 11300 NE Halsey St Portland OR, 97220 Phone: (503) 252-2900

Project: Project #: N/A Sample Type:

Sampling Location: Lincoln Park

Lab Number

Table with 8 columns: Lab Number, Code, Method, Result, Units, MRL, EPA MCL*, Analysis Date/ Time. Contains two rows of data for lead testing (6365003-01 and 6365003-02).

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit †All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: [Signature] Adriana Gonzalez-Gray Laboratory Director