

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 01/25/2017
Received: 11/18/2016
Sampled By: Troy Thompson
Work Order: 6323010

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: MECP Glisan


Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6323010-01	Sample Name: MECP 1 F Sampled: 11/18/16 5:51		Matrix: Water				
+Lead	1030	EPA 200.9	5.5	ppb	2.0	20 ppb	01/24/17 16:59
6323010-02	Sample Name: MECP 2 F Sampled: 11/18/16 5:53		Matrix: Water				
+Lead	1030	EPA 200.9	3.6	ppb	2.0	20 ppb	01/24/17 16:59
6323010-03	Sample Name: MECP 3 F Sampled: 11/18/16 5:53		Matrix: Water				
+Lead	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	01/24/17 16:59
6323010-04	Sample Name: MECP 4 F Sampled: 11/18/16 5:54		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/24/17 16:59
6323010-05	Sample Name: MECP 5 F Sampled: 11/18/16 5:55		Matrix: Water				
+Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	01/24/17 16:59
6323010-06	Sample Name: MECP 6 F Sampled: 11/18/16 5:55		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/24/17 16:59
6323010-07	Sample Name: MECP 7 F Sampled: 11/18/16 5:56		Matrix: Water				
+Lead	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	01/24/17 16:59

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director