

**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/25/2017  
Received: 11/18/2016  
Sampled By: Troy Thompson  
Work Order: 6323012

**C  
L  
I  
E  
N  
T**  
**David Douglas School District**  
Attn: -  
11300 NE Halsey St  
Portland OR, 97220  
Phone: (503) 252-2900

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: MECP Pac Trust


## Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6323012-01</b>	<b>Sample Name:</b> MECP PAC 1 F <b>Sampled:</b> 11/18/16 6:23		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/24/17 16:59
<b>6323012-02</b>	<b>Sample Name:</b> MECP PAC 2 F <b>Sampled:</b> 11/18/16 6:24		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	5.0	ppb	2.0	20 ppb	01/24/17 16:59
<b>6323012-03</b>	<b>Sample Name:</b> MECP PAC 3 F <b>Sampled:</b> 11/18/16 6:24		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/24/17 16:59
<b>6323012-04</b>	<b>Sample Name:</b> MECP PAC 4 DF <b>Sampled:</b> 11/18/16 6:26		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/24/17 16:59
<b>6323012-05</b>	<b>Sample Name:</b> MECP PAC 5 F <b>Sampled:</b> 11/18/16 6:25		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/24/17 16:59
<b>6323012-06</b>	<b>Sample Name:</b> MECP PAC 6 F <b>Sampled:</b> 11/18/16 6:25		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/24/17 16:59

**ND** = None detected at the MRL      **MRL** = Minimum Reporting Limit      **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director