



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 01/04/2017  
Received: 12/30/2016  
Sampled By: Troy Thompson  
Work Order: 6365002

**C  
L  
I  
E  
N  
T**  
**David Douglas School District**  
Attn: Troy Thompson  
11300 NE Halsey St  
Portland OR, 97220  
Phone: (503) 252-2900

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Menlo Park Elementary

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6365002-01</b>	<b>Sample Name:</b> MN 002F retest <b>Sampled:</b> 12/29/16 6:27		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	15.7	ppb	2.0	20 ppb	01/03/17 16:03
<b>6365002-02</b>	<b>Sample Name:</b> MN 008F retest <b>Sampled:</b> 12/29/16 6:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	<b>28.4</b>	ppb	2.0	20 ppb	01/03/17 16:03 <b>MCLE</b>
<b>6365002-03</b>	<b>Sample Name:</b> MN 10F retest <b>Sampled:</b> 12/29/16 6:32		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	6.5	ppb	2.0	20 ppb	01/03/17 16:03

**MCLE** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: \_\_\_\_\_

Adriana Gonzalez-Gray  
Laboratory Director