

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/14/2016
Received: 10/14/2016
Sampled By: Troy Thompson
Work Order: 6288037


**C
L
I
E
N
T**
David Douglas School District
Attn: Troy Thompson
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: Mill Park

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6288037-01	Sample Name: MP01-F Sampled: 10/13/16 4:00		Matrix: Water				
+Lead	1030	EPA 200.9	13.3	ppb	2.0	20 ppb	11/09/16 16:52
6288037-02	Sample Name: MP02-F Sampled: 10/13/16 4:00		Matrix: Water				
+Lead	1030	EPA 200.9	6.8	ppb	2.0	20 ppb	11/09/16 16:52
6288037-03	Sample Name: MP03-SP Sampled: 10/13/16 4:00		Matrix: Water				
+Lead	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	11/09/16 16:52
6288037-04	Sample Name: MP04-SK Sampled: 10/13/16 4:02		Matrix: Water				
+Lead	1030	EPA 200.9	5.4	ppb	2.0	20 ppb	11/09/16 16:52
6288037-05	Sample Name: MP05-F Sampled: 10/13/16 4:04		Matrix: Water				
+Lead	1030	EPA 200.9	11.6	ppb	2.0	20 ppb	11/09/16 16:52
6288037-06	Sample Name: MP06-DF Sampled: 10/13/16 4:07		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52
6288037-07	Sample Name: MP07-F Sampled: 10/13/16 4:07		Matrix: Water				
+Lead	1030	EPA 200.9	11.4	ppb	2.0	20 ppb	11/09/16 16:52
6288037-08	Sample Name: MP08-F Sampled: 10/13/16 4:08		Matrix: Water				
+Lead	1030	EPA 200.9	13.2	ppb	2.0	20 ppb	11/09/16 16:52
6288037-10	Sample Name: MP11-BUB Sampled: 10/13/16 4:12		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52
6288037-11	Sample Name: MP12-BUB Sampled: 10/13/16 4:13		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/14/2016
Received: 10/14/2016
Sampled By: Troy Thompson
Work Order: 6288037


**C
L
I
E
N
T**
David Douglas School District
Attn: Troy Thompson
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: Mill Park

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
6288037-12	Sample Name: MP13-F Sampled: 10/13/16 4:14							Matrix: Water
†Lead	1030	EPA 200.9	4.7	ppb	2.0	20 ppb	11/09/16 16:52	
6288037-13	Sample Name: MP14-F Sampled: 10/13/16 4:16							Matrix: Water
†Lead	1030	EPA 200.9	13.9	ppb	2.0	20 ppb	11/09/16 16:52	
6288037-14	Sample Name: MP15-B Sampled: 10/13/16 4:16							Matrix: Water
†Lead	1030	EPA 200.9	4.5	ppb	2.0	20 ppb	11/09/16 16:52	
6288037-15	Sample Name: MP16-F Sampled: 10/13/16 4:17							Matrix: Water
†Lead	1030	EPA 200.9	3.5	ppb	2.0	20 ppb	11/09/16 16:52	
6288037-16	Sample Name: MP17-B Sampled: 10/13/16 4:19							Matrix: Water
†Lead	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	11/09/16 16:52	
6288037-17	Sample Name: MP18-F Sampled: 10/13/16 4:19							Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52	
6288037-18	Sample Name: MP19-B Sampled: 10/13/16 4:21							Matrix: Water
†Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	11/09/16 16:52	
6288037-19	Sample Name: MP20-F Sampled: 10/13/16 4:21							Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52	
6288037-20	Sample Name: MP21-B Sampled: 10/13/16 4:22							Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52	
6288037-21	Sample Name: MP22-F Sampled: 10/13/16 4:22							Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52	



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/14/2016
Received: 10/14/2016
Sampled By: Troy Thompson
Work Order: 6288037

**C
L
I
E
N
T**
David Douglas School District
Attn: Troy Thompson
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: Mill Park

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6288037-22	Sample Name: MP23-B Sampled: 10/13/16 4:23		Matrix: Water				
+Lead	1030	EPA 200.9	2.7	ppb	2.0	20 ppb	11/09/16 16:52
6288037-23	Sample Name: MP24-F Sampled: 10/13/16 4:23		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52
6288037-24	Sample Name: MP25-B Sampled: 10/13/16 4:23		Matrix: Water				
+Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	11/09/16 16:52
6288037-25	Sample Name: MP26-F Sampled: 10/13/16 4:23		Matrix: Water				
+Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	11/09/16 16:52
6288037-26	Sample Name: MP27-B Sampled: 10/13/16 4:24		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52
6288037-27	Sample Name: MP28-F Sampled: 10/13/16 4:24		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52
6288037-28	Sample Name: MP29-B Sampled: 10/13/16 4:25		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52
6288037-29	Sample Name: MP30-F Sampled: 10/13/16 4:25		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52
6288037-30	Sample Name: MP31-B Sampled: 10/13/16 4:26		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52
6288037-31	Sample Name: MP32-F Sampled: 10/13/16 4:26		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/14/2016
Received: 10/14/2016
Sampled By: Troy Thompson
Work Order: 6288037

**C
L
I
E
N
T** **David Douglas School District**
Attn: Troy Thompson
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: Mill Park

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6288037-32	Sample Name: MP33-B Sampled: 10/13/16 4:27		Matrix: Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52
6288037-33	Sample Name: MP34-F Sampled: 10/13/16 4:27		Matrix: Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52
6288037-34	Sample Name: MP35-B Sampled: 10/13/16 4:28		Matrix: Water				
†Lead	1030	EPA 200.9	3.4	ppb	2.0	20 ppb	11/09/16 16:52
6288037-35	Sample Name: MP36-F Sampled: 10/13/16 4:28		Matrix: Water				
†Lead	1030	EPA 200.9	2.7	ppb	2.0	20 ppb	11/09/16 16:52
6288037-36	Sample Name: MP37-B Sampled: 10/13/16 4:30		Matrix: Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/09/16 16:52
6288037-37	Sample Name: MP38-F Sampled: 10/13/16 4:30		Matrix: Water				
†Lead	1030	EPA 200.9	5.3	ppb	2.0	20 ppb	11/09/16 16:52
6288037-38	Sample Name: MP39-B Sampled: 10/13/16 4:32		Matrix: Water				
†Lead	1030	EPA 200.9	3.8	ppb	2.0	20 ppb	11/09/16 16:52
6288037-39	Sample Name: MP40-F Sampled: 10/13/16 4:33		Matrix: Water				
†Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	11/09/16 16:52
6288037-40	Sample Name: MP41-B Sampled: 10/13/16 4:35		Matrix: Water				
†Lead	1030	EPA 200.9	4.2	ppb	2.0	20 ppb	11/09/16 16:52
6288037-41	Sample Name: MP42-F Sampled: 10/13/16 4:35		Matrix: Water				
†Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	11/11/16 15:30



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/14/2016
Received: 10/14/2016
Sampled By: Troy Thompson
Work Order: 6288037

**C
L
I
E
N
T**
David Douglas School District
Attn: Troy Thompson
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: Mill Park

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6288037-42	Sample Name: MP43 - Bradley Sampled: 10/13/16 4:36		Matrix: Water				
+Lead	1030	EPA 200.9	5.6	ppb	2.0	20 ppb	11/11/16 15:30
6288037-43	Sample Name: MP44-Bradley Sampled: 10/13/16 4:37		Matrix: Water				
+Lead	1030	EPA 200.9	5.3	ppb	2.0	20 ppb	11/11/16 15:30
6288037-44	Sample Name: MP45-F Sampled: 10/13/16 4:39		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/11/16 15:30
6288037-45	Sample Name: MP46-F Sampled: 10/13/16 4:40		Matrix: Water				
+Lead	1030	EPA 200.9	4.6	ppb	2.0	20 ppb	11/11/16 15:30
6288037-46	Sample Name: MP47-F Sampled: 10/13/16 4:40		Matrix: Water				
+Lead	1030	EPA 200.9	41.8	ppb	4.0	20 ppb	11/11/16 15:30 MCL
6288037-47	Sample Name: MP48-F Sampled: 10/13/16 4:44		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/11/16 15:30
6288037-48	Sample Name: MP49-F Sampled: 10/13/16 4:44		Matrix: Water				
+Lead	1030	EPA 200.9	14.5	ppb	2.0	20 ppb	11/11/16 15:30
6288037-49	Sample Name: MP50-B Sampled: 10/13/16 4:45		Matrix: Water				
+Lead	1030	EPA 200.9	6.3	ppb	2.0	20 ppb	11/11/16 15:30
6288037-50	Sample Name: 51-F Sampled: 10/13/16 4:46		Matrix: Water				
+Lead	1030	EPA 200.9	4.2	ppb	2.0	20 ppb	11/11/16 15:30
6288037-51	Sample Name: 77-Bub Sampled: 10/13/16 4:46		Matrix: Water				
+Lead	1030	EPA 200.9	4.8	ppb	2.0	20 ppb	11/11/16 15:30



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/14/2016
Received: 10/14/2016
Sampled By: Troy Thompson
Work Order: 6288037


C David Douglas School District
L Attn: Troy Thompson
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Mill Park

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6288037-52	Sample Name: 52-F Sampled: 10/13/16 4:47		Matrix: Water				
†Lead	1030	EPA 200.9	10.7	ppb	2.0	20 ppb	11/11/16 15:30
6288037-53	Sample Name: 53-B Sampled: 10/13/16 4:47		Matrix: Water				
†Lead	1030	EPA 200.9	5.1	ppb	2.0	20 ppb	11/11/16 15:30
6288037-54	Sample Name: 54-F Sampled: 10/13/16 4:47		Matrix: Water				
†Lead	1030	EPA 200.9	8.0	ppb	2.0	20 ppb	11/11/16 15:30
6288037-55	Sample Name: 55-B Sampled: 10/13/16 4:48		Matrix: Water				
†Lead	1030	EPA 200.9	5.7	ppb	2.0	20 ppb	11/11/16 15:30
6288037-56	Sample Name: 56-F Sampled: 10/13/16 4:48		Matrix: Water				
†Lead	1030	EPA 200.9	4.9	ppb	2.0	20 ppb	11/11/16 15:30
6288037-57	Sample Name: 57-B Sampled: 10/13/16 4:52		Matrix: Water				
†Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	11/11/16 15:30
6288037-58	Sample Name: 58-F Sampled: 10/13/16 4:52		Matrix: Water				
†Lead	1030	EPA 200.9	4.7	ppb	2.0	20 ppb	11/11/16 15:30
6288037-59	Sample Name: 59-B Sampled: 10/13/16 4:57		Matrix: Water				
†Lead	1030	EPA 200.9	2.7	ppb	2.0	20 ppb	11/11/16 15:30
6288037-60	Sample Name: MP60-F Sampled: 10/13/16 5:04		Matrix: Water				
†Lead	1030	EPA 200.9	3.5	ppb	2.0	20 ppb	11/11/16 15:30
6288037-61	Sample Name: MP61-B Sampled: 10/13/16 5:05		Matrix: Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/11/16 15:30



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013


Reported: 11/14/2016
Received: 10/14/2016
Sampled By: Troy Thompson
Work Order: 6288037

**C
L
I
E
N
T**
David Douglas School District
Attn: Troy Thompson
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: Mill Park

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6288037-62	Sample Name: MP62-F Sampled: 10/13/16 5:05		Matrix: Water				
+Lead	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	11/11/16 15:30
6288037-63	Sample Name: MP63-B Sampled: 10/13/16 5:05		Matrix: Water				
+Lead	1030	EPA 200.9	3.4	ppb	2.0	20 ppb	11/11/16 15:30
6288037-64	Sample Name: MP64-F Sampled: 10/13/16 5:06		Matrix: Water				
+Lead	1030	EPA 200.9	5.5	ppb	2.0	20 ppb	11/11/16 15:30
6288037-65	Sample Name: MP65-B Sampled: 10/13/16 5:06		Matrix: Water				
+Lead	1030	EPA 200.9	2.5	ppb	2.0	20 ppb	11/11/16 15:30
6288037-66	Sample Name: MP66-F Sampled: 10/13/16 5:06		Matrix: Water				
+Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	11/11/16 15:30
6288037-67	Sample Name: MP67-B Sampled: 10/13/16 5:07		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/11/16 15:30
6288037-68	Sample Name: MP68-F Sampled: 10/13/16 5:07		Matrix: Water				
+Lead	1030	EPA 200.9	3.5	ppb	2.0	20 ppb	11/11/16 15:30
6288037-69	Sample Name: MP69-B Sampled: 10/13/16 5:07		Matrix: Water				
+Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	11/11/16 15:30
6288037-70	Sample Name: MP70-F Sampled: 10/13/16 5:07		Matrix: Water				
+Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	11/11/16 15:30
6288037-71	Sample Name: MP71-B Sampled: 10/13/16 5:08		Matrix: Water				
+Lead	1030	EPA 200.9	3.8	ppb	2.0	20 ppb	11/11/16 15:30



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/14/2016
Received: 10/14/2016
Sampled By: Troy Thompson
Work Order: 6288037

C David Douglas School District
L Attn: Troy Thompson
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Mill Park

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6288037-72	Sample Name: MP72-F Sampled: 10/13/16 5:08		Matrix: Water				
†Lead	1030	EPA 200.9	3.9	ppb	2.0	20 ppb	11/11/16 15:30
6288037-73	Sample Name: MP73-Bradley Sampled: 10/13/16 5:09		Matrix: Water				
†Lead	1030	EPA 200.9	10.9	ppb	2.0	20 ppb	11/11/16 15:30
6288037-74	Sample Name: MP74-Bradley Sampled: 10/13/16 5:09		Matrix: Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/11/16 15:30
6288037-75	Sample Name: MP75-B Sampled: 10/13/16 5:10		Matrix: Water				
†Lead	1030	EPA 200.9	2.2	ppb	2.0	20 ppb	11/11/16 15:30
6288037-76	Sample Name: MP76-F Sampled: 10/13/16 5:10		Matrix: Water				
†Lead	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	11/11/16 15:30

MCL This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director