



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/14/2016
Received: 10/20/2016
Sampled By: Troy Thompson
Work Order: 6298015

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: North High School Social Studies Bldg

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298015-01	Sample Name: SS01-Bradley Sampled: 10/18/16 4:50		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59
6298015-02	Sample Name: SS02-Bradley Sampled: 10/18/16 4:50		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59
6298015-03	Sample Name: SS03-DF Sampled: 10/18/16 4:52		Matrix: Water				
+Lead	1030	EPA 200.9	45.1	ppb	4.0	20 ppb	12/12/16 15:59 MCLE
6298015-04	Sample Name: SS04-DF Sampled: 10/18/16 4:52		Matrix: Water				
+Lead	1030	EPA 200.9	19.3	ppb	2.0	20 ppb	12/12/16 15:59
6298015-05	Sample Name: SS05-F Sampled: 10/18/16 4:53		Matrix: Water				
+Lead	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	12/12/16 15:59
6298015-06	Sample Name: SS06-F Sampled: 10/18/16 4:54		Matrix: Water				
+Lead	1030	EPA 200.9	3.5	ppb	2.0	20 ppb	12/12/16 15:59
6298015-07	Sample Name: SS07-F Sampled: 10/18/16 4:54		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59
6298015-08	Sample Name: SS08-F Sampled: 10/18/16 4:56		Matrix: Water				
+Lead	1030	EPA 200.9	3.4	ppb	2.0	20 ppb	12/12/16 15:59
6298015-09	Sample Name: SS09-Bradley Sampled: 10/18/16 4:57		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59
6298015-10	Sample Name: SS10-Bradley Sampled: 10/18/16 4:57		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/14/2016
Received: 10/20/2016
Sampled By: Troy Thompson
Work Order: 6298015

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: North High School Social Studies Bldg

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298015-11	Sample Name: SS11-DF						Matrix: Water
	Sampled: 10/18/16 5:00						
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59
6298015-12	Sample Name: SS12-DF						Matrix: Water
	Sampled: 10/18/16 5:01						
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59

MCL This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director