



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/30/2017
Received: 01/23/2017
Sampled By: Troy Thompson
Work Order: 7023017

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: North Powellhurst

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7023017-01	Sample Name: NP 6DF Sampled: 1/6/17 6:57		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/27/17 16:16
7023017-02	Sample Name: NP 7DF Sampled: 1/6/17 6:57		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/27/17 16:16
7023017-03	Sample Name: NP 38F Retest Sampled: 1/6/17 6:50		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/27/17 16:16
7023017-04	Sample Name: NP 40F Retest Sampled: 1/6/17 6:51		Matrix: Water				
+Lead	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	01/27/17 16:16
7023017-05	Sample Name: NP 47F Retest Sampled: 1/6/17 6:49		Matrix: Water				
+Lead	1030	EPA 200.9	3.9	ppb	2.0	20 ppb	01/27/17 16:16

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:

Adriana Gonzalez-Gray
Laboratory Director