



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 11/08/2016  
Received: 10/17/2016  
Sampled By: Troy Thompson  
Work Order: 6291008

**C  
L  
I  
E  
N  
T**  
**David Douglas School District**  
Attn: -  
11300 NE Halsey St  
Portland OR, 97220  
Phone: (503) 252-2900

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: North Powelhurst

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6291008-01</b>	<b>Sample Name:</b> NP1 F <b>Sampled:</b> 10/15/16 7:14		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-02</b>	<b>Sample Name:</b> NP2 F <b>Sampled:</b> 10/15/16 7:13		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-03</b>	<b>Sample Name:</b> NP3 F <b>Sampled:</b> 10/15/16 7:13		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-04</b>	<b>Sample Name:</b> NP 5 Sprayer <b>Sampled:</b> 10/15/16 7:15		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.9	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-05</b>	<b>Sample Name:</b> NP7 B <b>Sampled:</b> 10/15/16 7:16		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-06</b>	<b>Sample Name:</b> NP8 B <b>Sampled:</b> 10/15/16 7:17		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	6.7	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-07</b>	<b>Sample Name:</b> NP9 F <b>Sampled:</b> 10/15/16 7:17		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.6	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-08</b>	<b>Sample Name:</b> NP10 B <b>Sampled:</b> 10/15/16 7:18		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-09</b>	<b>Sample Name:</b> NP11 B <b>Sampled:</b> 10/15/16 7:18		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-10</b>	<b>Sample Name:</b> NP12 F <b>Sampled:</b> 10/15/16 7:19		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	11/04/16 16:43



**Professional  
Laboratory  
Services**

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

Reported: 11/08/2016  
Received: 10/17/2016  
Sampled By: Troy Thompson  
Work Order: 6291008


**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: North Powelhurst

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6291008-11</b>	<b>Sample Name:</b> NP13 B <b>Sampled:</b> 10/15/16 7:19		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-12</b>	<b>Sample Name:</b> NP14 F <b>Sampled:</b> 10/15/16 7:20		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.5	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-13</b>	<b>Sample Name:</b> NP15 B <b>Sampled:</b> 10/15/16 7:20		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	6.3	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-14</b>	<b>Sample Name:</b> NP16 F <b>Sampled:</b> 10/15/16 7:21		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	5.7	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-15</b>	<b>Sample Name:</b> NP17 B <b>Sampled:</b> 10/15/16 7:21		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-16</b>	<b>Sample Name:</b> NP18 F <b>Sampled:</b> 10/15/16 7:22		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7.3	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-17</b>	<b>Sample Name:</b> NP19 B <b>Sampled:</b> 10/15/16 7:22		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.2	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-18</b>	<b>Sample Name:</b> NP20 F <b>Sampled:</b> 10/15/16 7:23		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-19</b>	<b>Sample Name:</b> NP21 Bradley <b>Sampled:</b> 10/15/16 7:23		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-20</b>	<b>Sample Name:</b> NP24 F <b>Sampled:</b> 10/15/16 7:25		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/04/16 16:43



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 11/08/2016  
Received: 10/17/2016  
Sampled By: Troy Thompson  
Work Order: 6291008


**C**  
**L**  
**I**  
**E**  
**N**  
**T**  
**David Douglas School District**  
Attn: -  
11300 NE Halsey St  
Portland OR, 97220  
Phone: (503) 252-2900

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: North Powelhurst

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6291008-21</b>	<b>Sample Name:</b> NP25 Bradley <b>Sampled:</b> 10/15/16 7:25		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-22</b>	<b>Sample Name:</b> NP28 F <b>Sampled:</b> 10/15/16 7:29		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-23</b>	<b>Sample Name:</b> NP29 B <b>Sampled:</b> 10/15/16 7:29		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-24</b>	<b>Sample Name:</b> NP30 <b>Sampled:</b> 10/15/16 7:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-25</b>	<b>Sample Name:</b> NP31 B <b>Sampled:</b> 10/15/16 7:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-26</b>	<b>Sample Name:</b> NP32 F <b>Sampled:</b> 10/15/16 7:31		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.8	ppb	2.0	20 ppb	11/04/16 16:43
<b>6291008-27</b>	<b>Sample Name:</b> NP33 B <b>Sampled:</b> 10/15/16 7:31		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-28</b>	<b>Sample Name:</b> NP34 F <b>Sampled:</b> 10/15/16 7:32		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.0	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-29</b>	<b>Sample Name:</b> NP35 B <b>Sampled:</b> 10/15/16 7:32		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-30</b>	<b>Sample Name:</b> NP38 F <b>Sampled:</b> 10/15/16 7:36		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	<b>66.5</b>	ppb	4.0	20 ppb	11/07/16 09:00 <b>MCL</b>



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

## ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/08/2016  
Received: 10/17/2016  
Sampled By: Troy Thompson  
Work Order: 6291008


**C  
L  
I  
E  
N  
T**  
**David Douglas School District**  
Attn: -  
11300 NE Halsey St  
Portland OR, 97220  
Phone: (503) 252-2900

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: North Powelhurst

### Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6291008-31</b>	<b>Sample Name:</b> NP39 B <b>Sampled:</b> 10/15/16 7:36		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7.0	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-32</b>	<b>Sample Name:</b> NP40 F <b>Sampled:</b> 10/15/16 7:37		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	16.7	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-33</b>	<b>Sample Name:</b> NP41 F <b>Sampled:</b> 10/15/16 7:39		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-34</b>	<b>Sample Name:</b> NP42 B <b>Sampled:</b> 10/15/16 7:39		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-35</b>	<b>Sample Name:</b> NP43 F <b>Sampled:</b> 10/15/16 7:40		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.6	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-36</b>	<b>Sample Name:</b> NP44 F <b>Sampled:</b> 10/15/16 7:41		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.7	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-37</b>	<b>Sample Name:</b> NP45 DF <b>Sampled:</b> 10/15/16 7:42		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-38</b>	<b>Sample Name:</b> NP46 DF <b>Sampled:</b> 10/15/16 7:42		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.9	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-39</b>	<b>Sample Name:</b> NP47 F <b>Sampled:</b> 10/15/16 7:43		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	<b>21.0</b>	ppb	2.0	20 ppb	11/07/16 09:00 <b>MCLE</b>
<b>6291008-40</b>	<b>Sample Name:</b> NP49 Bradley <b>Sampled:</b> 10/15/16 7:44		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/07/16 09:00



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 11/08/2016  
Received: 10/17/2016  
Sampled By: Troy Thompson  
Work Order: 6291008


**C** **David Douglas School District**  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: North Powelhurst

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6291008-41</b>	<b>Sample Name:</b> NP51F <b>Sampled:</b> 10/15/16 7:50		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-42</b>	<b>Sample Name:</b> NP52 F <b>Sampled:</b> 10/15/16 7:51		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-43</b>	<b>Sample Name:</b> NP53 F <b>Sampled:</b> 10/15/16 7:52		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	5.5	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-44</b>	<b>Sample Name:</b> NP54 F <b>Sampled:</b> 10/15/16 7:52		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.8	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-45</b>	<b>Sample Name:</b> NP55 F <b>Sampled:</b> 10/15/16 7:53		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-46</b>	<b>Sample Name:</b> NP56 F <b>Sampled:</b> 10/15/16 7:55		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-47</b>	<b>Sample Name:</b> NP57 F <b>Sampled:</b> 10/15/16 7:55		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-48</b>	<b>Sample Name:</b> NP58 DF <b>Sampled:</b> 10/15/16 7:56		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7.1	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-49</b>	<b>Sample Name:</b> NP60 F <b>Sampled:</b> 10/15/16 7:58		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-50</b>	<b>Sample Name:</b> NP61 F <b>Sampled:</b> 10/15/16 7:59		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8.7	ppb	2.0	20 ppb	11/07/16 09:00



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 11/08/2016  
Received: 10/17/2016  
Sampled By: Troy Thompson  
Work Order: 6291008

**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: North Powelhurst

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6291008-51</b>	<b>Sample Name:</b> NP62 F <b>Sampled:</b> 10/15/16 7:56		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	11.6	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-52</b>	<b>Sample Name:</b> NP63 Bradley <b>Sampled:</b> 10/15/16 8:00		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	6.6	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-53</b>	<b>Sample Name:</b> NP64 F <b>Sampled:</b> 10/15/16 8:02		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-54</b>	<b>Sample Name:</b> NP65 F <b>Sampled:</b> 10/15/16 8:03		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-55</b>	<b>Sample Name:</b> NP66 Bradley <b>Sampled:</b> 10/15/16 8:04		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	4.0	ppb	2.0	20 ppb	11/07/16 09:00
<b>6291008-56</b>	<b>Sample Name:</b> NP67 F <b>Sampled:</b> 10/15/16 7:53		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	8.7	ppb	2.0	20 ppb	11/07/16 09:00

**MCLE** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director