



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/19/2016
Received: 10/20/2016
Sampled By: Troy Thompson
Work Order: 6298019

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Aquatics Center

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
6298019-01	Sample Name: AC1 F Sampled: 10/18/16 4:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59	
6298019-02	Sample Name: AC2 DF Sampled: 10/18/16 4:01							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59	
6298019-03	Sample Name: AC3 F Sampled: 10/18/16 4:01							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59	
6298019-04	Sample Name: AC4 F Sampled: 10/18/16 4:03							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59	
6298019-05	Sample Name: AC5 F Sampled: 10/18/16 4:04							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59	
6298019-06	Sample Name: AC6 F Sampled: 10/18/16 4:04							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59	
6298019-07	Sample Name: AC7 F Sampled: 10/18/16 4:05							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59	
6298019-08	Sample Name: AC8 F Sampled: 10/18/16 4:05							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59	
6298019-09	Sample Name: AC9 F Sampled: 10/18/16 4:06							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59	
6298019-10	Sample Name: AC10 F Sampled: 10/18/16 4:06							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59	



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/19/2016
Received: 10/20/2016
Sampled By: Troy Thompson
Work Order: 6298019

**C
L
I
E
N
T** **David Douglas School District**
Attn: -
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: Aquatics Center


Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298019-11	Sample Name: AC11 F Sampled: 10/18/16 4:06		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6298019-12	Sample Name: AC12 F Sampled: 10/18/16 4:07		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6298019-13	Sample Name: AC13 DF Sampled: 10/18/16 4:07		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director