



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/13/2017  
Received: 10/24/2016  
Sampled By: Troy Thompson  
Work Order: 6298028


**C** **David Douglas School District**  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: South High School (SHS)

## Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6298028-01</b>	<b>Sample Name:</b> SHS1 F <b>Sampled:</b> 10/22/16 6:16		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
<b>6298028-02</b>	<b>Sample Name:</b> SHS2 F <b>Sampled:</b> 10/22/16 6:16		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
<b>6298028-03</b>	<b>Sample Name:</b> SHS3 Sprayer <b>Sampled:</b> 10/22/16 6:17		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
<b>6298028-04</b>	<b>Sample Name:</b> SHS6 F <b>Sampled:</b> 10/22/16 6:18		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	19.4	ppb	2.0	20 ppb	12/16/16 16:39
<b>6298028-05</b>	<b>Sample Name:</b> SHS7 Sprayer <b>Sampled:</b> 10/22/16 6:18		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	12/02/16 16:04
<b>6298028-06</b>	<b>Sample Name:</b> SHS8 F <b>Sampled:</b> 10/22/16 6:21		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	12/02/16 16:04
<b>6298028-07</b>	<b>Sample Name:</b> SHS11 F <b>Sampled:</b> 10/22/16 6:23		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	5.4	ppb	2.0	20 ppb	12/02/16 16:04
<b>6298028-08</b>	<b>Sample Name:</b> SHS12 F <b>Sampled:</b> 10/22/16 6:23		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7.9	ppb	2.0	20 ppb	12/02/16 16:04
<b>6298028-09</b>	<b>Sample Name:</b> SHS13 Bradley <b>Sampled:</b> 10/22/16 6:25		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	15.2	ppb	2.0	20 ppb	12/02/16 16:04
<b>6298028-10</b>	<b>Sample Name:</b> SHS14 Bradley <b>Sampled:</b> 10/22/16 6:25		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.9	ppb	2.0	20 ppb	12/02/16 16:04



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/13/2017  
Received: 10/24/2016  
Sampled By: Troy Thompson  
Work Order: 6298028

**C** **David Douglas School District**  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: South High School (SHS)

## Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6298028-11</b>	<b>Sample Name:</b> SHS15 F <b>Sampled:</b> 10/22/16 6:28		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	5.6	ppb	2.0	20 ppb	12/02/16 16:04
<b>6298028-12</b>	<b>Sample Name:</b> SHS16 F <b>Sampled:</b> 10/22/16 6:29		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	12/02/16 16:04
<b>6298028-13</b>	<b>Sample Name:</b> SHS17 Bradley <b>Sampled:</b> 10/22/16 6:30		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	8.1	ppb	2.0	20 ppb	01/06/17 17:02
<b>6298028-14</b>	<b>Sample Name:</b> SHS18 F <b>Sampled:</b> 10/22/16 6:31		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	7.6	ppb	2.0	20 ppb	12/02/16 15:50
<b>6298028-15</b>	<b>Sample Name:</b> SHS19 DF <b>Sampled:</b> 10/22/16 6:33		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
<b>6298028-16</b>	<b>Sample Name:</b> SHS20 F <b>Sampled:</b> 10/22/16 6:35		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	6.1	ppb	2.0	20 ppb	12/02/16 15:50
<b>6298028-17</b>	<b>Sample Name:</b> SHS21 F <b>Sampled:</b> 10/22/16 6:35		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	12/02/16 15:50
<b>6298028-18</b>	<b>Sample Name:</b> SHS22 F <b>Sampled:</b> 10/22/16 6:36		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
<b>6298028-19</b>	<b>Sample Name:</b> SHS23 F <b>Sampled:</b> 10/22/16 6:36		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	4.0	ppb	2.0	20 ppb	12/02/16 15:50
<b>6298028-20</b>	<b>Sample Name:</b> SHS24 F <b>Sampled:</b> 10/22/16 6:37		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	8.1	ppb	2.0	20 ppb	01/06/17 17:02



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/13/2017  
Received: 10/24/2016  
Sampled By: Troy Thompson  
Work Order: 6298028


**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: South High School (SHS)

## Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6298028-21</b>	<b>Sample Name:</b> SHS25 F <b>Sampled:</b> 10/22/16 6:37		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/06/17 17:02
<b>6298028-22</b>	<b>Sample Name:</b> SHS26 Ice Maker <b>Sampled:</b> 10/22/16 6:39		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/06/17 17:02
<b>6298028-23</b>	<b>Sample Name:</b> SHS27 F <b>Sampled:</b> 10/22/16 6:41		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/06/17 17:02
<b>6298028-24</b>	<b>Sample Name:</b> SHS28 F <b>Sampled:</b> 10/22/16 6:41		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	6.7	ppb	2.0	20 ppb	01/06/17 17:02
<b>6298028-25</b>	<b>Sample Name:</b> SHS29 Sprayer <b>Sampled:</b> 10/22/16 6:40		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.4	ppb	2.0	20 ppb	01/06/17 17:02
<b>6298028-26</b>	<b>Sample Name:</b> SHS30 F <b>Sampled:</b> 10/22/16 6:42		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	01/06/17 17:02
<b>6298028-27</b>	<b>Sample Name:</b> SHS31 F <b>Sampled:</b> 10/22/16 6:44		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8.9	ppb	2.0	20 ppb	01/06/17 17:02
<b>6298028-28</b>	<b>Sample Name:</b> SHS32 F <b>Sampled:</b> 10/22/16 6:44		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.5	ppb	2.0	20 ppb	01/06/17 17:02
<b>6298028-29</b>	<b>Sample Name:</b> SHS33 F <b>Sampled:</b> 10/22/16 6:43		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	<b>22.1</b>	ppb	2.0	20 ppb	01/06/17 17:02 <b>MCLE</b>
<b>6298028-30</b>	<b>Sample Name:</b> SHS34 Bradley <b>Sampled:</b> 10/22/16 6:45		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8.5	ppb	2.0	20 ppb	01/06/17 17:02



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 01/13/2017  
Received: 10/24/2016  
Sampled By: Troy Thompson  
Work Order: 6298028

**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: South High School (SHS)

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6298028-31</b>	<b>Sample Name:</b> SHS35 Bradley <b>Sampled:</b> 10/22/16 6:46		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	49.1	ppb	4.0	20 ppb	01/06/17 17:02 <b>MCLE</b>
<b>6298028-32</b>	<b>Sample Name:</b> SHS36 F <b>Sampled:</b> 10/22/16 6:47		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	141	ppb	8.0	20 ppb	01/10/17 16:19 <b>MCLE</b>
<b>6298028-33</b>	<b>Sample Name:</b> SHS37 F <b>Sampled:</b> 10/22/16 6:47		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.5	ppb	2.0	20 ppb	01/06/17 17:02
<b>6298028-34</b>	<b>Sample Name:</b> SHS38 F <b>Sampled:</b> 10/22/16 6:49		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/06/17 17:02
<b>6298028-35</b>	<b>Sample Name:</b> SHS39 F <b>Sampled:</b> 10/22/16 6:50		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/06/17 17:02
<b>6298028-36</b>	<b>Sample Name:</b> SHS40 F <b>Sampled:</b> 10/22/16 6:50		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/06/17 17:02

**MCLE** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL      **MRL** = Minimum Reporting Limit      **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: \_\_\_\_\_

Adriana Gonzalez-Gray  
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.