



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 03/23/2017
Received: 03/10/2017
Sampled By: Troy Thompson
Work Order: 7069010

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: SHS

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7069010-01	Sample Name: SHS 101F Retest		Matrix: Water				
	Sampled: 3/10/17 6:30						
+Lead	1030	EPA 200.9	7.5	ppb	2.0	20 ppb	03/21/17 17:11
7069010-02	Sample Name: SHS 109F Retest		Matrix: Water				
	Sampled: 3/10/17 6:34						
+Lead	1030	EPA 200.9	3.8	ppb	2.0	20 ppb	03/21/17 17:11

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:

Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.

