


**DAVID DOUGLAS SCHOOL DISTRICT
LEAD TESTING RESULTS BY SCHOOL**

6/6/2016 3:59 PM

Classroom/Location	Analysis Report Date	Work Order #	1st Draw	1 Min Draw	Action Taken
			Test #1 mg/L	Test #2 mg/L	
SOUTH POWELLHURST OFFICES					
Lobby	1/7/2014	3358001	nd	nd	none
Staff	1/7/2014	3358001	nd	nd	none
SLIP	1/7/2014	3358001	nd	nd	none
CTP	1/7/2014	3358001	nd	nd	none
Bus Cafeteria	1/7/2014	3358001	nd	nd	none
Boys Restroom	1/7/2014	3358001	0.0080	0.0030	none
Girls Restroom	1/7/2014	3358001	nd	nd	none
MNT	1/7/2014	3358001	nd	nd	none
PIT	1/7/2014	3358001	0.0030	0.0020	none

ND - NONE DETECTED

ITEMS IN RED ARE OVER THE 20 PPB EPA RECOMMENDATION FOR REPLACEMENT



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/07/2014
Received: 12/24/2013
Sampled By: Faye Bayer
Work Order: 3358001

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project #: N/A
PWSID #: -
PO #: 141528


Sampling Location: South Powellhurst
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 12/24/13 7:43		Sample Composition:				
3358001-01	SPLOBBYA							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	12/27/13 14:00

Lab Number	Sample Name	Sampled: 12/24/13 7:44		Sample Composition:				
3358001-02	SPLOBBYB							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	12/27/13 14:00

Lab Number	Sample Name	Sampled: 12/24/13 7:38		Sample Composition:				
3358001-03	SPSTAFFA							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	12/27/13 14:00

Lab Number	Sample Name	Sampled: 12/24/13 7:39		Sample Composition:				
3358001-04	SPSTAFFB							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	12/27/13 14:00



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 01/07/2014
Received: 12/24/2013
Sampled By: Faye Bayer
Work Order: 3358001

**C
L
I
E
N
T**
David Douglas School District
Attn: David Callaway
2900 SE 122nd
Portland OR, 97236
Phone: (503) 252-2900

Project: -
Project # : N/A
PWSID # : -
PO # : 141528


Sampling Location: South Powellhurst
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 12/23/13 14:08		Sample Composition:				
3358001-05	SPLIPA							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	12/27/13 14:00

Lab Number	Sample Name	Sampled: 12/23/13 14:09		Sample Composition:				
3358001-06	SPLIPB							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	12/27/13 14:00

Lab Number	Sample Name	Sampled: 12/23/13 14:01		Sample Composition:				
3358001-07	SPCTPA							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	12/27/13 14:00

Lab Number	Sample Name	Sampled: 12/23/13 14:02		Sample Composition:				
3358001-08	SPCTPB							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	12/27/13 14:00



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/07/2014
Received: 12/24/2013
Sampled By: Faye Bayer
Work Order: 3358001

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project #: N/A
PWSID #: -
PO #: 141528


Sampling Location: South Powellhurst
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 12/24/13 7:26		Sample Composition:				
3358001-09	SPBUSCAFEA							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	12/27/13 14:00

Lab Number	Sample Name	Sampled: 12/24/13 7:28		Sample Composition:				
3358001-10	SPBUSCAFEB							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	12/27/13 14:00

Lab Number	Sample Name	Sampled: 12/24/13 7:31		Sample Composition:				
3358001-11	SPBOYSA							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.008	0.002	0.015	-	12/27/13 14:00

Lab Number	Sample Name	Sampled: 12/24/13 7:33		Sample Composition:				
3358001-12	SPBOYSB							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	01/03/14 15:08



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/07/2014
Received: 12/24/2013
Sampled By: Faye Bayer
Work Order: 3358001

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project #: N/A
PWSID #: -
PO #: 141528

Sampling Location: South Powellhurst
Sample Matrix: Drinking Water

Lab Number 3358001-13 **Sample Name** SPGIRLSA **Sampled:** 12/24/13 7:34 **Sample Composition:**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	12/27/13 14:00

Lab Number 3358001-14 **Sample Name** SPGIRLSB **Sampled:** 12/24/13 7:36 **Sample Composition:**


Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	12/27/13 14:00

Lab Number 3358001-15 **Sample Name** SPMNTA **Sampled:** 12/23/13 14:33 **Sample Composition:**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	12/27/13 14:00

Lab Number 3358001-16 **Sample Name** SPMNTB **Sampled:** 12/23/13 14:35 **Sample Composition:**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	12/27/13 14:00



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/07/2014
Received: 12/24/2013
Sampled By: Faye Bayer
Work Order: 3358001

C David Douglas School District
L Attn: David Callaway
I 2900 SE 122nd
E Portland OR, 97236
N Phone: (503) 252-2900
T

Project: -
Project # : N/A
PWSID # : -
PO # : 141528

Sampling Location: South Powellhurst
Sample Matrix: Drinking Water


Lab Number **Sample Name** **Sampled:** 12/23/13 14:40 **Sample Composition:**
3358001-17 **SPITA**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	12/27/13 14:00

Lab Number **Sample Name** **Sampled:** 12/23/13 14:42 **Sample Composition:**
3358001-18 **SPITB**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
[†] Lead	1030	EPA 200.9	mg/L	0.002	0.002	0.015	-	12/27/13 14:00

ND = None detected MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit
†All procedures for this analysis conform to NELAC standards.

Approved by: 
Scott Dickman
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.