



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 03/03/2017  
Received: 02/24/2017  
Sampled By: Troy Thompson  
Work Order: 7055008

**C  
L  
I  
E  
N  
T** **David Douglas School District**  
Attn: -  
11300 NE Halsey St  
Portland OR, 97220  
Phone: (503) 252-2900

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Social Studies  
Sample Matrix: Water

**Lab Number**

Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>7055008-01</b>	<b>Sample Name:</b> SS DF Lower main line <b>Sampled:</b> 2/24/17 6:10					<b>Matrix:</b> Water
+Lead	1030 EPA 200.9	9.3	ppb	2.0	20 ppb	03/01/17 14:04

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: \_\_\_\_\_



Adriana Gonzalez-Gray  
Laboratory Director

*This report shall not be reproduced, except in full, without the written approval of the laboratory.*