



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/23/2017
Received: 11/18/2016
Sampled By: Troy Thompson
Work Order: 6323009

C **David Douglas School District**
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: South Powell

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6323009-01	Sample Name: SP 1 F Sampled: 11/18/16 5:05		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6323009-02	Sample Name: SP 2 F Sampled: 11/18/16 5:05		Matrix: Water				
+Lead	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	01/20/17 16:36
6323009-03	Sample Name: SP 3 F Sampled: 11/18/16 5:06		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6323009-04	Sample Name: SP 4 DF Sampled: 11/18/16 5:06		Matrix: Water				
+Lead	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	01/20/17 16:36
6323009-05	Sample Name: SP 5 DF Sampled: 11/18/16 5:06		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6323009-06	Sample Name: SP 6 F Sampled: 11/18/16 5:07		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6323009-07	Sample Name: SP 7 F Sampled: 11/18/16 5:10		Matrix: Water				
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	01/20/17 16:36
6323009-08	Sample Name: SP 8 F Sampled: 11/18/16 5:11		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6323009-09	Sample Name: SP 9 DF Sampled: 11/18/16 5:11		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6323009-10	Sample Name: SP 10 F Sampled: 11/18/16 5:12		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 01/23/2017
Received: 11/18/2016
Sampled By: Troy Thompson
Work Order: 6323009

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: South Powell

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6323009-11	Sample Name: SP 11 F Sampled: 11/18/16 5:13		Matrix: Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6323009-12	Sample Name: SP 12 F Sampled: 11/18/16 5:13		Matrix: Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6323009-13	Sample Name: SP 13 F Sampled: 11/18/16 5:13		Matrix: Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6323009-14	Sample Name: SP 14 F Sampled: 11/18/16 5:14		Matrix: Water				
†Lead	1030	EPA 200.9	2.5	ppb	2.0	20 ppb	01/20/17 16:36
6323009-15	Sample Name: SP 15 F Sampled: 11/18/16 5:14		Matrix: Water				
†Lead	1030	EPA 200.9	12.1	ppb	2.0	20 ppb	01/20/17 16:36
6323009-16	Sample Name: SP 16 F Sampled: 11/18/16 5:14		Matrix: Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6323009-17	Sample Name: SP 17 F Sampled: 11/18/16 5:15		Matrix: Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6323009-18	Sample Name: SP 29 F Sampled: 11/18/16 5:15		Matrix: Water				
†Lead	1030	EPA 200.9	34.8	ppb	2.0	20 ppb	01/20/17 16:36 MCLE
6323009-19	Sample Name: SP 18 DF Sampled: 11/18/16 5:16		Matrix: Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6323009-20	Sample Name: SP 19 F Sampled: 11/18/16 5:00		Matrix: Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/23/2017
Received: 11/18/2016
Sampled By: Troy Thompson
Work Order: 6323009

C
L
I
E
N
T

David Douglas School District
Attn: -
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: South Powell

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6323009-21	Sample Name: SP 20 F Sampled: 11/18/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6323009-22	Sample Name: SP 21 F Sampled: 11/18/16 4:45		Matrix: Water				
+Lead	1030	EPA 200.9	5.6	ppb	2.0	20 ppb	01/20/17 16:36
6323009-23	Sample Name: SP 22 F Sampled: 11/18/16 4:45		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6323009-24	Sample Name: SP 23 F Sampled: 11/18/16 4:45		Matrix: Water				
+Lead	1030	EPA 200.9	9.1	ppb	2.0	20 ppb	01/20/17 16:36
6323009-25	Sample Name: SP 24 F Sampled: 11/18/16 4:48		Matrix: Water				
+Lead	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	01/20/17 16:36
6323009-26	Sample Name: SP 25 F Sampled: 11/18/16 4:48		Matrix: Water				
+Lead	1030	EPA 200.9	9.0	ppb	2.0	20 ppb	01/20/17 16:36
6323009-27	Sample Name: SP 27 DF Sampled: 11/18/16 4:49		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6323009-28	Sample Name: SP 28 B Sampled: 11/18/16 4:49		Matrix: Water				
+Lead	1030	EPA 200.9	22.4	ppb	2.0	20 ppb	01/20/17 16:36 MCLE


MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL

MRL = Minimum Reporting Limit

MCL = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/23/2017
Received: 11/18/2016
Sampled By: Troy Thompson
Work Order: 6323009


C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N
T Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: South Powell

Lab Number

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director