

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/19/2017
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298032


C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: South High School (SHS)

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298032-01	Sample Name: SHS41 F Sampled: 10/22/16 6:51		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
6298032-02	Sample Name: SHS42 F Sampled: 10/22/16 6:51		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
6298032-03	Sample Name: SHS43 F Sampled: 10/22/16 6:52		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
6298032-04	Sample Name: SHS44 F Sampled: 10/22/16 6:52		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
6298032-05	Sample Name: SHS45 F Sampled: 10/22/16 6:54		Matrix: Water				
+Lead	1030	EPA 200.9	14.4	ppb	2.0	20 ppb	01/18/17 16:14
6298032-06	Sample Name: SHS46 F Sampled: 10/22/16 6:55		Matrix: Water				
+Lead	1030	EPA 200.9	22.2	ppb	2.0	20 ppb	01/18/17 16:14 MCLE
6298032-07	Sample Name: SHS47 B Sampled: 10/22/16 6:58		Matrix: Water				
+Lead	1030	EPA 200.9	6.9	ppb	2.0	20 ppb	01/18/17 16:14
6298032-08	Sample Name: SHS48 B Sampled: 10/22/16 6:58		Matrix: Water				
+Lead	1030	EPA 200.9	4.4	ppb	2.0	20 ppb	01/18/17 16:14
6298032-09	Sample Name: SHS49 F Sampled: 10/22/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	2.7	ppb	2.0	20 ppb	01/18/17 16:14
6298032-10	Sample Name: SHS50 F Sampled: 10/22/16 7:01		Matrix: Water				
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	01/18/17 16:14



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 01/19/2017
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298032


C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: South High School (SHS)

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298032-11	Sample Name: SHS51 F Sampled: 10/22/16 7:01		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
6298032-12	Sample Name: SHS52 F Sampled: 10/22/16 7:03		Matrix: Water				
+Lead	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	01/18/17 16:14
6298032-13	Sample Name: SHS53 F Sampled: 10/22/16 7:03		Matrix: Water				
+Lead	1030	EPA 200.9	5.1	ppb	2.0	20 ppb	01/18/17 16:14
6298032-14	Sample Name: SHS56 F Sampled: 10/22/16 7:04		Matrix: Water				
+Lead	1030	EPA 200.9	7.0	ppb	2.0	20 ppb	01/18/17 16:14
6298032-15	Sample Name: SHS57 F Sampled: 10/22/16 7:10		Matrix: Water				
+Lead	1030	EPA 200.9	13.8	ppb	2.0	20 ppb	01/18/17 16:14
6298032-16	Sample Name: SHS60 F Sampled: 10/22/16 7:13		Matrix: Water				
+Lead	1030	EPA 200.9	4.8	ppb	2.0	20 ppb	01/18/17 16:14
6298032-17	Sample Name: SHS61 Sprayer Sampled: 10/22/16 7:13		Matrix: Water				
+Lead	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	01/18/17 16:14
6298032-18	Sample Name: SHS62 F Sampled: 10/22/16 7:14		Matrix: Water				
+Lead	1030	EPA 200.9	8.5	ppb	2.0	20 ppb	01/10/17 16:19
6298032-19	Sample Name: SHS63 Sprayer Sampled: 10/22/16 7:14		Matrix: Water				
+Lead	1030	EPA 200.9	8.4	ppb	2.0	20 ppb	01/18/17 16:14
6298032-20	Sample Name: SHS66 F Sampled: 10/22/16 7:16		Matrix: Water				
+Lead	1030	EPA 200.9	19.0	ppb	2.0	20 ppb	01/18/17 16:14



13035 SW Pacific Hwy
 Tigard, OR 97223
 Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
 Laboratory
 Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/19/2017
 Received: 10/24/2016
 Sampled By: Troy Thompson
 Work Order: 6298032


C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
 Project # : N/A
 Sample Type :

Sampling Location: South High School (SHS)

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298032-21	Sample Name: SHS67 Sprayer Sampled: 10/22/16 7:16		Matrix: Water				
+Lead	1030	EPA 200.9	20.0	ppb	2.0	20 ppb	01/18/17 16:14
6298032-22	Sample Name: SHS68 F Sampled: 10/22/16 7:17		Matrix: Water				
+Lead	1030	EPA 200.9	44.7	ppb	4.0	20 ppb	01/18/17 16:14 MCLE
6298032-23	Sample Name: SHS69 Sprayer Sampled: 10/22/16 7:17		Matrix: Water				
+Lead	1030	EPA 200.9	59.2	ppb	4.0	20 ppb	01/18/17 16:14 MCLE
6298032-24	Sample Name: SHS70 F Sampled: 10/22/16 7:18		Matrix: Water				
+Lead	1030	EPA 200.9	6.6	ppb	2.0	20 ppb	01/18/17 16:14
6298032-25	Sample Name: SHS71 F Sampled: 10/22/16 7:19		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
6298032-26	Sample Name: SHS74 Bradley Sampled: 10/22/16 7:23		Matrix: Water				
+Lead	1030	EPA 200.9	7.2	ppb	2.0	20 ppb	01/18/17 16:14
6298032-27	Sample Name: SHS75 Bradley Sampled: 10/22/16 7:25		Matrix: Water				
+Lead	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	01/18/17 16:14
6298032-28	Sample Name: SHS77 F Sampled: 10/22/16 7:29		Matrix: Water				
+Lead	1030	EPA 200.9	40.0	ppb	4.0	20 ppb	01/18/17 16:14 MCLE
6298032-29	Sample Name: SHS78 F Sampled: 10/22/16 7:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14
6298032-30	Sample Name: SHS79 DF Sampled: 10/22/16 7:32		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 01/19/2017
Received: 10/24/2016
Sampled By: Troy Thompson
Work Order: 6298032

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: South High School (SHS)

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6298032-31	Sample Name: SHS80 DF		Matrix: Water				
	Sampled: 10/22/16 7:32						
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/18/17 16:14

MCL This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director