


**DAVID DOUGLAS SCHOOL DISTRICT  
LEAD TESTING RESULTS BY SCHOOL**

6/6/2016 3:59 PM

Classroom/Location	Analysis Report Date	Work Order #	1st Draw		1 Min Draw		Action Taken
			Test #1 mg/L	Test #2 mg/L	Test #1 mg/L	Test #2 mg/L	
<b>WEST POWELLHURST ELEMENTARY SCHOOL</b>							
Cafeteria 1	11/15/2013	3312010	0.0020	nd			none
Cafeteria 2	11/15/2013	3312010	nd	nd			none
Gym	11/15/2013	3312010	0.0030	nd			none
1	11/15/2013	3312010	0.0590		0.0070		Turned off
3	11/15/2013	3312010	0.0640		0.0130		Turned off
Hall 16	11/15/2013	3312010	0.0150		0.0130		none
Hall 17	11/15/2013	3312010	0.0120		0.0090		none
Hall 20	11/15/2013	3312010	nd	nd			none
Hall 21	11/15/2013	3312010	nd		0.0020		none
Hall 23	11/15/2013	3312010	0.0030		0.0030		none
Hall 24	11/15/2013	3312010	nd	nd			none
Hall 13	11/15/2013	3312010	0.0140		0.0090		none
Hall 9	11/15/2013	3312010	0.0020	nd			none
Hall 10	11/15/2013	3312010	0.0030		0.0030		none
Hall BR RA	11/15/2013	3312010	nd	nd			none
Hall 19	11/15/2013	3312010	nd	nd			none
Kitchen 1	11/15/2013	3312010	0.0040	nd			none
Kitchen 2	11/15/2013	3312010	0.0080	nd			none

ND - NONE DETECTED

ITEMS IN RED ARE OVER THE 20 PPB EPA RECOMMENDATION FOR REPLACEMENT



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 11/15/2013  
Received: 11/07/2013  
Sampled By: Faye Bayer  
Work Order: 3312010

**C** David Douglas School District  
**L** Attn: David Callaway  
**I** 2900 SE 122nd  
**E** Portland OR, 97236  
**N** Phone: (503) 252-2900  
**T**

**Project:** -  
Project #: N/A  
PWSID #: -  
PO #: 140989


Sampling Location: West Powellhurst  
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/30/13 7:59		Sample Composition:				
<b>3312010-01</b>	<b>WPCAFE1A</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	0.002	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/30/13 8:01		Sample Composition:				
<b>3312010-02</b>	<b>WPCAFE1B</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/30/13 8:02		Sample Composition:				
<b>3312010-03</b>	<b>WPCAFE2A</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/30/13 8:03		Sample Composition:				
<b>3312010-04</b>	<b>WPCAFE2B</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 11/15/2013  
Received: 11/07/2013  
Sampled By: Faye Bayer  
Work Order: 3312010

**C  
L  
I  
E  
N  
T**  
**David Douglas School District**  
Attn: David Callaway  
2900 SE 122nd  
Portland OR, 97236  
Phone: (503) 252-2900

**Project:** -  
Project # : N/A  
PWSID # : -  
PO # : 140989

Sampling Location: West Powellhurst  
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 11/1/13 6:10		Sample Composition:				
<b>3312010-05</b>	<b>WPGYMA</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	11/13/13 15:43

Lab Number	Sample Name	Sampled: 11/1/13 6:12		Sample Composition:				
<b>3312010-06</b>	<b>WPGYMB</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/13/13 15:43

Lab Number	Sample Name	Sampled: 11/1/13 6:15		Sample Composition:				
<b>3312010-07</b>	<b>WP1A</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	<b>0.059</b>	0.004	0.015	-	11/13/13 15:43 MCLE

Lab Number	Sample Name	Sampled: 11/1/13 6:16		Sample Composition:				
<b>3312010-08</b>	<b>WP1B</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.007	0.002	0.015	-	11/11/13 15:57



**Professional  
Laboratory  
Services**

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel: (503) 639-9311 Fax: (503) 684-1588

Reported: 11/15/2013  
Received: 11/07/2013  
Sampled By: Faye Bayer  
Work Order: 3312010

**C** David Douglas School District  
**L** Attn: David Callaway  
**I** 2900 SE 122nd  
**E** Portland OR, 97236  
**N** Phone: (503) 252-2900  
**T**

**Project:** -  
**Project # :** N/A  
**PWSID # :** -  
**PO # :** 140989


**Sampling Location:** West Powellhurst  
**Sample Matrix:** Drinking Water

Lab Number	Sample Name	Sampled: 11/1/13 6:19		Sample Composition:				
<b>3312010-09</b>	<b>WP3A</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	<b>0.064</b>	0.004	0.015	-	11/13/13 15:43 MCL

Lab Number	Sample Name	Sampled: 11/1/13 6:21		Sample Composition:				
<b>3312010-10</b>	<b>WP3B</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	0.013	0.002	0.015	-	11/13/13 15:43

Lab Number	Sample Name	Sampled: 10/30/13 8:41		Sample Composition:				
<b>3312010-11</b>	<b>WPHALL16A</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	0.015	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/30/13 8:42		Sample Composition:				
<b>3312010-12</b>	<b>WPHALL16B</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	0.013	0.002	0.015	-	11/11/13 15:57



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 11/15/2013  
Received: 11/07/2013  
Sampled By: Faye Bayer  
Work Order: 3312010

**C** David Douglas School District  
**L** Attn: David Callaway  
**I** 2900 SE 122nd  
**E** Portland OR, 97236  
**N** Phone: (503) 252-2900  
**T**

**Project:** -  
Project # : N/A  
PWSID # : -  
PO # : 140989


Sampling Location: West Powellhurst  
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/8/13 8:43		Sample Composition:				
<b>3312010-13</b>	<b>WPHALL17A</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	0.012	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/30/13 8:45		Sample Composition:				
<b>3312010-14</b>	<b>WPHALL17B</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	0.009	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/30/13 8:28		Sample Composition:				
<b>3312010-15</b>	<b>WPHALL20A</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/30/13 8:29		Sample Composition:				
<b>3312010-16</b>	<b>WPHALL20B</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 11/15/2013  
Received: 11/07/2013  
Sampled By: Faye Bayer  
Work Order: 3312010

**C** David Douglas School District  
**L** Attn: David Callaway  
**I** 2900 SE 122nd  
**E** Portland OR, 97236  
**N** Phone: (503) 252-2900  
**T**

**Project:** -  
Project #: N/A  
PWSID #: -  
PO #: 140989


Sampling Location: West Powellhurst  
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/30/13 8:30		Sample Composition:				
<b>3312010-17</b>	<b>WPHALL21A</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/11/13 15:57

Lab Number	Sample Name	Sampled: 10/30/13 8:31		Sample Composition:				
<b>3312010-18</b>	<b>WPHALL21B</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.002	0.002	0.015	-	11/13/13 15:43

Lab Number	Sample Name	Sampled: 10/30/13 8:34		Sample Composition:				
<b>3312010-19</b>	<b>WPHALL23A</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	11/13/13 15:43

Lab Number	Sample Name	Sampled: 10/30/13 8:35		Sample Composition:				
<b>3312010-20</b>	<b>WPHALL23B</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	11/13/13 15:43



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 11/15/2013  
Received: 11/07/2013  
Sampled By: Faye Bayer  
Work Order: 3312010

**C  
L  
I  
E  
N  
T**  
**David Douglas School District**  
Attn: David Callaway  
2900 SE 122nd  
Portland OR, 97236  
Phone: (503) 252-2900

**Project:** -  
Project # : N/A  
PWSID # : -  
PO # : 140989

Sampling Location: West Powellhurst  
Sample Matrix: Drinking Water

**Lab Number**      **Sample Name**      **Sampled:** 10/30/13 8:36      **Sample Composition:**  
**3312010-21**      **WPHALL24A**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/13/13 15:43

**Lab Number**      **Sample Name**      **Sampled:** 10/31/13 8:37      **Sample Composition:**  
**3312010-22**      **WPHALL24B**


Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/13/13 15:43

**Lab Number**      **Sample Name**      **Sampled:** 10/30/13 8:17      **Sample Composition:**  
**3312010-23**      **WPHALL13A**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	0.014	0.002	0.015	-	11/13/13 15:43

**Lab Number**      **Sample Name**      **Sampled:** 10/30/13 8:18      **Sample Composition:**  
**3312010-24**      **WPHALL13B**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	0.009	0.002	0.015	-	11/13/13 15:43



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 11/15/2013  
Received: 11/07/2013  
Sampled By: Faye Bayer  
Work Order: 3312010

**C** David Douglas School District  
**L** Attn: David Callaway  
**I** 2900 SE 122nd  
**E** Portland OR, 97236  
**N** Phone: (503) 252-2900  
**T**

**Project:** -  
**Project #:** N/A  
**PWSID #:** -  
**PO #:** 140989

**Sampling Location:** West Powellhurst  
**Sample Matrix:** Drinking Water


Lab Number	Sample Name	Sampled: 10/30/13 8:13		Sample Composition:				
<b>3312010-25</b>	<b>WPHALL9A</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	0.002	0.002	0.015	-	11/13/13 15:43

Lab Number	Sample Name	Sampled: 10/30/13 8:15		Sample Composition:				
<b>3312010-26</b>	<b>WPHALL9B</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/13/13 15:43

Lab Number	Sample Name	Sampled: 10/30/13 8:12		Sample Composition:				
<b>3312010-27</b>	<b>WPHALL10A</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	11/13/13 15:43

Lab Number	Sample Name	Sampled: 10/30/13 8:13		Sample Composition:				
<b>3312010-28</b>	<b>WPHALL10B</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	11/13/13 15:43





**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 11/15/2013  
Received: 11/07/2013  
Sampled By: Faye Bayer  
Work Order: 3312010

**C** David Douglas School District  
**L** Attn: David Callaway  
**I** 2900 SE 122nd  
**E** Portland OR, 97236  
**N** Phone: (503) 252-2900  
**T**

**Project:** -  
Project # : N/A  
PWSID # : -  
PO # : 140989


Sampling Location: West Powellhurst  
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/30/13 8:22		Sample Composition:				
<b>3312010-29</b>	<b>WPHALLBRRRA</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/13/13 15:43

Lab Number	Sample Name	Sampled: 10/30/13 8:24		Sample Composition:				
<b>3312010-30</b>	<b>WPHALLBRRB</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/13/13 15:43

Lab Number	Sample Name	Sampled: 11/1/13 6:04		Sample Composition:				
<b>3312010-31</b>	<b>WPHALL19A</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/13/13 15:43

Lab Number	Sample Name	Sampled: 11/1/13 6:05		Sample Composition:				
<b>3312010-32</b>	<b>WPHALL19B</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/13/13 15:43



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 11/15/2013  
Received: 11/07/2013  
Sampled By: Faye Bayer  
Work Order: 3312010

**C** David Douglas School District  
**L** Attn: David Callaway  
**I** 2900 SE 122nd  
**E** Portland OR, 97236  
**N** Phone: (503) 252-2900  
**T**

**Project:** -  
**Project # :** N/A  
**PWSID # :** -  
**PO # :** 140989


**Sampling Location:** West Powellhurst  
**Sample Matrix:** Drinking Water

Lab Number	Sample Name	Sampled: 11/1/13 5:54		Sample Composition:				
<b>3312010-33</b>	<b>WPKITCHEN1A</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	0.004	0.002	0.015	-	11/13/13 15:43

Lab Number	Sample Name	Sampled: 11/1/13 5:56		Sample Composition:				
<b>3312010-34</b>	<b>WPKITCHEN1B</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/13/13 15:43

Lab Number	Sample Name	Sampled: 11/1/13 5:53		Sample Composition:				
<b>3312010-35</b>	<b>WPKITCHEN2A</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	0.008	0.002	0.015	-	11/13/13 15:43

Lab Number	Sample Name	Sampled: 11/1/13 5:55		Sample Composition:				
<b>3312010-36</b>	<b>WPKITCHEN2B</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
<sup>†</sup> Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	11/13/13 15:43



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 11/15/2013  
Received: 11/07/2013  
Sampled By: Faye Bayer  
Work Order: 3312010

**C** David Douglas School District  
**L** Attn: David Callaway  
**I** 2900 SE 122nd  
**E** Portland OR, 97236  
**N** Phone: (503) 252-2900  
**T**

**Project:** -  
Project # : N/A  
PWSID # : -  
PO # : 140989

Sampling Location: West Powellhurst  
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled:	Sample Composition:						
			Code	Method	Units	Result	MRL	EPA MCL	Analysis Date

†

ND = None detected    MRL = Minimum Reporting Limit    MCL = Maximum Contamination Limit  
MCLE This analyte exceeds the MCL limit.

†All procedures for this analysis conform to NELAC standards.

Approved by:

Scott Dickman  
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.