



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/12/2016

Received: 10/17/2016

Sampled By:

Work Order: 6291026


**C
L
I
E
N
T**
David Douglas School District
Attn: -
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: Menlo Park

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
6291026-01	Sample Name: MN1 F Sampled: 10/15/16 9:51							Matrix: Drinking Water
+Lead	1030	EPA 200.9	2.8	ppb	2.0	20 ppb	12/06/16 17:01	
6291026-02	Sample Name: MN2 F Sampled: 10/15/16 9:51							Matrix: Drinking Water
+Lead	1030	EPA 200.9	40.3	ppb	4.0	20 ppb	12/06/16 17:01 MCLE	
6291026-03	Sample Name: MN3 F Sampled: 10/15/16 9:52							Matrix: Drinking Water
+Lead	1030	EPA 200.9	10.1	ppb	2.0	20 ppb	12/06/16 17:01	
6291026-04	Sample Name: MN4 F Sampled: 10/15/16 9:53							Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01	
6291026-05	Sample Name: MN5 F Sampled: 10/15/16 9:53							Matrix: Drinking Water
+Lead	1030	EPA 200.9	6.3	ppb	2.0	20 ppb	12/06/16 17:01	
6291026-06	Sample Name: MN6 SK Sampled: 10/15/16 9:54							Matrix: Drinking Water
+Lead	1030	EPA 200.9	6.4	ppb	2.0	20 ppb	12/06/16 17:01	
6291026-07	Sample Name: MN7 Spayer Sampled: 10/15/16 9:55							Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01	
6291026-08	Sample Name: MN8 F Sampled: 10/15/16 9:56							Matrix: Drinking Water
+Lead	1030	EPA 200.9	54.3	ppb	4.0	20 ppb	12/06/16 17:01 MCLE	
6291026-09	Sample Name: MN9 F Sampled: 10/15/16 9:56							Matrix: Drinking Water
+Lead	1030	EPA 200.9	5.1	ppb	2.0	20 ppb	12/06/16 17:01	
6291026-10	Sample Name: MN10 F Sampled: 10/15/16 9:59							Matrix: Drinking Water
+Lead	1030	EPA 200.9	35.4	ppb	2.0	20 ppb	12/06/16 17:01 MCLE	



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/12/2016
Received: 10/17/2016
Sampled By:
Work Order: 6291026

**C
L
I
E
N
T**
David Douglas School District
Attn: -
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: Menlo Park

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6291026-11	Sample Name: MN11 F Sampled: 10/15/16 10:01		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	2.8	ppb	2.0	20 ppb	12/06/16 17:01
6291026-12	Sample Name: MN12 F Sampled: 10/15/16 10:00		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	12/06/16 17:01
6291026-13	Sample Name: MN13 F Sampled: 10/15/16 10:02		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	4.4	ppb	2.0	20 ppb	12/06/16 17:01
6291026-14	Sample Name: MN14 F Sampled: 10/15/16 10:03		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01
6291026-15	Sample Name: MN15 F Sampled: 10/15/16 10:04		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	12/06/16 17:01
6291026-16	Sample Name: MN16 F Sampled: 10/15/16 10:05		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	12/06/16 17:01
6291026-17	Sample Name: MN17 F Sampled: 10/15/16 10:06		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	12/06/16 17:01
6291026-18	Sample Name: MN18 F Sampled: 10/15/16 10:07		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01
6291026-19	Sample Name: MN19 F Sampled: 10/15/16 10:08		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01
6291026-20	Sample Name: MN20 DF Sampled: 10/15/16 10:09		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/12/2016

Received: 10/17/2016

Sampled By:

Work Order: 6291026


**C
L
I
E
N
T**
David Douglas School District
Attn: -
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: Menlo Park

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
6291026-21	Sample Name: MN21 Bradley Sampled: 10/15/16 10:11							Matrix: Drinking Water
+Lead	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	12/06/16 17:01	
6291026-22	Sample Name: MN22 F Sampled: 10/15/16 10:12							Matrix: Drinking Water
+Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	12/06/16 17:01	
6291026-23	Sample Name: MN23 DF Sampled: 10/15/16 10:12							Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01	
6291026-24	Sample Name: MN 24 Bradley Sampled: 10/15/16 10:13							Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01	
6291026-25	Sample Name: MN25 Bradley Sampled: 10/15/16 10:13							Matrix: Drinking Water
+Lead	1030	EPA 200.9	4.6	ppb	2.0	20 ppb	12/06/16 17:01	
6291026-26	Sample Name: MN27 F Sampled: 10/15/16 10:17							Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01	
6291026-27	Sample Name: MN28 B Sampled: 10/15/16 10:19							Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01	
6291026-28	Sample Name: MN29 F Sampled: 10/15/16 10:19							Matrix: Drinking Water
+Lead	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	12/06/16 17:01	
6291026-29	Sample Name: MN30 F Sampled: 10/15/16 10:20							Matrix: Drinking Water
+Lead	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	12/06/16 17:01	
6291026-30	Sample Name: MN31 B Sampled: 10/15/16 10:20							Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01	



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/12/2016
Received: 10/17/2016
Sampled By:
Work Order: 6291026

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Menlo Park

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6291026-31	Sample Name: MN32 F Sampled: 10/15/16 10:21		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	3.8	ppb	2.0	20 ppb	12/06/16 17:01
6291026-32	Sample Name: MN33 B Sampled: 10/15/16 10:21		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	2.5	ppb	2.0	20 ppb	12/07/16 16:39
6291026-33	Sample Name: MN34 F Sampled: 10/15/16 10:22		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	3.4	ppb	2.0	20 ppb	12/07/16 16:39
6291026-34	Sample Name: MN35 B Sampled: 10/15/16 10:22		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-35	Sample Name: MN36 DF Sampled: 10/15/16 10:23		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-36	Sample Name: MN37 B Sampled: 10/15/16 10:08		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-37	Sample Name: MN38 B Sampled: 10/15/16 10:07		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-38	Sample Name: MN39 B Sampled: 10/15/16 10:06		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-39	Sample Name: MN40 B Sampled: 10/15/16 10:05		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-40	Sample Name: MN41 B Sampled: 10/15/16 10:04		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/12/2016
Received: 10/17/2016
Sampled By:
Work Order: 6291026

C
L
I
E
N
T


David Douglas School District
Attn: -
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: Menlo Park

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6291026-41	Sample Name: MN42 B Sampled: 10/15/16 10:03		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-42	Sample Name: MN43 DF Sampled: 10/15/16 10:30		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-43	Sample Name: MN44 F Sampled: 10/15/16 10:31		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-44	Sample Name: MN45 B Sampled: 10/15/16 10:31		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-45	Sample Name: MN46 F0 Sampled: 10/15/16 10:32		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-46	Sample Name: MN47 B Sampled: 10/15/16 10:32		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-47	Sample Name: MN48 F Sampled: 10/15/16 10:33		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-48	Sample Name: MN49 B Sampled: 10/15/16 10:33		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-49	Sample Name: MN50 F Sampled: 10/15/16 10:34		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-50	Sample Name: MN51 B Sampled: 10/15/16 10:34		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/12/2016
Received: 10/17/2016
Sampled By:
Work Order: 6291026

**C
L
I
E
N
T**
David Douglas School District
Attn: -
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: Menlo Park

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6291026-51	Sample Name: MN52 F Sampled: 10/15/16 10:35		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-52	Sample Name: MN53 B Sampled: 10/15/16 10:35		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	12/07/16 16:39
6291026-53	Sample Name: MN54 F Sampled: 10/15/16 10:36		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-54	Sample Name: MN55 B Sampled: 10/15/16 10:36		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	12/07/16 16:39
6291026-55	Sample Name: MN56 B Sampled: 10/15/16 10:01		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-56	Sample Name: MN57 B Sampled: 10/15/16 10:00		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-57	Sample Name: MN58 Bradley Sampled: 10/15/16 10:38		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-58	Sample Name: MN60 Bradley Sampled: 10/15/16 10:39		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	12/07/16 16:39
6291026-59	Sample Name: MN61 F Sampled: 10/15/16 10:42		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-60	Sample Name: MN62 B Sampled: 10/15/16 10:42		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/12/2016
Received: 10/17/2016
Sampled By:
Work Order: 6291026

C **David Douglas School District**
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Menlo Park

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6291026-61	Sample Name: MN63 F Sampled: 10/15/16 10:43		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	2.7	ppb	2.0	20 ppb	12/07/16 16:39
6291026-62	Sample Name: MN64 B Sampled: 10/15/16 10:43		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	12/07/16 16:39
6291026-63	Sample Name: MN65 DF Sampled: 10/15/16 10:45		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-64	Sample Name: MN66 F Sampled: 10/15/16 10:45		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	12/07/16 16:39
6291026-65	Sample Name: MN67 B Sampled: 10/15/16 10:45		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	4.3	ppb	2.0	20 ppb	12/07/16 16:39
6291026-66	Sample Name: MN68 F Sampled: 10/15/16 10:46		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	12/07/16 16:39
6291026-67	Sample Name: MN69 B Sampled: 10/15/16 10:46		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	3.6	ppb	2.0	20 ppb	12/07/16 16:39
6291026-68	Sample Name: MN70 F Sampled: 10/15/16 10:47		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	12/07/16 16:39
6291026-69	Sample Name: MN71 B Sampled: 10/15/16 10:47		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	2.8	ppb	2.0	20 ppb	12/07/16 16:39
6291026-70	Sample Name: MN72 F Sampled: 10/15/16 10:48		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	3.6	ppb	2.0	20 ppb	12/07/16 16:39



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/12/2016
Received: 10/17/2016
Sampled By:
Work Order: 6291026

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Menlo Park

Lab Number


	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6291026-71	Sample Name: MN73 B Sampled: 10/15/16 10:48		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	2.5	ppb	2.0	20 ppb	12/07/16 16:39
6291026-72	Sample Name: MN74 Sampled: 10/15/16 10:49		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	12/07/16 16:39
6291026-73	Sample Name: MN75 Sampled: 10/15/16 10:49		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39
6291026-74	Sample Name: MN76 Sampled: 10/15/16 10:15		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/07/16 16:39

MCL This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director