



December 4, 2017

David Callaway
David Douglas School District
11300 NE Halsey Street
Portland, Oregon 97220

Via email: david_callaway@ddsd40.org

Regarding: District-Wide Radon Testing
David Douglas High School, North Building
1001 SE 135th Avenue
Portland, Oregon 97233
PBS Project 23179.043, Phase 0002

Dear Mr. Callaway:

From October 30 to November 17, 2017, PBS Engineering and Environmental Inc. (PBS) performed short-term radon testing at David Douglas High School, North building located at 1001 SE 135th Avenue in Portland, Oregon.

The Environmental Protection Agency (EPA) and Oregon Health Authority (OHA) recommend that buildings be tested for radon and that any radon concentrations be maintained below 4.0 picocuries per liter (pCi/L) of air. PBS used Air Chek, Inc. brand single-use, short-term radon test kits to measure radon levels in frequently-occupied rooms that are in contact with the ground or above unoccupied basements or crawlspaces.

The following table lists all samples in which radon levels were found to be above the EPA action level. Following OHA protocol samples with results equal to or greater than 8.0 pCi/L were retested. Retest samples include "#2" in the sample location description.

Test Kits with Radon 4.0 pCi/L or Above

Test Kit Number	Sample location	Radon Level (pCi/L)
7957231	North, gym-2	4.2
7957234	North, girls locker room office	18.9
7957237	North, weight room-1	5.0
7957238	North, weight room-1 duplicate	4.7
7957239	North, cardio room duplicate	5.4
7957240	North, weight room-2	5.1
7957241	North, cardio room	5.8
7957242	North, boys locker room office	10.0
7957247	North, boys team office	10.7
7957616	North, boys locker room office #2	9.8

Test Kit Number	Sample location	Radon Level (pCi/L)
7957617	North, boys team office #2	12.3
7957618	North, girls locker room office #2	21.1

See the attached laboratory analysis report for more details.

In addition to the EPA recommendation that radon concentrations not exceed 4.0 pCi/L, OHA recommends that the following steps be conducted based on the results of a room's initial short-term test:

- **If the result is less than 2.0 pCi/L**, school districts are required to test again every 10 years, per Oregon Revised Statute 332.166-167.
- **If the result is between 2.0 pCi/L and 4.0 pCi/L**, consider fixing (i.e., lowering) the radon in that room.
- **If the result is from 4.0 pCi/L to 8.0 pCi/L**, perform a follow-up measurement of that room using a long-term test. This test should be conducted over as much of a nine-month school year as possible, when the room is likely to be occupied. If that result is equal to or greater than 4.0 pCi/L, the radon in the room should be fixed (i.e., lowered).
- **If the initial short-term test result is equal to or greater than 8.0 pCi/L**, conduct a second short-term test and average its result with the initial short-term test result. If the average of the two is equal to or greater than 4.0 pCi/L, radon in the room should be fixed (i.e., lowered).

Note: A great difference in the results of the short-term tests may indicate a flaw in the testing process. Investigate and consider retesting. For situations in which one of the test results is equal to or greater than 4.0 pCi/L, if the higher result is two or more times the lower result, repeat the test.

LIMITATIONS OF SCOPE

This study was limited to the tests and locations as previously indicated. The site as a whole may have other environmental concerns that will not be characterized by this study. The findings and conclusions of this work are not scientific certainties, but probabilities based on professional judgment concerning the significance of the data gathered during the course of this investigation. PBS is not able to represent conditions on the site or adjoining sites beyond those detected or observed by PBS.

Please feel free to contact me at 503.417.7694 or chris.boyce@pbsusa.com with any questions or comments.

Sincerely,



Chris Boyce
Project Manager

Attachment: AirChek, Inc Laboratory Analysis Report

CB::bmp

Radon test result report for:

**DAVID DOUGLAS HIGH SCHOOL
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7956932	102A	2017-11-06 @ 3:00 pm	2017-11-09 @ 2:00 pm	0.8 ± 0.3	2017-11-13
7956954	102B	2017-11-06 @ 4:00 pm	2017-11-09 @ 2:00 pm	0.5 ± 0.3	2017-11-13
7956938	103A	2017-11-06 @ 3:00 pm	2017-11-09 @ 2:00 pm	1.0 ± 0.3	2017-11-13
7956934	103B	2017-11-06 @ 3:00 pm	2017-11-09 @ 2:00 pm	2.0 ± 0.4	2017-11-13
7956937	103C	2017-11-06 @ 3:00 pm	2017-11-09 @ 2:00 pm	1.2 ± 0.3	2017-11-13
7956950	124A	2017-11-06 @ 3:00 pm	2017-11-09 @ 2:00 pm	< 0.3	2017-11-13
7956944	125A	2017-11-06 @ 3:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956949	125A DUP	2017-11-06 @ 3:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956948	125B	2017-11-06 @ 3:00 pm	2017-11-09 @ 2:00 pm	0.7 ± 0.3	2017-11-13
7956947	125C	2017-11-06 @ 3:00 pm	2017-11-09 @ 2:00 pm	1.2 ± 0.3	2017-11-13
7956943	126A	2017-11-06 @ 3:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956942	126B	2017-11-06 @ 3:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956941	126C	2017-11-06 @ 3:00 pm	2017-11-09 @ 3:00 pm	0.7 ± 0.3	2017-11-13
7957230	137A	2017-11-06 @ 6:00 pm	2017-11-09 @ 5:00 pm	0.6 ± 0.3	2017-11-13
7957207	141 DUP	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	0.5 ± 0.3	2017-11-13
7956994	145 DUP	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7957216	169 B	2017-11-06 @ 6:00 pm	2017-11-09 @ 5:00 pm	0.5 ± 0.3	2017-11-13
7957215	169 C	2017-11-06 @ 6:00 pm	2017-11-09 @ 5:00 pm	0.6 ± 0.3	2017-11-13
7957223	169A	2017-11-06 @ 6:00 pm	2017-11-09 @ 5:00 pm	0.8 ± 0.3	2017-11-13
7956931	ATHLETIC OFF SEC	2017-11-06 @ 3:00 pm	2017-11-09 @ 2:00 pm	< 0.3	2017-11-13
7956933	ATTENDANCE OFFIC	2017-11-06 @ 3:00 pm	2017-11-09 @ 2:00 pm	0.9 ± 0.3	2017-11-13
7957219	BOOK ROOM	2017-11-06 @ 6:00 pm	2017-11-09 @ 5:00 pm	1.0 ± 0.3	2017-11-13
7957242	BOYS LOCKER OFFI	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	10.0 ± 0.6	2017-11-13
7957247	BOYS TEAM OFFICE	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	10.7 ± 0.6	2017-11-13
7957256	CAFETERIA 1	2017-11-06 @ 8:00 pm	2017-11-09 @ 2:00 pm	0.6 ± 0.3	2017-11-13
7957254	CAFETERIA 1 DUP	2017-11-06 @ 8:00 pm	2017-11-09 @ 2:00 pm	0.5 ± 0.3	2017-11-13
7957255	CAFETERIA 2	2017-11-06 @ 8:00 pm	2017-11-09 @ 2:00 pm	0.7 ± 0.3	2017-11-13
7957241	CARDIO ROOM	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	5.8 ± 0.5	2017-11-13
7957239	CARDIO ROOM BLAN	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	5.4 ± 0.4	2017-11-13
7956955	CLR 104	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956960	CLR 105	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956963	CLR 108	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956962	CLR 108 DUP	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	0.6 ± 0.3	2017-11-13
7956965	CLR 109	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956966	CLR 110	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	0.7 ± 0.3	2017-11-13
7956967	CLR 111	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	0.5 ± 0.3	2017-11-13
7956969	CLR 112	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13

Radon test result report for:

**DAVID DOUGLAS HIGH SCHOOL
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7956971	CLR 113	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956964	CLR 114	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956961	CLR 114 BLANK	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956956	CLR 115	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956935	CLR 116	2017-11-06 @ 3:00 pm	2017-11-09 @ 3:00 pm	0.9 ± 0.3	2017-11-13
7956940	CLR 118	2017-11-06 @ 3:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956951	CLR 120	2017-11-06 @ 4:00 pm	2017-11-09 @ 5:00 pm	0.6 ± 0.3	2017-11-13
7956952	CLR 121	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	0.6 ± 0.3	2017-11-13
7956957	CLR 122	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956958	CLR 123	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956945	CLR 124	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956972	CLR 127	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956973	CLR 128	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	0.6 ± 0.3	2017-11-13
7956975	CLR 129	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	0.6 ± 0.3	2017-11-13
7956976	CLR 130	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7956978	CLR 131	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7956981	CLR 132	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7956977	CLR 133	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7956970	CLR 134	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7956974	CLR 135	2017-11-06 @ 4:00 pm	2017-11-09 @ 4:00 pm	0.8 ± 0.3	2017-11-13
7956968	CLR 136	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7957214	CLR 138	2017-11-06 @ 6:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7957211	CLR 139	2017-11-06 @ 6:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7957212	CLR 140	2017-11-06 @ 6:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7957208	CLR 141	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7957201	CLR 142	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7956999	CLR 143	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7957000	CLR 144	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7956993	CLR 145	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7956997	CLR 146	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7956996	CLR 147	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	0.5 ± 0.3	2017-11-13
7957204	CLR 148	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7957202	CLR 149	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7957205	CLR 149 BLANK	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7957206	CLR 150	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7957203	CLR 152	2017-11-06 @ 6:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7957218	CLR 153	2017-11-06 @ 6:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13

Radon test result report for:

**DAVID DOUGLAS HIGH SCHOOL
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7957217	CLR 154	2017-11-06 @ 6:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7957210	CLR 154 DUP	2017-11-06 @ 6:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7957224	CLR 168	2017-11-06 @ 6:00 pm	2017-11-09 @ 5:00 pm	0.7 ± 0.3	2017-11-13
7957222	CLR 168	2017-11-06 @ 6:00 pm	2017-11-09 @ 5:00 pm	0.8 ± 0.3	2017-11-13
7957221	CLR 168 DUP	2017-11-06 @ 6:00 pm	2017-11-09 @ 5:00 pm	0.6 ± 0.3	2017-11-13
7957220	CLR 169	2017-11-06 @ 6:00 pm	2017-11-09 @ 5:00 pm	0.6 ± 0.3	2017-11-13
7956936	COUNSELING ADMIN	2017-11-06 @ 3:00 pm	2017-11-09 @ 2:00 pm	0.5 ± 0.3	2017-11-13
7957227	CUST SHOP	2017-11-06 @ 6:00 pm	2017-11-09 @ 5:00 pm	0.5 ± 0.3	2017-11-13
7956986	FAC WORKROOM	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	1.1 ± 0.3	2017-11-13
7957234	GIRLS LOCKER OFF	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	18.9 ± 0.8	2017-11-13
7957233	GYM 1	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	3.3 ± 0.4	2017-11-13
7957232	GYM 1 DUP	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	3.3 ± 0.3	2017-11-13
7957231	GYM 2	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	4.2 ± 0.4	2017-11-13
7956953	KITCHEN OFFICE	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7957228	LIBRARY 1	2017-11-06 @ 6:00 pm	2017-11-09 @ 5:00 pm	1.1 ± 0.3	2017-11-13
7957229	LIBRARY 1 DUP	2017-11-06 @ 6:00 pm	2017-11-09 @ 5:00 pm	0.9 ± 0.3	2017-11-13
7957225	LIBRARY 2	2017-11-06 @ 6:00 pm	2017-11-09 @ 5:00 pm	0.9 ± 0.3	2017-11-13
7957226	LIBRARY OFFICE	2017-11-06 @ 6:00 pm	2017-11-09 @ 5:00 pm	0.9 ± 0.3	2017-11-13
7956928	MAIN OFFICE	2017-11-06 @ 3:00 pm	2017-11-09 @ 2:00 pm	< 0.3	2017-11-13
7957213	NURSE	2017-11-06 @ 6:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7956930	OFFICE	2017-11-06 @ 3:00 pm	2017-11-09 @ 2:00 pm	< 0.3	2017-11-13
7957209	OFFICE 151	2017-11-06 @ 6:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7957257	PORT 155 DUP	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	0.6 ± 0.3	2017-11-13
7957253	PORT 155A	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	< 0.3	2017-11-13
7957249	PORT 156	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	< 0.3	2017-11-13
7957250	PORT 156A	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	0.5 ± 0.3	2017-11-13
7957258	PORTABLE 155	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	0.6 ± 0.3	2017-11-13
7957252	PORTABLE 158	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	< 0.3	2017-11-13
7957251	PORTABLE 159	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	< 0.3	2017-11-13
7956927	PRINCIPAL	2017-11-06 @ 3:00 pm	2017-11-09 @ 3:00 pm	< 0.3	2017-11-13
7956946	ROOM 119	2017-11-06 @ 4:00 pm	2017-11-09 @ 2:00 pm	< 0.3	2017-11-13
7956984	S1	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7956990	S10	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7956995	S11	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	0.6 ± 0.3	2017-11-13
7956998	S12	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	0.6 ± 0.3	2017-11-13
7956982	S2	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7956983	S3	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13

Radon test result report for:

**DAVID DOUGLAS HIGH SCHOOL
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7956980	S4	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7956979	S5	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7956988	S6	2017-11-06 @ 5:00 pm	2017-11-09 @ 5:00 pm	1.1 ± 0.3	2017-11-13
7956985	S7	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	1.1 ± 0.3	2017-11-13
7956989	S7 DUP	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	1.2 ± 0.3	2017-11-13
7956991	S8	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	1.0 ± 0.3	2017-11-13
7956992	S8 BLANK	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	< 0.3	2017-11-13
7956987	S9	2017-11-06 @ 5:00 pm	2017-11-09 @ 4:00 pm	0.8 ± 0.3	2017-11-13
7956959	STAFF LOUNGE	2017-11-06 @ 4:00 pm	2017-11-09 @ 3:00 pm	0.8 ± 0.3	2017-11-13
7956929	VICE PRINCIPAL	2017-11-06 @ 3:00 pm	2017-11-09 @ 2:00 pm	< 0.3	2017-11-13
7957238	WEIGHT 1 DUP	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	4.7 ± 0.4	2017-11-13
7957237	WEIGHT ROOM 1	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	5.0 ± 0.4	2017-11-13
7957240	WEIGHT ROOM 2	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	5.1 ± 0.4	2017-11-13

Radon test result report for:
**HIGH SCHOOL -NORTH
SOCIAL STUDIES**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7957235	301	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	0.7 ± 0.3	2017-11-13
7957236	302	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	0.8 ± 0.3	2017-11-13
7957243	303	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	0.6 ± 0.3	2017-11-13
7957245	303-DUP	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	0.9 ± 0.3	2017-11-13
7957244	304	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	< 0.3	2017-11-13
7957246	305	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	0.6 ± 0.3	2017-11-13
7957248	306	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	0.8 ± 0.3	2017-11-13
7957392	307	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	0.5 ± 0.3	2017-11-13
7957393	308	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	0.8 ± 0.3	2017-11-13
7957394	309	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	1.0 ± 0.3	2017-11-13
7957395	310	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	1.2 ± 0.3	2017-11-13
7957396	BLANK	2017-11-06 @ 7:00 pm	2017-11-09 @ 5:00 pm	< 0.3	2017-11-13

November 20, 2017

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
**HIGH SCHOOL -NORTH
NORTH**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7957616	BOYS LR OFF. #2	2017-11-14 @ 11:00 am	2017-11-17 @ 1:00 pm	9.8 ± 0.5	2017-11-20
7957617	BOYS TEAM OFF.#2	2017-11-14 @ 11:00 am	2017-11-17 @ 1:00 pm	12.3 ± 0.6	2017-11-20
7957618	GIRLS LR OFF.#2	2017-11-14 @ 11:00 am	2017-11-17 @ 1:00 pm	21.1 ± 0.7	2017-11-20

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498