



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 12/12/2017  
Received: 11/15/2017  
Sampled By: Adam Ponce  
Work Order: 7319026

**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Gilbert Heights  
Sample Matrix: Water

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>7319026-01</b>	<b>Sample Name: #058 F</b>		<b>Matrix: Water</b>				
	<b>Sampled: 11/15/17 6:25</b>						
+Lead	1030	EPA 200.9	5	ppb	2	20 ppb	12/11/17 14:28

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director