



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/12/2017  
Received: 11/15/2017  
Sampled By: Adam Ponce  
Work Order: 7319028

**C  
L  
I  
E  
N  
T**  
**David Douglas School District**  
Attn: -  
11300 NE Halsey St  
Portland OR, 97220  
Phone: (503) 252-2900

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: North Powellhurst

## Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>7319028-01</b>	<b>Sample Name: #058 D/F</b> <b>Sampled: 11/15/17 5:10</b>		<b>Matrix: Water</b>				
+Lead	1030	EPA 200.9	7	ppb	2	20 ppb	12/11/17 14:28
<b>7319028-02</b>	<b>Sample Name: #036 D/F</b> <b>Sampled: 11/15/17 5:14</b>		<b>Matrix: Water</b>				
+Lead	1030	EPA 200.9	14	ppb	2	20 ppb	12/11/17 14:28 <b>B</b>
<b>7319028-03</b>	<b>Sample Name: #022 D/F</b> <b>Sampled: 11/15/17 5:17</b>		<b>Matrix: Water</b>				
+Lead	1030	EPA 200.9	6	ppb	2	20 ppb	12/11/17 14:28
<b>7319028-04</b>	<b>Sample Name: #025 D/F</b> <b>Sampled: 11/15/17 5:19</b>		<b>Matrix: Water</b>				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	12/11/17 14:28
<b>7319028-05</b>	<b>Sample Name: #010 D/F</b> <b>Sampled: 11/15/17 5:21</b>		<b>Matrix: Water</b>				
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	12/11/17 14:28
<b>7319028-06</b>	<b>Sample Name: #011 D/F</b> <b>Sampled: 11/15/17 5:23</b>		<b>Matrix: Water</b>				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	12/11/17 14:28

**B** Analyte is found in the associated blank as well as in the sample (CLP B-flag).

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director