



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/12/2017
Received: 11/15/2017
Sampled By: Adam Ponce
Work Order: 7319031

C
L
I
E
N
T

David Douglas School District
Attn: -
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: Gilbert Park

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7319031-01	Sample Name: #027 F		Matrix: Water				
	Sampled: 11/15/17 6:38						
+Lead	1030	EPA 200.9	7	ppb	2	20 ppb	12/11/17 14:28
7319031-02	Sample Name: #028 DF		Matrix: Water				
	Sampled: 11/15/17 6:40						
+Lead	1030	EPA 200.9	15	ppb	2	20 ppb	12/11/17 14:28
7319031-03	Sample Name: #023 F		Matrix: Water				
	Sampled: 11/15/17 6:44						
+Lead	1030	EPA 200.9	13	ppb	2	20 ppb	12/11/17 14:28
7319031-04	Sample Name: #025 F		Matrix: Water				
	Sampled: 11/15/17 6:46						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	12/11/17 14:28
7319031-05	Sample Name: #019 F		Matrix: Water				
	Sampled: 11/15/17 6:50						
+Lead	1030	EPA 200.9	8	ppb	2	20 ppb	12/11/17 14:28
7319031-06	Sample Name: #059 DF		Matrix: Water				
	Sampled: 11/15/17 6:55						
+Lead	1030	EPA 200.9	5	ppb	2	20 ppb	12/11/17 14:28

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:

Adriana Gonzalez-Gray
Laboratory Director