



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/26/2017
Received: 12/13/2017
Sampled By: Adam Ponce
Work Order: 7347003

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project:
Project # : N/A
Sample Type :

Sampling Location: South High

Lab Number


Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7347003-01	Sample Name: #009 DF Sampled: 12/13/17 5:18		Matrix: Water				
+Lead	1030	EPA 200.9	4	ppb	2	20 ppb	12/15/17 14:15
7347003-02	Sample Name: #059 F Sampled: 12/13/17 5:25		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	12/15/17 14:15
7347003-03	Sample Name: #064 DF Sampled: 12/13/17 5:31		Matrix: Water				
+Lead	1030	EPA 200.9	3	ppb	2	20 ppb	12/15/17 14:15
7347003-04	Sample Name: #072 DF Sampled: 12/13/17 5:35		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	12/15/17 14:15
7347003-05	Sample Name: #076 DF Sampled: 12/13/17 5:42		Matrix: Water				
+Lead	1030	EPA 200.9	16	ppb	2	20 ppb	12/15/17 14:15
7347003-06	Sample Name: #084 F Sampled: 12/13/17 5:55		Matrix: Water				
+Lead	1030	EPA 200.9	22	ppb	2	20 ppb	12/26/17 12:51 MCLE
7347003-07	Sample Name: #085 DF Sampled: 12/13/17 5:50		Matrix: Water				
+Lead	1030	EPA 200.9	3	ppb	2	20 ppb	12/15/17 14:15
7347003-08	Sample Name: #054 DF Sampled: 12/13/17 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	25	ppb	2	20 ppb	12/26/17 12:51 MCLE

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit

MCL = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/26/2017
Received: 12/13/2017
Sampled By: Adam Ponce
Work Order: 7347003

C
L
I
E
N
T

David Douglas School District
Attn: -
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :


Sampling Location: South High

Lab Number

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.



Professional Laboratory Services

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email: mail@alexinlabs.com

Chain of Custody Record

Laboratory Job Number:

7347003-01-08

Page 1 of 1

Client Contact Information		Results Reporting Information		Invoicing Information	
Company/Client Name: David Douglas S.D.		Project Manager:		Accounts Payable Contact:	
Address: 11300 NE Halsey St		Mailing Address: same		Mailing Address: same	
City/State/Zip: Portland OR 97222		City/State/Zip:		City/State/Zip:	
phone: (503) 519-5244		phone:		phone:	
fax or email: troy-thompson@ddsdd40.org		fax or email:		fax or email:	

Sampling Location: Troy - Thompson ca 12/13/17 **SAMPLING INFORMATION**

Project Name: P.O. #: PWSID #:

Project #: Permit #:

S.H = South High
D.F = Drinking Fountain
F = Faucet

Lab ID	Sample Identification	Date Collected	Time Collected (Begin/End if camp)	Sample Matrix*	# of cont	Analysis Requested**	Sample Specific Notes/Field Data
-01	#009 DF	12/13/17	5:18 AM		10		SEE ATTACHED
-02	#059 F	12/13/17	5:25 AM				for each WW sample, specify <u>Grab / Composite</u>
-03	#069 DF	12/13/17	5:31 AM				for each DW sample, specify <u>Raw / Treated</u>
-04	#072 DF	12/13/17	5:35 AM				Source / Distribution, Single / Combined
-05	#076 DF	12/13/17	5:42 AM				WHERE APPLICABLE
-06	#084 F	12/13/17	5:55 AM				
-07	#085 DF	12/13/17	5:50 AM				
-08	#054 DF	12/13/17	6:00 AM				

Relinquished By (print): <u>Adam Jones</u>	Company: <u>David Douglas South High</u>	Date/Time: <u>12/13/17</u>	Signature: <u>[Signature]</u>	Received By:	Company:	Date/Time:	Signature:
Relinquished By (print):	Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:

The most current revision of SOP-10-003 was used when these samples were collected

Received by Laboratory Staff: [Signature] Date/Time: 12/13/17 Temp. on receipt: 7 °C On Ice? Y

Containers Intact? Y ID: TRM-10-0

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.

COC-90-006rev0.1