



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 04/12/2018
Received: 03/30/2018
Sampled By: Adam Ponce
Work Order: 8089010

C
L
I
E
N
T

David Douglas School District
Attn: -
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: West Powellhurst

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
8089010-01	Sample Name: W.P. # 020 DF Sampled: 3/30/18 7:10		Matrix: Water				
+Lead	1030	EPA 200.9	7	ppb	2	20 ppb	04/11/18 14:44
8089010-02	Sample Name: W.P. # 021 DF Sampled: 3/30/18 7:12		Matrix: Water				
+Lead	1030	EPA 200.9	4	ppb	2	20 ppb	04/11/18 14:44

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____



Adriana Gonzalez-Gray
Laboratory Director

