



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 08/02/2018
Received: 07/31/2018
Sampled By: Adam Ponce
Work Order: 8212001

**C
L
I
E
N
T**
David Douglas School District
Attn: Troy Thompson
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: North High School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
8212001-01	Sample Name: #195F Re-test Sampled: 7/31/18 6:10		Matrix: Water				
+Lead	1030	EPA 200.9	46	ppb	4	20 ppb	08/01/18 16:06 MCLE
8212001-02	Sample Name: #189F Re-test Sampled: 7/31/18 6:13		Matrix: Water				
+Lead	1030	EPA 200.9	13	ppb	4	20 ppb	08/01/18 16:06
8212001-03	Sample Name: #027DF Sampled: 7/31/18 6:19		Matrix: Water				
+Lead	1030	EPA 200.9	57	ppb	4	20 ppb	08/01/18 16:06 MCLE
8212001-04	Sample Name: #019DF Sampled: 7/31/18 6:22		Matrix: Water				
+Lead	1030	EPA 200.9	15	ppb	4	20 ppb	08/01/18 16:06
8212001-05	Sample Name: #135DF Sampled: 7/31/18 6:26		Matrix: Water				
+Lead	1030	EPA 200.9	52	ppb	4	20 ppb	08/01/18 16:06 MCLE
8212001-06	Sample Name: #127DF Sampled: 7/31/18 6:27		Matrix: Water				
+Lead	1030	EPA 200.9	30	ppb	4	20 ppb	08/01/18 16:06 MCLE
8212001-07	Sample Name: #183DF Sampled: 7/31/18 6:36		Matrix: Water				
+Lead	1030	EPA 200.9	93	ppb	8	20 ppb	08/01/18 16:06 MCLE

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Adriana Gonzalez-Gray
Laboratory Director



Alexin Analytical Laboratories, Inc.
Professional Laboratory Services

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email: mail@alexinlabs.com

Chain of Custody Record

Laboratory Job Number: 0212001-01-207

Page 1 of 1

Client Contact Information	Results Reporting Information	Invoicing Information
Company/Client Name: David Douglas S.D.	Project Manager:	Accounts Payable Contact:
Address: 11300 NE Halsey St	Mailing Address: same	Mailing Address: same
City/State/Zip: Portland OR 97222	City/State/Zip:	City/State/Zip:
phone: (503) 519-5244	phone:	phone:
fax or email: <u>tray.thompson@ddsd40.org</u>	fax or email:	fax or email:

Project Name: Troy Thompson 02 8/1/18

Project #: SAMPLING INFORMATION

Sampling Location: North High School

Sampled By: Adam Ponce

Send results to OR State Health Division? (Please circle) Yes No

P.O. #: _____ PWSID #: _____

Permit #: _____

N.H. = North High School
D.F. = Drinking Fountain
F. = Faucet

Lab. ID <small>Lab. use only</small>	Sample Identification	Date Collected	Time Collected <small>(Begin/End if comp)</small>	Sample Matrix*	# of cont. rec'd	Analysis Requested**	Sample Specific Notes/Field Data
-01	#195F Re-test	7/31/18	6:10 AM		200	X	SEE ATTACHED
-02	#189F Re-test	7/31/18	6:13 AM				
-03	#0270F	7/31/18	6:19 AM				
-04	#019DF	7/31/18	6:22 AM				
-05	#1350F	7/31/18	6:26 AM				
-06	#127DF	7/31/18	6:27 AM				
-07	#183DF	7/31/18	6:36 AM				

Relinquished By (print): <u>Adam Ponce</u>	Company: _____	Date/Time: <u>7/31/18</u>	Signature: <u>[Signature]</u>	Received By: _____	Company: _____	Date/Time: _____	Signature: _____
--	----------------	---------------------------	-------------------------------	--------------------	----------------	------------------	------------------

The most current revision of SOP-10-003 was used when these samples were collected

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

Received by: [Signature] Date/Time: 7/31/18 Temp. on receipt: _____
 Containers: Intact? Y N ID: TRM-10: _____

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.

COC-90-006rev0.1