

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 08/14/2018
Received: 08/10/2018
Sampled By: Adam Ponce
Work Order: 8222028

C
L
I
E
N
T


David Douglas School District
Attn: Troy Thompson
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: North High School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
8222028-01	Sample Name: #195F Retest 1st Draw		Matrix: Water				
	Sampled: 8/10/18 6:07						
+Lead	1030	EPA 200.9	28	ppb	4	20 ppb	08/13/18 16:49 MCLE
8222028-02	Sample Name: #195F 2nd Draw		Matrix: Water				
	Sampled: 8/10/18 6:08						
+Lead	1030	EPA 200.9	20	ppb	4	20 ppb	08/13/18 16:49
8222028-03	Sample Name: #027DF Retest 1st Draw		Matrix: Water				
	Sampled: 8/10/18 6:13						
+Lead	1030	EPA 200.9	5	ppb	2	20 ppb	08/13/18 16:49
8222028-04	Sample Name: #027DF 2nd Draw		Matrix: Water				
	Sampled: 8/10/18 6:14						
+Lead	1030	EPA 200.9	4	ppb	2	20 ppb	08/13/18 16:49
8222028-05	Sample Name: #127DF Retest 1st Draw		Matrix: Water				
	Sampled: 8/10/18 6:19						
+Lead	1030	EPA 200.9	5	ppb	2	20 ppb	08/13/18 16:49
8222028-06	Sample Name: #127DF 2nd Draw		Matrix: Water				
	Sampled: 8/10/18 6:20						
+Lead	1030	EPA 200.9	3	ppb	2	20 ppb	08/13/18 16:49
8222028-07	Sample Name: #135DF Retest 1st Draw		Matrix: Water				
	Sampled: 8/10/18 6:24						
+Lead	1030	EPA 200.9	8	ppb	2	20 ppb	08/13/18 16:49
8222028-08	Sample Name: #135DF 2nd Draw		Matrix: Water				
	Sampled: 8/10/18 6:25						
+Lead	1030	EPA 200.9	5	ppb	2	20 ppb	08/13/18 16:49
8222028-09	Sample Name: #019DF Restest 1st Draw		Matrix: Water				
	Sampled: 8/10/18 6:29						
+Lead	1030	EPA 200.9	4	ppb	2	20 ppb	08/13/18 16:49
8222028-10	Sample Name: #019DF 2nd Draw		Matrix: Water				
	Sampled: 8/10/18 6:30						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	08/13/18 16:49



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 08/14/2018
Received: 08/10/2018
Sampled By: Adam Ponce
Work Order: 8222028

C
L
I
E
N
T

David Douglas School District

Attn: Troy Thompson
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:

Project # : N/A
Sample Type :

Sampling Location: North High School

Lab Number

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director