



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 08/27/2018
Received: 08/15/2018
Sampled By: Adam Ponce
Work Order: 8227012

CLIENT
David Douglas School District
Attn: Troy Thompson
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project #: N/A
Sample Type:
Sampling Location: North High
Sample Matrix: Water

Lab Number

Table with 8 columns: Lab Number, Code, Method, Result, Units, MRL, EPA MCL*, Analysis Date/ Time. Row 1: 8227012-01, Sample Name: #183DF Retest, Sampled: 8/15/18 6:05, Matrix: Water. Row 2: †Lead, 1030, EPA 200.9, 6, ppb, 2, 20 ppb, 08/17/18 16:32

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:

Handwritten signature of Adriana Gonzalez-Gray

Adriana Gonzalez-Gray
Laboratory Director