

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 09/16/2015
Received: 09/08/2015
Sampled By:
Work Order: 5251024

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project: -
Project #: N/A
PWSID #: -


Sampling Location: South High School
Sample Matrix: Water

Lab Number	Sample Name	Sampled: 9/8/15 12:00		Sample Composition:					
5251024-01	Main DW								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
+Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	09/15/15 16:32	

Lab Number	Sample Name	Sampled: 9/8/15 12:05		Sample Composition:					
5251024-02	DF-1 #1 @ S Gym								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
+Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	09/15/15 16:32	

Lab Number	Sample Name	Sampled: 9/8/15 12:00		Sample Composition:					
5251024-03	DF-1 #1 @ #239								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
+Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	09/15/15 16:32	

ND = None detected MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit
†All procedures for this analysis conform to NELAC standards.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.